

January 29, 2015

File: L020

Dave Fox
Acting Head Environmental Assessment North
Environment Canada
5019 52nd St
P.O. Box 2310
Yellowknife, Northwest Territories
X1A 2P7

Mathew Seaboyer
Air Quality Programs Coordinator
Government of the Northwest Territories
Environment and Natural Resources
5102 – 50th Ave,
Yellowknife, Northwest Territories
X1A 2L9

Dear Mr. Fox and Mr. Seaboyer:

**Re: De Beers - Snap Lake Mine
Incinerator Stack Testing**

De Beers Canada Inc. (De Beers) Snap Lake Mine committed to conducting incineration stack testing in 2014 for its two (2) Ketek incinerators (model CY-100-CA) that were installed in 2013. De Beers is pleased to provide the following incinerator stack testing summary for your information.

Desired Emissions Targets in the NWT:

Air quality management and emissions are important global considerations, and as a company De Beers strives in mine planning to minimize our operational footprint. With regards to air emissions there are currently no regulated emissions standards, or enabling legislation in the Northwest Territories for incinerators. De Beers notes that the Mackenzie Valley Land and Water Board (MVLWB) does not regulate air emissions in the Northwest Territories.

As per the Environmental Agreement, De Beers Air Quality and Emission Monitoring Management Plan (AQEMMP) and Programs are to correspond with Articles VI Section 6.3 d) and e) and Article VI Section 7.2 part a).

DE BEERS

GROUP OF COMPANIES

Section 3.2 of the AQEMMP, requires De Beers to conduct Emission Estimates at the Snap Lake Mine, which was approved by the GNWT and EC. The AQEMMP states in Section 3.2 item 4) the emission estimate is “*to demonstrate De Beers’ commitment to ongoing minimization of emissions.*”

The AQEMMP; Section 3.2.2.5 Dioxins, Furans and Mercury Calculation Methods states that De Beers would conduct “*intermittent*” stack sampling to estimate incinerator emissions and compare this to the Canadian Council of the Ministers of Environment (CCME) Canada Wide Standards for Dioxins, Furans and Mercury Emissions.

Deficiencies, as measured against the Canada Wide Standards, will be managed through adaptive management and continuous improvement by De Beers.

Air Emissions Monitoring:

A. Lanfranco and Associates Inc. (Lanfranco) of Surrey British Columbia, were retained to conduct the stack testing of the camp waste incinerators at the Snap Lake Mine. A final report was issued in September 2014 and has been included as Appendix I. A summary of the Mercury, Dioxin and Furan results are provided in Table 1.

Table 1: Stack Testing Results- Snap Lake Mine Camp Waste Incinerators

		Incinerator 1				Incinerator 2			
Parameter	Units	Trial 1	Trial 2	Trial 3	Average	Trial 1	Trial 2	Trial 3	Average
Mercury (corrected to 11%O ₂)	ug/m ³	0.02	0.03	0.07	0.04	0.04	0.04	0.04	0.04
Temperature (Secondary Unit)	°C	996	1003	980	993	997	994	1005	999
Dioxins and Furans TEQ (corrected to 11%O ₂)	pg/m ³	84	580	902	522	1482	7921	6258	5220

DE BEERS

GROUP OF COMPANIES

Stack Testing Results Summary:

Based upon the incinerator stack testing conducted by Lanfranco, the camp waste incinerators at the Snap Lake mine have dioxin and furan emissions above the CCME Canada Wide Standards (CWS)(80 pg/m³); Incinerator 1 (522 pg/m³) and Incinerator 2 (5220 pg/m³) exceed this standard.

For Mercury emissions the CWS is 20 ug/m³. Both incinerator 1 (0.04 ug/m³) and incinerator 2 (ug/m³) were well below this limit.

De Beers Adaptive Management Approach:

De Beers has committed to employing adaptive management as a core principle when operational issues arise with respect to air quality management as per Article VI, Section 7.2 of the Environmental Agreement. As a result of the elevated Dioxin and Furan emissions noted in the Lanfranco report, an adaptive management response has been triggered consisting of evaluation of results and adjustment of management practices to implement solutions.

Root Cause Analysis for Elevated Dioxins and Furans:

De Beers' root cause analysis began with a detailed analysis of the Lanfranco stack testing report. From the report two key issues were identified that may have resulted in elevated results for dioxin and furans:

1. Opaque smoke: Black opaque smoke was noted for all tests early in the incineration cycle.
2. Temperature: The incineration equipment did not consistently achieve primary (600°C) and secondary (1000°C) minimum temperatures for the complete destruction of dioxin and furans.

De Beers explored the potential deficiencies looking for commonality between the two issues; opaque smoke and low temperature as both issues were consistent themes that were identified as potential causes of the elevated levels of dioxins and furans. Upon investigation, a primary cause of opaque smoke is insufficient temperature as indicated in the Ketek manual. Lanfranco noted in their report that if the insufficient primary and secondary temperatures were rectified this may reduce the amount of dioxin and furan production. This is consistent with Environment Canada's *Technical Document for Batch Waste Incineration* where it states "It is known that at temperatures in excess of 600C, any PCDD/F will be destroyed"

A detailed internal root cause analysis was conducted to determine the main cause of elevated dioxin/furans identified during the incinerator testing. It is important to note

that both incinerators had undergone a routine inspection by the manufacturer one week prior to stack testing.

The root cause was:

1. Not following standardized work practices.

Adaptive Management Response:

To rectify the condition and emphasize the importance of standardized work procedures, all site services staff with responsibilities for the camp incinerator were retrained, and detailed instructions were incorporated into the operators Safety Health and Environment Operating Procedure (SHEOP).

Specifically the SHEOP was modified to include:

- Visual confirmation check of refractory and secondary temperatures. If temperatures are not achieved during the incineration run, the operator must notify supervision and environment departments to determine the cause of the failure. If safe to do so the incineration run should be shut down.
- Visual confirmation and Inspection of the refractory, nozzles and air intakes to ensure that they are intact and no blockages are present.
- A supervisory check has been included for the removal of ash after each incineration run.

DE BEERS

GROUP OF COMPANIES

Conclusion:

De Beers is committed to ensuring that waste management practices at the Snap Lake Mine are protective of the environment. De Beers notes that currently in the NWT stack testing is not a regulated practice, and in the interim De Beers will ensure that its commitments to our stakeholders are upheld through the Environmental Agreement, Land and Water Board Authorizations and through consultation with our partners. De Beers highlights that it will conform with any regulatory requirements regarding incinerator stack testing once enabling legislation is developed and approved in the NWT.

As a result of the Lanfranco report finalized in September 2014, De Beers has implemented operational practices aimed at addressing the root cause of the elevated dioxin and furan production.

As per the Environmental Agreement, De Beers had committed to performing intermittent stack testing as per Section 3.2.2.5 Dioxins, Furans and Mercury Calculation Methods of the AQEMMP. This letter and attached report satisfies the commitment made by the Snap Lake Mine. De Beers will continue to employ best management practices and adaptive management based upon the findings of this study. Additionally De Beers will continue to improve standard practices to maintain camp waste incinerators operation at optimal levels. This report fulfills De Beers commitment for the Environmental Agreement to stack test the new Ketek incinerators installed in 2013.

Should you have any questions, comments or require further clarification, please do not hesitate to contact me at 767-8646 or email me at the following address: Alexandra.Hood@debeerscanada.com

Sincerely,



Alexandra Hood
Environment and Permitting Superintendent
Snap Lake Mine

Cc:

S. LaceyMcMillan
P.di Pizzo, Z. Liu

EC
SLEMA

DE BEERS

GROUP OF COMPANIES

Appendices

Appendix I – Lanfranco

**EMISSION COMPLIANCE SURVEY
MONITORING REPORT
(De Beers, Snap Lake Incinerators)
(July 2014)**

**Prepared for
De Beers Group of Companies Canada
Yellowknife, NT**

**Prepared by
A. LANFRANCO & ASSOCIATES INC.
Surrey, B.C.**

September 2014

Certification

The monitoring of the incinerators was conducted by three (two certified) stack test technicians.


The field crew consisted of,

Mr. C. Lanfranco (certified), Mr. L. Agassiz (certified) and Mr. S. Ferguson.


The report was prepared by Mr. M. Lanfranco using reporting principles and guidelines generally acceptable to Environment Canada and US EPA. Final report review was conducted by Mr. C. Lanfranco.

The field crew certifies that the test methods used were Environment Canada or EPA reference methods for the parameters investigated.

Mark Lanfranco

A large, stylized handwritten signature in black ink, appearing to read 'Mark Lanfranco', written over the printed name.

Report reviewed by:

A smaller, stylized handwritten signature in black ink, appearing to read 'Carter Lanfranco', written over the printed name.

Carter Lanfranco

TABLE OF CONTENTS

	Page
SUMMARY	i
1.0 INTRODUCTION	1
2.0 PROCESS DESCRIPTION/TEST OPERATIONS	2
3.0 METHODOLOGY	3
3.1 Preparation Techniques	4
3.2 Sampling Techniques	5
3.3 Analytical and Sample Recovery Techniques	9
3.3.1 Organic Sample Analysis	10
3.3.2 Particulate/Hg Sample Recovery/Analysis	10
3.4 Quality Assurance/Quality Control Techniques	11
4.0 RESULTS	12
4.1 QA/QC Results	18
5.0 DISCUSSION OF RESULTS	19
APPENDICES	
Appendix 1 - Computer Outputs of Measured and Calculated Data	
Appendix 2 - Analytical Data	
Appendix 3 - QA/QC Results	
Appendix 4 - Field Data Sheets and Process Data	
Appendix 5 - Calibration Data	

LIST OF TABLES

Table 1	Incinerator 1 Emission Results
Table 1a	Detailed PCDD/PCDF Emission Results
Table 2	Incinerator 2 Emission Results
Table 2a	Detailed PCDD/PCDF Emission Results
Table 3	Incinerator Stack Particulate Gravimetric Results
Table 4	Process Summaries

LIST OF FIGURES

Figure 1	Semi-Volatile (Dioxin/Furan) Organics Sampling Train
Figure 2	Particulate/Hg Sampling Train
Figure 3	Dioxin/Furan Sample Recovery Schematic
Figure 4	Extraction Schematic for Stack Samples
Figure 5	Schematic of Analytical Methodology for PCDD/PCDF

SUMMARY

The following table presents the triplicate test averages for the listed parameters from the Westland Incinerator stacks at Snap Lake on July 11-15, 2014.

PARAMETER	Incinerator 1	Incinerator 2	CWS Emission Limits
Particulate (mg/Rm ³ @ 11% O ₂)	59.8	79.3	N/A
Particulate (Kg/hr)	0.095	0.129	N/A
Hg (ug/Rm ³ @ 11% O ₂)	0.04	0.04	20
Hg (g/hr)	<0.0001	<0.0001	N/A
Flowrate (Rm ³ /min) *	18.4 (18.1)*	17.2 (17.4)*	N/A

PARAMETER	Incinerator 1	Incinerator 2	CWS Emission Limits
PCDD & PCDF TEQ (pg/Rm ³ @11% O ₂)	522	5220	80

* PCDD Flowrate results

N/A = not applicable

See Tables 1 and 2 for individual results

Note: values presented in boldface are results which have CWS permitted limits.

Concentrations and flow rates are expressed at standard conditions of 25°C and 101.3 KPa (dry).

Rm³ = reference cubic meter

1.0 INTRODUCTION

De Beers Mining Canada retained A. Lanfranco and Associates Inc. of Surrey, B.C., Canada to conduct an emission monitoring survey at the refuse incinerators located at Snap Lake, NT. The purpose of the survey was to measure and report emission levels of particulate, dioxins/furans (PCDD/PCDF), and mercury from the incinerator stacks during the firing of a normal mixture of camp refuse.

The survey is the initial emission monitoring of the incinerators in response to the emission survey requirements of the Canada Wide Standards (CWS). The CWS require, by 2006, emission measurements of dioxin/furan and mercury.

This report documents the methods used and results determined for triplicate stack samples from the twin incinerator stacks collected on July 11-15, 2014

The report also presents QA/QC results for spiked samples and all blank samples.

2.0 PROCESS DESCRIPTION/TEST OPERATIONS

The incinerators operated at Snap Lake were twin Model CY100CA D - two stage incinerators. The incinerators utilize a primary combustion chamber and secondary afterburner section, and are equipped with a six meter (nominal) refractory lined smokestack.

Following cleaning, and prior to waste introduction, the secondary chamber was pre-heated to approximately 1000 °C. The waste was manually introduced to the primary chamber via the main charge door prior to primary ignition. Testing commenced at a pre-determined time and once the primary chamber reached the 600°C set point.

Approximately 254 to 480 kg of waste, including a mixture of wet and dry waste described as “household waste” were loaded for each day. The operating procedure requires that each charge of waste to be incinerated during a twenty four hour time period.

The day to day test schedule for **Incinerator 1** was:

<u>Date</u>	<u>Charge Size (weighed)</u>	<u>Test Matrix</u>
July 11, 2014	480 kg	one dioxin/furan test and one Hg test
July 12, 2014	410 kg	one dioxin/furan test and one Hg test
July 13, 2014	454 kg	one dioxin/furan test and one Hg test

The day to day test schedule for **Incinerator 2** was:

<u>Date</u>	<u>Charge Size (weighed)</u>	<u>Test Matrix</u>
July 13, 2014	370 kg	one dioxin test and one Hg test
July 14, 2014	390 kg	one dioxin/furan test and two Hg tests
July 15, 2014	254 kg	one dioxin/furan test

note: O₂/CO₂, temperatures and velocities measured throughout the test program with EC reference techniques.

Waste Feed Charging Schedule and Test Start Times

In general, the incinerator was charged and the system was allowed to stabilize for about fifteen to twenty minutes prior to sample commencement. Once charged initially, the incinerator was not recharged during the emission survey. In other words, samples were collected during the first six hours of the incineration process. Details of the sampling initiation are as follows:

Incinerator 1

D/F Test 1 – July 11, 2014 commenced 60 minutes after Primary ignition
D/F Test 2 – July 12, 2014 commenced 40 minutes after Primary ignition
D/F Test 3 – July 13, 2014 commenced 20 minutes after Primary ignition
PM/Hg Test 1 – July 11, 2014 commenced 100 minutes after Primary ignition
PM/Hg Test 2 – July 12, 2014 commenced 60 minutes after Primary ignition
PM/Hg Test 3 – July 13, 2014 commenced 20 minutes after Primary ignition

Incinerator 2

D/F Test 1 – July 13, 2014 commenced 20 minutes after Primary ignition
D/F Test 2 – July 14, 2014 commenced 40 minutes after Primary ignition
D/F Test 3 – July 15, 2014 commenced 60 minutes after Primary ignition
PM/Hg Test 1 – July 13, 2014 commenced 20 minutes after Primary ignition
PM/Hg Test 2 – July 14, 2014 commenced 60 minutes after Primary ignition
PM/Hg Test 3 – July 15, 2014 commenced 100 minutes after Primary ignition

3.0 METHODOLOGY

The sampling and analytical methods used throughout this survey conform to the procedures outlined in the Environment Canada emission monitoring reference method manuals, and supplementary EPA reference methods. Specifically, the methods used were:

<u>Parameter</u>	<u>Reference Method</u>
Particulate Matter/Mercury	EPS Method 8 with EPA Method 29 (metals)
Sample and velocity traverse points	EPS Method 8 A
Velocity and flowrate	EPS Method 8 B
Oxygen (O ₂ for corrections to 11%)	EPA CTM 34 (as approved by Env. Canada)
Gas molecular weight (O ₂ /CO ₂)	EPS Method 8 C
Flue gas Moisture	EPS Method 8 D
Dioxin/furan	EPS Method 1/RM/2 with 1/RM/3 analysis

3.1 Preparation Techniques

The preparation, cleaning, and proofing of the sampling equipment and materials is an integral part of the quality assurance/quality control (QA/QC) component of each stack survey. Following are details of the cleaning and proofing of relevant sample train components.

Organic (Dioxin) Train Glassware

1. Washed twice with industrial strength cleaner/detergent
2. Rinsed with generous amounts of deionized H₂O
3. Rinsed three times with methylene chloride
4. Rinsed three times with hexane
5. Rinsed three times with acetone
6. Oven baked at 300°C overnight
7. Rinsed three times with hexane (saved for proofing)
8. Rinsed three times with acetone (saved for proofing)

Amberlite XAD-2

1. Rinsed and extracted with deionized H₂O
2. Soxhlet extraction with methanol, methylene chloride and toluene (22 hrs each)
3. Nitrogen purge
4. Oven dried @ 50°C
5. Approx. 40 gram aliquot saved for proofing
6. Individual sample traps packed and spiked with surrogate regime

Organic filters

1. Soxhlet extraction (16 hrs) with toluene
2. Nitrogen drying
3. Save 1 filter for proofing

Metal Train Glassware

1. Hot detergent wash with brushing
2. Rinse with 0.1 N HNO₃
3. Copious rinsing with deionized H₂O
4. Oven drying at 105°C

Metal Train Filters

1. Overnight extraction with 1:1 nitric acid
2. Overnight rinsing with deionized H₂O
3. Drying for 2 hrs @ 105°C, desiccation and weighing
4. Save 1 filter for blank

Other Glassware

1. Hot detergent wash with brushing
2. Copious deionized H₂O rinses

3.2 Sampling Techniques

Following are brief descriptions of the reference method sampling techniques utilized to collect the various samples. The techniques employed for isokinetic sampling of particulate/metals and dioxin/furan from this source were consistent and complied with the previously referenced stack testing methods.

EPS Method 8a - Sampling Site and Traverse Points

The stack sampling location was located about 7.3 diameters downstream and 1.8 diameters upstream of the nearest flow disturbances. From these criteria, and measured stack diameters of 16.0 inches, and Figure A-1 of EPS Method A, a 24 point sampling regime, where 12 points along 2 - 90° traverses were sampled for each isokinetic stack test. Test point locations for the incinerator stacks are presented in the following table.

Point	Distance from Wall
1	0.3 used 1.0 inch
2	1.1
3	1.9
4	2.8
5	4.0
6	5.7
7	10.3
8	12.0
9	13.2
10	14.1
11	14.9
12	15.7 used 15.0 inch

EPS Method 8b - Stack Gas Velocity and Volumetric Flowrate

At each traverse point a series of measurements including stack temperature, velocity pressure, static pressure, and sampling rate were recorded. Velocity and static pressures were measured with a calibrated S-type pitot tube mounted alongside the sample probe. Stack temperatures were measured with a calibrated K-type chromel-alumel thermocouple with a control console mounted digital readout. Cyclonic flow angles were measured using the null velocity technique.

EPS Method 8c/EPA CTM 34 - Molecular Weight by Gas Analysis

Stack gas molecular weight for O₂ was determined by the portable CEM system and was validated by a series of grab samples which were analyzed on site for O₂ and CO₂ by Fyrite analyzers. A minimum of four to a maximum of eight grab samples per traverse were collected. O₂ readings were taken every ten to fifteen minutes and were hand entered on the field data sheets. The Fyrite Tech Analytical O₂ analysers were calibrated (zero and span) at one to two hour intervals as required by EPA CTM 34. Compressed N₂ was used for zero, and ambient air was used for span. The CEM system results were averaged for insertion in the computer programs for final result calculations and corrections to 11% O₂.

EPS Method 8d - Moisture Content

Stack gas moisture content was determined from the measured condensed water vapour which was collected in the impinger (cold box) section of the sampling trains, and the gas volume sampled corrected to standard conditions of 25°C and 101.3 KPa (dry).

The contaminants investigated during this survey were collected with two independent sampling trains as follows:

EPS 1/RM/2 - Dioxin/Furan

This sample train was assembled and leak checked at the laboratory the night prior to testing. Prior to sampling initiation, the stack train was assembled as shown in Figure 1 and leak checked to code specifications. The probe (quartz lined) and filter module were heated to 120 +/- 15°C and crushed ice was placed around the impingers. Iced water was circulated in the condenser and in a cooling jacket around the XAD cartridge. Once the sampling system achieved the appropriate temperatures the probe tip was positioned at point No.1, isokinetic sampling was performed using the K_o orifice constant sampling procedure. A set of recordings was taken every five minutes until two sets of readings for each sample point of traverse one was achieved. The sample pump was shut off and the sample module with attached probe was withdrawn from the stack.

The system was repositioned at point No. 1 of the next traverse and an additional 120 (12 points for 10 minutes each) minutes of sampling commenced. This regime was continued until both sample ports had been sampled. The total sample volume for each PCDD/PCDF test was 4.2 to 4.8 Rm³.

At the conclusion of the final traverse sampling the train was final leak checked and the probe was disassembled from the hot box/sample module.

Any open ends of the sampling module and probe assembly were immediately sealed with pre-cleaned aluminium foil or teflon tape, and leak checks were conducted with only teflon tape touching the open ends.

At the conclusion of each test the sample module and probe were lowered from the stack location and were in transport to the laboratory without delay. Approximately twenty minutes elapsed from sample conclusion to sample delivery at the sample recovery "laboratory".




Figure 1 – Semi-Volatile (Dioxin/Furan) Sampling Train

Note – The above diagram depicts a US EPA 23 train. The train used for EC 1/RM/2 at Snap Lake is identical in all respects except that the two HPLC water impingers were replaced with one impinger containing 100 ml of ethylene glycol.

EPS Method 8/EPA 29 - Particulate, Hg

This train was a normal Method 29 train (Fig. 2) except special (low metal) microquartz glass filters were utilized and the impinger components were:

Incinerator Stack Impingers

- 100 ml 5% HNO₃ in 10% H₂O₂
- 100 ml 5% HNO₃ in 10% H₂O₂
- Empty
- 100 ml 4% KMnO₄ in 10% H₂SO₄
- 100 ml 4% KMnO₄ in 10% H₂SO₄
- 100 ml distilled H₂O
- 200 g silica gel

The train was operated isokinetically, sampling a total of 12 points on 2 - 90° traverses for five minutes each, resulting in final sample volumes of about 2.5 to 2.8 Rm³. Data recordings were conducted at five minute intervals. The train utilized a three foot quartz probe and nozzle.




Figure 2: EPA Method 29 Particulate/Hg Sampling Train

3.3 Analytical and Sample Recovery Techniques

Following sampling for PCDD/PCDF, the sample train was sealed and transported to the field laboratory for sample recovery. At the laboratory the sample train was disassembled and six components were identified for each train. The recovery of each sample is described below:

1. Sample Filter: The exposed sample filter was removed from its holder with clean tweezers, placed on a sheet of aluminium foil, folded inside the foil and sealed in a glass petri dish. This was labelled component 1 of each test.
2. Front/Back Half Washings: This included a thorough acetone/hexane rinsing and brushing of the sample nozzle, probe liner, and connecting glassware prior to the filter. These washings were collected in a pre-cleaned one litre amber sample bottle with a teflon lined lid. This was labelled component 2 of each test. The back half of the filter holder and glassware connecting the filter holder to the condenser were rinsed and soaked with acetone and hexane with the solvents added to the component 2 sample bottle.
3. Amberlite XAD-2 Resin Trap: The resin trap was sealed with teflon tape, covered with aluminium foil and kept at about 4 °C prior to shipment to the analytical laboratory. This was labelled component 3 of each test.
4. Impinger Condensate: The condensate contained in the condensate trap, plus water and condensate from the impingers was measured for volume and collected in pre-cleaned amber bottles. These samples were labelled component 4 for each test.
5. Soak: The glassware connecting the filter to the XAD module was soaked with hexane and acetone sequentially, three times, with all “soaks” and rinses collected in 1 litre amber sample bottles.
6. Final Rinse: All glassware was rinsed with hexane and acetone, sequentially three times into amber sample bottles.

All samples were labelled appropriately and placed in a cold room at 4°C until analysis was initiated. Each bottle containing solvent was marked with the liquid level and the lid was sealed.

3.3.1 Organic Sample Analysis

The organic analysis of the sample train components involved an extremely complex series of procedures as detailed in the analytical manuals.

Following is a description, in very simplified terms, of the basic procedures used to process the sample train components.

Initially the sample components are separated into liquid (containers 2,4,5,6) or solid phases (containers 1 and 3) Figure 3. Solid samples are extracted with various solvents (usually toluene), sometimes under acid conditions. The liquid samples are extracted and concentrated with a rotary evaporator, with the final concentrate added to the filter and XAD components. At this point, an internal standard solution is added to the sample for QA/QC recovery determinations. The extraction and concentrating of the various train components are shown in Figure 4.

The toluene rinse has internal standards added, with subsequent concentration by rotary evaporation. The extract volumes are fractionated, cleaned-up and analyzed by high resolution GC/MS analytical instrumentation (Figure 5).

3.3.2 Particulate/Hg Sample Recovery/Analysis


The particulate sample filters were removed from the cooled filter housing with teflon coated tweezers, with material retained on the gasket recovered with a nylon brush and added to the filter. The filter was folded and placed in an identified plastic petri dish or envelope labelled Container 1 with date, time and run number.

Sample clean-up of the probe and front half glassware from the Hg/particulate train was conducted with sequential rinses and brushings with acetone collected in Container 2.

Impingers 1 and 2 were measured for volume and transferred with about 100 ml of deionised water to a glass sample container. Impingers 3, 4, and 5 were transferred to a glass sample container using 100 ml potassium permanganate and water rinses. HCl rinses of the permanganate impingers were not conducted as visible deposits were effectively removed by the earlier rinsing.

Silica gel from the final impinger was transferred to its original container for final weighing.

Blank filters and solutions for each component of the particulate Hg test were collected and labelled appropriately.



Container or Sample	Component(s)	Recovery Procedure
1	1, 2, 3, 4	Wash and brush 3 times each with hexane (H) and acetone (A). Rinse 3 times each with H and A.
2	5	Remove carefully from holder. Place on pre-cleaned foil. Fold in half. Place in pre-cleaned glass petri dish.
3	6, 7	Soak 5 minutes each with H and A. Rinse 3 times each with H and A.
4	8	Cap ends and wrap in foil.
5	9, 12	Empty contents into container and rinse each 3 times with HPLC water.
6	6 to 15 except 8	Rinse 3 times each with H and A.

Mark liquid levels on all bottles.
 All sample containers are pre-cleaned amber glass bottles with pre-cleaned Teflon lid liners.

FIGURE 3. SEMI-VOLATILE ORGANICS RECOVERY PROCEDURES




Fig 4 - Extraction schematic diagram for stack samples and components




Fig.5 Schematic of analytical methodology for Dioxin and Furan

Gravimetric Analysis

At A. Lanfranco and Associates Surrey, B.C. laboratory, the sample filters were desiccated to constant weight and weighed as per EPA Method 5. Probe and front-half acetone rinsings were evaporated at about 50°C in tared, pre-cleaned 250 ml glass beakers, with subsequent weighing to constant weight. Blank filters and acetone were carried through the gravimetric process.

Hg Analysis

Following the gravimetric analysis, the filters and wash residues, along with the back half liquid samples were forwarded to Exova Laboratories in Surrey, B.C. for analysis of Hg. The samples and appropriate blanks were digested with acids and analyzed for Hg by ICAP procedures. Impingers 1, 2, 3, 4 and 5, for Hg, were analyzed at Exova using flameless atomic absorption.

3.4 Quality Assurance / Quality Control (QA/QC) Techniques

The QA/QC component of this survey was designed to exceed the requirements normally instituted by the regulatory agency. Additionally, QA/QC of this survey was accomplished by the following mechanisms.

1. Pre and Post-test leak checks
2. Calibration of volume measuring and monitoring instrumentation
3. Proofing of organic glassware and supplies (archived proofs)
4. Analysis of all blank solutions and materials
5. Spiking and recovery analysis of organic trains
6. Use of acid cleaned microquartz filters
7. Duplicate analysis of selected samples
8. Reference material analysis with samples
9. Labelling and record-keeping
10. Surrogate spiking of dioxin trains using EPA protocols
11. O2 analyser calibration using compressed zero gas

A "Blank" test was conducted, with that sampled analysed in the same manner as test samples.

4.0 RESULTS

Most of the stack testing results were calculated using a "STACK" computer program developed for EPA and Canadian requirements. Standard conditions used in the program are 25 °C and 29.92 "Hg (dry basis)

Corrections to 11% O₂ were calculated by multiplying the determined stack concentrations by;

$$\frac{20.9-11.0}{20.9- \text{measured O}_2}$$

Tables 1 and 2 present the detailed triplicate test data for Particulate, Hg, and flowrate, as well as supporting data such as temperatures, O₂/CO₂ and stack gas moistures.

PCDD/PCDF results are presented in Tables 1a and 2a. Tables 1a and 2a present the detailed triplicate test data for PCDD/PCDF in terms of actual amounts detected and toxic equivalents. In addition, all dioxin/furan results were recovery corrected according to surrogate recovery efficiencies determined for each organic analysis. Surrogates added and the recoveries determined are listed in the analytical data presented in the Appendices.

Table 3 presents particulate gravimetric results, and Table 4 presents process data.

Please note that data from the Hg and dioxin tests vary slightly for O₂, temperature and flowrates due to the timing of each test.

TABLE 1 INCINERATOR 1 EMISSION RESULTS

Parameter	Test 1	Test 2	Test 3	Average
Test Date	July. 11/14	July. 12/14	July. 13/14	
Test Time	13:50-16:00	10:26-14:05	14:50-17:13	
Duration (minutes)	120	120	120	120
Particulate (mg/Rm3)	68.2	78.9	111.1	86.1
Particulate (mg/Rm3 @ 11% O ₂)	41.9	57.7	79.8	59.8
Particulate (Kg/hr)	0.078	0.085	0.123	0.095
Particulate (Kg/day)	1.9	2.0	2.9	2.3
Hg (ug/Rm3 @ 11% O ₂)	0.02	0.03	0.07	0.04
SO _x (mg/Rm3 @ 11% O ₂)	56.0	73.0	35.0	54.7
Flowrate (Rm3/min)	19.0	18.0	18.4	18.4
Flowrate (acm/min)	97.0	90.8	91.4	93.1
Temperature (°C)	996	1003	980	993
O ₂ (vol % dry)	4.8	7.4	7.1	6.4
CO ₂ (vol % dry)	11.0	9.8	10.3	10.4
H ₂ O (vol %)	11.9	11.2	11.7	11.6
Isokinetic Variation (%)	101.2	99.9	99.6	100

standard conditions of 25 deg C and 101.3kPa

TABLE 1a Detailed PCDD/PCDF Emission Results

Client: De Beers, Snap Lake
Jobsite: Snap Lake Mine
Source: Incinerator Stack #1

Component	TEF	Test 1 (July 11, 2014)		Test 2 (July 12, 2014)		Test 3 (July 13, 2014)	
		Analyzed (ng)	TEQ (ng)	Analyzed (ng)	TEQ (ng)	Analyzed (ng)	TEQ (ng)
2378 TCDD	1.0000	0.0010	0.0010	0.0540	0.0540	0.1300	0.1300
12378 PCDD	0.5000	0.2100	0.1050	1.0000	0.5000	0.7500	0.3750
123478 HxCDD	0.1000	0.2200	0.0220	1.6000	0.1600	0.8400	0.0840
123678 HxCDD	0.1000	0.2500	0.0250	1.1000	0.1100	1.4000	0.1400
123789 HxCDD	0.1000	0.2500	0.0250	0.9400	0.0940	1.1000	0.1100
1234678 HpCDD	0.0100	2.0000	0.0200	19.0000	0.1900	22.0000	0.2200
OCDD	0.0010	3.5000	0.0035	53.0000	0.0530	53.0000	0.0530
2378 TCDF	0.1000	0.1200	0.0120	0.2000	0.0200	0.5200	0.0520
12378 PCDF	0.0500	0.1600	0.0080	0.5900	0.0295	1.3000	0.0650
23478 PCDF	0.5000	0.3700	0.1850	1.3000	0.6500	2.5000	1.2500
123478 HxCDF	0.1000	0.3600	0.0360	1.7000	0.1700	3.5000	0.3500
123678 HxCDF	0.1000	0.4500	0.0450	3.1000	0.3100	4.9000	0.4900
234678 HxCDF	0.1000	0.8500	0.0850	7.6000	0.7600	12.0000	1.2000
123789 HxCDF	0.1000	0.1700	0.0170	1.2000	0.1200	2.8000	0.2800
1234678 HpCDF	0.0100	2.3000	0.0230	22.0000	0.2200	23.0000	0.2300
1234789 HpCDF	0.0100	0.3500	0.0035	3.2000	0.0320	11.0000	0.1100
OCDF	0.0010	1.2000	0.0012	21.0000	0.0210	45.0000	0.0450
Summed PCDD & PCDF TEQ (ng)			0.617		3.494		5.184
Sample Volume (Rm3)			4.770		4.231		4.400
PCDD & PCDF TEQ ng/Rm3			0.129		0.826		1.178
PCDD & PCDF TEQ ng/Rm3 (@11% O2)			0.084		0.580		0.902
PCDD & PCDF TEQ grams/day			0.000004		0.000021		0.000030
Particulate mg/dscm (@ 11% O2)			41.9		57.7		79.8
SOx mg/dscm (@ 11% O2)			56.0		73.0		35.0
Hg ug/dscm (@ 11% O2)			0.02		0.03		0.07
Flowrate (Rm3/min)			18.9		17.7		17.6
Oxygen (Vol. %)			5.6		6.8		8.0
Carbon Dioxide (Vol. %)			10.8		10.2		9.1
Carbon Monoxide (ppm)			0		0		0
Moisture (Vol. %)			11.5		12.0		11.9
Temperature (oC)			986.4		1008.2		990.7
Isokinetic Variation (%)			102.7		97.6		101.8

*Particulate emission results from Hg tests

TABLE 2 INCINERATOR 2 EMISSION RESULTS

Parameter	Test 1	Test 2	Test 3	Average
Test Date	July. 13/14	July. 14/14	July. 15/14	
Test Time	09:33-11:45	13:50-14:07	10:15-12:33	
Duration (minutes)	120	120	120	120
Particulate (mg/Rm3)	140.8	147.9	84.9	124.5
Particulate (mg/Rm3 @ 11% O ₂)	80.3	99.3	58.2	79.2
Particulate (Kg/hr)	0.149	0.149	0.088	0.129
Particulate (Kg/day)	3.6	3.6	2.1	3.1
Hg (ug/Rm3 @ 11% O ₂)	0.04	0.04	0.04	0.04
SO _x (mg/Rm3 @ 11% O ₂)	33.0	59.0	58.0	50.0
Flowrate (Rm3/min)	17.6	16.8	17.3	17.2
Flowrate (acm/min)	91.8	86.0	90.0	89.3
Temperature (°C)	997	994	1005	999
O ₂ (vol % dry)	3.5	6.2	6.5	5.4
CO ₂ (vol % dry)	12.9	10.8	10.7	11.5
H ₂ O (vol %)	14.7	13.2	13.0	13.6
Isokinetic Variation (%)	104.9	102.4	100.6	103

standard conditions of 25 deg C and 101.3kPa

TABLE 2a Detailed PCDD/PCDF Emission Results

Client: De Beers, Snap Lake
Jobsite: Snap Lake Mine
Source: Incinerator Stack #2

Component	TEF	Test 1 (July 13, 2014)		Test 2 (July 14, 2014)		Test 3 (July 15, 2014)	
		Analyzed (ng)	TEQ (ng)	Analyzed (ng)	TEQ (ng)	Analyzed (ng)	TEQ (ng)
2378 TCDD	1.0000	0.3400	0.3400	9.2000	9.2000	2.2000	2.2000
12378 PCDD	0.5000	1.8000	0.9000	20.0000	10.0000	14.0000	7.0000
123478 HxCDD	0.1000	3.9000	0.3900	6.8000	0.6800	16.0000	1.6000
123678 HxCDD	0.1000	4.6000	0.4600	11.0000	1.1000	24.0000	2.4000
123789 HxCDD	0.1000	3.4000	0.3400	7.8000	0.7800	16.0000	1.6000
1234678 HpCDD	0.0100	64.0000	0.6400	45.0000	0.4500	69.0000	0.6900
OCDD	0.0010	127.0000	0.1270	47.0000	0.0470	117.0000	0.1170
2378 TCDF	0.1000	2.3000	0.2300	34.0000	3.4000	7.4000	0.7400
12378 PCDF	0.0500	4.2000	0.2100	38.0000	1.9000	17.0000	0.8500
23478 PCDF	0.5000	4.9000	2.4500	25.0000	12.5000	20.0000	10.0000
123478 HxCDF	0.1000	6.5000	0.6500	22.0000	2.2000	23.0000	2.3000
123678 HxCDF	0.1000	8.5000	0.8500	23.0000	2.3000	25.0000	2.5000
234678 HxCDF	0.1000	15.0000	1.5000	21.0000	2.1000	34.0000	3.4000
123789 HxCDF	0.1000	3.2000	0.3200	5.2000	0.5200	11.0000	1.1000
1234678 HpCDF	0.0100	36.0000	0.3600	33.0000	0.3300	40.0000	0.4000
1234789 HpCDF	0.0100	12.0000	0.1200	10.0000	0.1000	29.0000	0.2900
OCDF	0.0010	70.0000	0.0700	41.0000	0.0410	69.0000	0.0690
Summed PCDD & PCDF TEQ (ng)			9.957		47.648		37.256
Sample Volume (Rm3)			4.482		4.333		4.423
PCDD & PCDF TEQ ng/Rm3			2.221		10.997		8.423
PCDD & PCDF TEQ ng/Rm3 (@11% O2)			1.482		7.921		6.258
PCDD & PCDF TEQ grams/day			0.000057		0.000273		0.000207
Particulate mg/dscm (@ 11% O2)			80.3		99.3		58.2
SOx mg/dscm (@ 11% O2)			33.0		59.0		58.0
Hg ug/dscm (@ 11% O2)			0.04		0.04		0.04
Flowrate (Rm3/min)			17.9		17.2		17.1
Oxygen (Vol. %)			6.1		7.2		7.6
Carbon Dioxide (Vol. %)			10.6		10.2		10.0
Carbon Monoxide (ppm)			0		0 to 1200		0
Moisture (Vol. %)			12.3		12.2		12.4
Temperature (oC)			1000.9		1016.9		1012.8
Isokinetic Variation (%)			102.0		99.8		102.7

Table 3 Incinerator Stack Particulate Gravimetric Results

Test No.	Filter Particulate (mg)	Probe and Washings (mg)	Total Particulate (mg)
<u>Incinerator 1</u>			
1	94.9	99.2	194.1
2	97.2	112.5	209.7
3	147.6	154.8	302.4
<u>Incinerator 2</u>			
1	207.4	178.4	385.8
2	208.7	168.6	377.3
3	107.2	111.6	218.8

Table 4 Process Summary

	Nominal for all Tests
<u>Incinerator 1</u>	
Primary Temp.	600 °C
Secondary Temp	1000 °C
Load Type	normal mixture of camp refuse.
Load Size (approx)	448 kg
Load Rate	19 kg/hr (nominal)
<u>Incinerator 2</u>	
Primary Temp.	600 °C
Secondary Temp	1000 °C
Load Type	normal mixture of camp refuse.
Load Size (approx)	338 kg
Load Rate	14 kg/hr (nominal)

Detailed process data is presented in Appendix 4.

4.1 QA/QC Results

Pre and Post Test Leak Checks

Each test is required to be leak checked prior to, and following the test. The leak checks must show less than 0.02 cfm. All tests passed the code leak check requirements. Evidence of the leak checks is shown on each data sheet of appendix 4.

Equipment Calibrations

All emission monitoring equipment used for the Snap Lake camp incinerator emission monitoring was calibrated to Environment Canada specifications. Dry gas meters, pitot tubes and temperature measuring devices were calibrated within four months of the test date. See appendix 5

Proofing of Dioxin Glassware and Supplies

Although not required by Nunavut/GNWT, it is our practice to verify that the glassware and sorbent used in dioxin tests is free of contamination. Proofs of the glassware and XAD are implied by the very low Blank sample results of appendix 3.

Analysis of Blank Materials and Reagents

All blank materials and reagents yielded very low or non-detectable levels of target species.

Spiking and Recovery of Dioxin/Furan Surrogates

The recovery of the labelled surrogate samples ranged from 81 to 119. These recoveries comply with EPA Method 23 requirements of 70 to 130%. In addition, all data was recovery corrected for each congener. Recoveries of all internal standards ranged from 52 to 93%, complying with EPS 1/RM/2 and Method 23 requirements of 25 to 130% recovery.

Spiking and Recovery Assessments of Inorganic Samples

Blanks of all reagents used for sample collection were spiked to known contaminant concentrations and analyzed with the source samples. Normally a high and low spike was conducted. The various recoveries are reported on the analytical data in appendix 2. In summary the results are:

	<u>Spike 1</u>	<u>Spike 2</u>	<u>Cert Ref. Mat.</u>
Hg	96 % recovery	100 % recovery	2.32 measured for 2.42 ug true 6.88 measured for 6.88 ug true

Chain of Custody

All samples were in the possession of the stack test team until relinquishing to the courier/shipping companies used. The samples were inspected on arrival, and shipping containers were observed to be sealed on arrival, with no apparent tampering or sample loss in shipment.

Field Calibrations of O₂ Analyser

Field calibrations of the portable O₂ analyser were conducted according to the zero and span calibrations stipulated in EPA CTM 34. The O₂ analyser easily complied with the Performance Specification of +/- 0.3% drift between calibrations,

Dioxin Analytical Column

The dioxin analytical laboratory, Pacific Rim Laboratories of Surrey, B.C. used a Restek Dioxin-2 analytical column to quantify all D/F congeners, as required by the Environment Canada QA/QC document EPS 1/RM/23. This Environment Canada document requires that interfering peaks be resolved before reporting D/F concentrations.

5.0 DISCUSSION OF RESULTS

This survey was an investigation of specific emitted contaminants during the firing of waste materials normally disposed of in the Snap Lake camp incinerators. The survey included monitoring of contaminants required by Canada Wide Standards (CWS), namely dioxin/furan and mercury.

The incinerator tested, consisted of Primary and Secondary (afterburner) chambers. The combustion chambers use diesel fuel as the primary fuel.

Compliance Status

Based on the CWS and the "Guidelines for the Management of Biomedical Waste in the Northwest Territories", the test results showed that the emissions were in compliance for Hg. All six test runs for PCDD/DF at Snap Lake were above allowable limits for dioxin/furans.

Mercury

The average Hg emissions at Snap Lake were 0.04 ug/Rm³ @ 11% O₂. Compared to the emission standard of 20 ug/Rm³ @ 11% O₂, these results should be considered very low.

Mercury was found at levels above method detection limits, yielding confident quantification of Hg at the levels measured. The Hg emission results suggest that the waste feed Hg content was very low, however.

Dioxin/Furan

At Snap Lake, the Incinerator 1 average dioxin/furan emissions was 522 pg/Rm³ @ 11% O₂, compared to an emission standard of 80 pg/Rm³ @ 11% O₂. Interestingly the average was determined from a nearly compliant Test 1 (84 pg/Rm³) and two significantly high DF tests. The Incinerator 2 average dioxin emission was 5220 pg/ Rm³ @ 11% O₂ with a maximum DF level of 7921 pg/Rm³ for test 2 from this source. This test was the only test where elevated CO was observed.

Closer monitoring of the waste stream would likely drastically increase the effectiveness of the incinerators. Segregating the waste material and controlling moisture content is highly recommended, while materials of particular concern such as polyvinyl chloride and copper (known dioxin catalysts) should be processed minimally.

Close attention to both Primary and Secondary chamber temperatures should be observed, as the technicians often recorded temperatures below the advised specification of 600 deg. C Primary and 1100 deg. C Secondary.

The technicians also observed periods of extremely elevated opacity (black plume) coinciding with low Oxygen measurements, suggesting poor combustion conditions towards the beginning of sampling (during high opacity). It is likely a large percentage of the contaminants were collected during these "less than optimum" combustion periods.

Further process data is not easily formatted for reporting purposes and is available upon request.

General

Research into dioxin emissions from combustion sources has generally shown that dioxin is formed in two manners. The first mechanism is known as the “Precursor mechanism” where there is incomplete combustion and dioxin is formed by reactions of chlorine and organic aromatic compounds. The second mechanism is known as “DeNovo Synthesis”, where dioxin formation reactions occur post-combustor, in the air pollution control systems at temperatures between 200 and 450 °C.

Another well documented condition leading to higher than expected D/F emissions is known as the “memory effect”. The “memory effect” phenomenon occurs when prior operating conditions and residual emitted materials effect the subsequent test periods. In the case of batch systems, like camp incinerators, the type and amounts of waste material used in several previous burn loads (before the compliance test) could significantly impact the results of the first series of compliance tests.

The QA/QC program was successful in showing excellent analytical accuracy, in proving the avoidance of any significant sample contamination, and in maintaining leak free sampling procedures. The analysis of the dioxin/furan samples indicated complete recovery by virtue of excellent surrogate recoveries for the compounds of interest.

There were no problems encountered in sample collection or analysis and validation of the field study is provided, in large part, by the analytical QA/QC program and the use of calibrated test equipment by qualified monitoring professionals. The test results, therefore, are reported with confidence and are considered an accurate representation of emission characteristics for the process conditions maintained on the test dates.

APPENDIX 1
COMPUTER OUTPUTS OF MEASURED
AND CALCULATED DATA

Client: De Beers, Snap Lake
Jobsite: Snap Lake Mine
Source: Incinerator Stack #1

Date: July, 11/14
Run: 1 PCDD/PCDF
Run Time: 13:10-17:20

Concentration:
 0.00 mg/dscm
 0.00 mg/Acm
 0.0000 gr/dscf
 0.0000 gr/Acf

Emission Rate:
 0.00 mg/dscm (@ 11% O2)
 0.00 Kg/hr
 0.0000 gr/dscf (@ 11% O2)
 0.000 lb/hr

Sample Gas Volume:
 4.7703 dscm
Total Sample Time:
 240.0 minutes
Average Isokineticity:
 102.7 %

Flue Gas Characteristics

Moisture: 11.54 %
Temperature: 986.4 oC
Flow: 1807.5 oF
 18.9 dscm/min
 0.32 dscm/sec
 95.8 Acm/min
 669 dscf/min
 11.1 dscf/sec
 3382 Acf/min

Velocity: 40.37 f/sec
Gas Analysis: 10.80 % CO2
 29.952 Mol. Wt (g/gmole) Dry
 28.573 Mol. Wt (g/gmole) Wet

*** Standard Conditions:**
Metric: 25 deg C, 101.325 kPa
Imperial: 77 deg F, 29.92 in.Hg

Client: De Beers, Snap Lake
Jobsite: Snap Lake Mine
Source: Incinerator Stack #1

Date: July, 11/14
Run: 1 PCDD/PCDF
Run Time: 13:10-17:20

Control Unit (Y) 1.0101
Nozzle Diameter (in.) 0.5113
Pilot Factor 0.8463
Baro. Press. (in. Hg) 28.25
Static Press. (in. Hg) 0.06
Stack Height (ft) 25
Stack Diameter (in.) 16.0
Stack Area (sq.ft.) 1.396
Minutes Per Reading 5.0
Minutes Per Point 10.0

Collection:

Filter (grams) 0.0000
Washings (grams) 0.0000
Impinger (grams) 0.0000
Total (grams) 0.0000

Gas Analysis (Vol. %):

CO2 11.25
O2 4.56
Trav 1 10.34
Trav 2 6.69

Condensate Collection:
Impinger 1 (grams) 416.0
Impinger 2 (grams) 30.0
Impinger 3 (grams) 0.0
Impinger 4 (grams) 12.0

Average = 10.80 **5.63**

Total Gain (grams) **458.0**

Traverse	Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	XAD Exit (oF)	Stack (oF)	Wall Dist. (in.)	Isokin. (%)
1	1	0.0	851.412	0.110	1.83	66	66	4	45	1750	0.3	105.9
		5.0	855.140	0.110	1.83	67	67	4	45	1779	0.3	101.6
	2	15.0	862.420	0.120	1.86	68	68	4	48	1780	1.1	101.4
		20.0	866.140	0.120	1.86	68	68	4	48	1794	1.1	101.8
	3	25.0	869.710	0.110	1.70	66	66	4	50	1797	1.9	102.4
		30.0	873.430	0.120	1.85	66	66	4	50	1798	1.9	102.2
	4	35.0	877.210	0.120	1.87	67	67	4	54	1830	2.8	104.4
		40.0	880.990	0.120	1.87	68	68	4	54	1888	2.8	105.5
	5	45.0	884.780	0.120	1.87	68	68	4	48	1900	4.0	106.1
		50.0	888.560	0.120	1.87	68	68	4	48	1905	4.0	105.9
	6	55.0	892.350	0.120	1.87	69	69	4	50	1915	5.7	106.2
		60.0	896.140	0.120	1.87	68	68	4	54	1920	10.3	106.2
	7	65.0	899.760	0.110	1.72	68	68	4	54	1760	10.3	102.6
		70.0	903.540	0.120	1.87	68	68	4	56	1735	12.0	101.8
	8	75.0	907.160	0.110	1.72	69	69	5	56	1720	12.0	101.6
		80.0	910.790	0.110	1.72	70	70	5	60	1717	13.2	101.5
	9	85.0	914.420	0.110	1.72	70	70	6	60	1800	13.2	103.4
		90.0	918.050	0.110	1.72	70	70	6	58	1770	14.1	102.4
	10	95.0	921.670	0.120	1.72	71	71	6	58	1770	14.1	102.3
		100.0	925.450	0.120	1.87	71	71	6	54	1766	14.9	102.2
	11	105.0	929.230	0.120	1.87	71	71	6	54	1750	14.9	101.8
		110.0	933.010	0.120	1.87	71	71	6	48	1750	15.7	101.8
	12	115.0	936.790	0.120	1.87	71	71	6	48	1750	15.7	101.8
		120.0	940.570	0.120	1.87	71	71	6	48	1788	15.7	102.7
2	1	0.0	940.570	0.120	1.83	71	71	7	52	1792	0.3	101.7
		5.0	944.310	0.120	1.83	72	72	8	52	1790	0.3	102.0
	2	10.0	948.070	0.120	1.83	72	72	8	54	1756	1.1	101.2
		15.0	951.830	0.120	1.83	73	73	8	54	1737	1.1	100.0
	3	20.0	955.570	0.120	1.83	73	73	8	54	1788	1.9	101.3
		25.0	959.150	0.110	1.68	72	72	7	54	1885	1.9	103.3
	4	30.0	962.730	0.110	1.68	73	73	7	48	1775	2.8	102.2
		35.0	966.510	0.120	1.87	72	72	8	48	1876	2.8	104.3
	5	40.0	970.290	0.120	1.87	73	73	10	48	1775	4.0	102.0
		45.0	973.910	0.110	1.72	73	73	10	48	1830	4.0	102.1
	6	50.0	977.490	0.110	1.68	73	73	10	50	1775	5.7	101.2
		55.0	980.910	0.100	1.53	72	72	10	50	1832	5.7	102.7
	7	60.0	984.330	0.100	1.53	71	71	10	52	1821	10.3	102.4
		65.0	987.570	0.090	1.38	70	70	10				

A. Lanfranco and Associates Inc. - Emission Report

	70.0	990,900	0.095	1.45	70	70	70	10	52	1800	10.3	102.0
8	75.0	994,140	0.090	1.38	70	70	70	10	54	1783	12.0	101.6
	80.0	997,380	0.090	1.38	70	70	70	10	54	1780	12.0	101.5
9	85.0	1000,560	0.090	1.32	70	70	70	10	57	1915	13.2	102.6
	90.0	1003,800	0.090	1.38	70	70	70	10	57	1819	13.2	102.4
10	95.0	1007,220	0.100	1.53	70	70	70	10	56	1840	14.1	103.0
	100.0	1010,810	0.110	1.68	70	70	70	10	56	1800	14.1	102.3
11	105.0	1014,560	0.120	1.83	70	70	70	12	50	1800	14.9	102.3
	110.0	1018,140	0.110	1.68	70	70	70	12	50	1793	14.9	101.8
12	115.0	1021,590	0.100	1.53	70	70	70	12	48	1806	15.7	103.2
	120.0	1024,940	0.100	1.46	70	70	70	12	48	1900	15.7	102.2
		Average:	0.111	1.720	69.9	69.9	69.9	7.1	52.0	1807.5		102.7

Client: De Beers, Snap Lake
Jobsite: Snap Lake
Source: Incinerator Stack #1

Date: July, 12/14
Run: 2 PCDD/PCDF
Run Time: 10:06-14:20

Concentration:
 0.00 mg/dscm 0.0000 gr/dscf
 0.00 mg/Acm 0.0000 gr/Acf

Emission Rate:
 0.00 mg/dscm (@ 11% O2) 0.0000 gr/dscf (@ 11% O2)
 0.00 Kg/hr 0.000 lb/hr

Sample Gas Volume: 4.2309 dscm
Total Sample Time: 240.0 minutes

Average Isokineticity: 97.6 %

Flue Gas Characteristics

Moisture: 11.99 %
Temperature: 1846.8 oF

Flow: 625 dscf/min
 10.4 dscf/sec
 3204 Acf/min

Velocity: 38.24 f/sec

Gas Analysis: 10.21 % CO2

29.906 Mol. Wt (g/gmole) Dry 28.478 Mol. Wt (g/gmole) Wet

*** Standard Conditions:** Metric: 25 deg C, 101.325 kPa
 Imperial: 77 deg F, 29.92 in.Hg

Client: De Beers, Snap Lake
Jobsite: Snap Lake
Source: Incinerator Stack #1

Date: July, 12/14
Run: 2 PCDD/PCDF
Run Time: 10:06-14:20

Control Unit (Y) 1.0101
Nozzle Diameter (in.) 0.5113
Pitot Factor 0.8463
Baro. Press. (in. Hg) 28.50
Static Press. (in. Hg) 0.06
Stack Height (ft) 25
Stack Diameter (in.) 16.0
Stack Area (sq.ft.) 1.396
Minutes Per Reading 5.0
Minutes Per Point 10.0

Collection:

Filter (grams) 0.0000
Washings (grams) 0.0000
Impinger (grams) 0.0000
Total (grams) 0.0000

Gas Analysis (Vol. %):

Trav 1	CO2	O2
Trav 2	12.21	4.46
	8.21	9.14

Condensate Collection:

Impinger 1 (grams) 372.0
Impinger 2 (grams) 36.0
Impinger 3 (grams) 2.0
Impinger 4 (grams) 14.0

Average = 10.21 6.80

Total Gain (grams) 424.0

Traverse	Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	XAD Exit (oF)	Stack (oF)	Wall Dist. (in.)	Isokin. (%)
1	1	0.0	25.845	0.075	1.17	78	78	3	41	1776	0.3	101.2
		5.0	28.820	0.080	1.20	79	79	4	41	1819	0.3	99.3
		10.0	31.810	0.085	1.27	81	81	4	41	1865	1.1	99.8
		15.0	34.890	0.090	1.32	81	81	4	41	1906	1.1	99.8
		20.0	38.030	0.090	1.20	81	81	4	42	1932	1.9	100.3
		25.0	40.990	0.090	1.32	83	83	5	42	1950	1.9	100.7
		30.0	44.140	0.090	1.32	84	84	5	42	1955	2.8	100.3
		35.0	47.280	0.095	1.33	86	86	5	42	1548	2.8	95.2
		40.0	50.470	0.090	1.41	87	87	5	43	1745	4.0	99.0
		45.0	53.730	0.080	1.25	88	88	6	43	1713	4.0	97.9
		50.0	56.800	0.090	1.41	90	90	6	48	1784	5.7	99.3
		55.0	60.060	0.095	1.48	91	91	6	48	1754	5.7	98.2
60.0	63.400	0.100	1.46	92	92	6	53	1916	10.3	98.1		
65.0	66.710	0.110	1.61	92	92	6	53	1955	10.3	98.9		
70.0	70.180	0.100	1.50	93	93	6	56	1790	12.0	96.1		
75.0	73.520	0.100	1.50	94	94	6	56	1850	12.0	97.2		
80.0	76.860	0.090	1.35	94	94	8	60	1818	13.2	96.6		
85.0	80.030	0.100	1.46	95	95	8	60	1900	13.2	97.2		
90.0	83.340	0.100	1.46	95	95	8	60	1910	14.1	97.4		
95.0	86.650	0.100	1.50	96	96	8	48	1810	14.1	96.0		
100.0	89.990	0.100	1.50	96	96	9	48	1800	14.9	97.0		
105.0	93.370	0.120	1.76	97	97	10	42	1920	14.9	97.2		
110.0	96.990	0.130	1.90	98	98	10	40	1942	15.7	97.8		
115.0	100.770	0.120	1.80	98	98	10	40	1815	15.7	95.9		
120.0	104.430											
2	1	0.0	104.430	0.120	1.76	97	97	12	42	1915	0.3	98.2
		5.0	108.090	0.120	1.76	97	97	12	42	1930	0.3	98.5
		10.0	111.750	0.130	1.94	98	98	13	44	1872	1.1	97.1
		15.0	115.560	0.110	1.65	98	98	14	44	1850	1.1	96.8
		20.0	119.070	0.110	1.65	98	98	14	44	1850	1.9	96.8
		25.0	122.580	0.105	1.57	99	99	14	44	1872	1.9	97.0
		30.0	126.010	0.085	1.27	98	98	6	46	1805	2.8	95.5
35.0	129.090	0.090	1.35	98	98	15	46	1835	2.8	96.2		
40.0	132.260	0.090	1.35	97	97	15	48	1860	4.0	96.9		
45.0	135.430	0.090	1.35	96	96	15	48	1856	4.0	97.0		
50.0	138.600	0.095	1.42	97	97	15	46	1850	5.7	96.8		
55.0	141.860	0.100	1.50	98	98	15	46	1823	5.7	104.6		
60.0	145.500	0.100	1.50	98	98	15	46	1816	10.3	96.7		
65.0	148.870	0.100	1.50	98	98	15	46					

A. Lanfranco and Associates Inc. - Emission Report

8	70.0	152.210	0.100	1.50	98	98	15	46	1809	10.3	95.7
	75.0	155.550	0.100	1.50	98	98	15	48	1850	12.0	96.5
9	80.0	158.890	0.100	1.50	99	99	15	48	1880	12.0	97.0
	85.0	162.320	0.105	1.57	99	99	15	50	1888	13.2	97.4
10	90.0	165.750	0.105	1.57	99	99	15	50	1864	13.2	96.9
	95.0	169.010	0.095	1.42	100	100	15	44	1836	14.1	96.0
11	100.0	172.370	0.100	1.50	100	100	15	44	1820	14.1	96.1
	105.0	175.710	0.100	1.50	100	100	15	42	1835	14.9	95.9
12	110.0	178.880	0.090	1.35	100	100	16	42	1828	14.9	95.7
	115.0	182.100	0.095	1.39	100	100	17	42	1900	15.7	96.1
	120.0	185.440	0.100	1.50	100	100	18	42	1827	15.7	95.7
Average:			0.099	1.476	94.0	94.0	10.4	45.8	1846.8		97.6

Client: De Beers, Snap Lake
Jobsite: Snap Lake Mine
Source: Incinerator Stack #1

Date: July, 13/14
Run: 3 PCDD/PCDF
Run Time: 14:50-19:55

Concentration:
 0.00 mg/dscm 0.0000 gr/dscf
 0.00 mg/Acm 0.0000 gr/Acf
 0.00 mg/dscm (@ 11% O2) 0.0000 gr/dscf (@ 11% O2)
 0.00 Kg/hr 0.000 lb/hr

Emission Rate:
 4.4003 dscm 155.396 dscf
 240.0 minutes

Sample Gas Volume:
Total Sample Time: 240.0 minutes

Average Isokineticity: 101.8 %

Flue Gas Characteristics

Moisture: 11.87 %

Temperature: 990.7 oC

Flow:
 17.6 dscm/min 623 dscf/min
 0.29 dscm/sec 10.4 dscf/sec
 88.5 Acfm/min 3126 Acf/min

Velocity: 11.375 m/sec 37.32 f/sec

Gas Analysis: 7.97 % O2 9.12 % CO2

29.777 Mol. Wt (g/gmole) Dry 28.379 Mol. Wt (g/gmole) Wet

*** Standard Conditions:**
Metric: 25 deg C, 101.325 kPa
Imperial: 77 deg F, 29.92 in.Hg

Client: De Beers, Snap Lake
Jobsite: Snap Lake Mine
Source: Incinerator Stack #1

Date: July, 13/14
Run: 3 PCDD/PCDF
Run Time: 14:50-19:55

Control Unit (Y) 1.0101
 Nozzle Diameter (in.) 0.5113
 Pitot Factor 0.8463
 Baro. Press. (in. Hg) 28.66
 Static Press. (in. Hg) 0.06
 Stack Height (ft) 25
 Stack Diameter (in.) 16.0
 Stack Area (sq.ft.) 1.396
 Minutes Per Reading 5.0
 Minutes Per Point 10.0

Collection:

Filter (grams) 0.0000
 Washings (grams) 0.0000
 Impinger (grams) 0.0000
Total (grams) 0.0000

Gas Analysis (Vol. %):

Trav 1	CO2	O2
Trav 2	10.29	6.60
	7.94	9.34

Condensate Collection:

Impinger 1 (grams) 388.0
 Impinger 2 (grams) 36.0
 Impinger 3 (grams) 0.0
 Impinger 4 (grams) 12.0

Average = 9.12 7.97

Total Gain (grams) 436.0

Traverse	Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	XAD Exit (oF)	Stack (oF)	Wall Dist. (in.)	Isokin. (%)	
1	1	0.0	350.729	0.110	1.66	60	80	5	42	1837	0.3	102.5	
		5.0	354.270	0.115	1.74	59	81	5	42	1850	0.3	102.7	
	2		15.0	361.490	0.115	1.70	59	82	6	44	1892	1.1	103.0
			20.0	364.980	0.110	1.63	63	83	6	44	1902	1.1	101.8
	3		25.0	368.310	0.100	1.45	66	83	10	46	1960	1.9	102.8
			30.0	371.570	0.095	1.38	65	84	12	46	1944	1.9	102.9
	4		35.0	374.740	0.090	1.31	66	84	14	48	1900	2.8	101.7
			40.0	378.200	0.090	1.57	67	83	16	48	1488	2.8	100.9
	5		45.0	381.570	0.100	1.48	67	84	15	50	1845	4.0	101.3
			50.0	384.950	0.100	1.48	67	84	15	50	1860	4.0	102.0
6		55.0	388.390	0.100	1.52	69	81	5	52	1800	5.7	102.5	
		60.0	391.970	0.110	1.67	69	82	5	52	1789	5.7	101.4	
7		65.0	395.510	0.105	1.62	71	82	6	52	1754	10.3	101.7	
		70.0	398.960	0.100	1.55	71	81	6	52	1750	10.3	101.5	
8		75.0	402.540	0.110	1.67	71	82	7	49	1820	12.0	101.9	
		80.0	406.130	0.110	1.67	71	81	8	49	1781	12.0	101.4	
9		85.0	409.550	0.100	1.52	72	82	10	49	1791	13.2	101.4	
		90.0	412.890	0.095	1.44	72	82	10	49	1793	13.2	101.6	
10		95.0	416.130	0.090	1.36	72	82	10	50	1780	14.1	100.9	
		100.0	419.340	0.090	1.33	72	82	12	50	1870	14.1	102.0	
11		105.0	422.610	0.090	1.39	72	82	12	52	1775	14.9	101.8	
		110.0	425.770	0.085	1.31	73	82	12	52	1750	14.9	100.5	
12		115.0	428.920	0.085	1.29	73	81	12	50	1795	15.7	101.3	
		120.0	432.160	0.090	1.36	73	82	12	50	1800	15.7	101.3	
2	1	0.0	432.160	0.090	1.36	67	81	12	54	1794	0.3	101.8	
		5.0	435.400	0.090	1.36	71	82	12	54	1780	0.3	100.7	
	2		10.0	438.630	0.090	1.36	70	82	13	54	1800	1.1	101.9
			15.0	441.880	0.090	1.36	70	81	13	54	1800	1.1	102.3
	3		20.0	445.140	0.090	1.36	70	81	14	51	1793	1.9	101.5
			25.0	448.290	0.085	1.29	70	81	14	51	1890	1.9	100.9
	4		30.0	451.360	0.085	1.23	70	82	14	51	1789	2.8	102.5
		35.0	454.630	0.090	1.36	71	79	14	51	1870	2.8	100.6	
5		40.0	457.880	0.095	1.38	73	80	14	51	1790	4.0	101.5	
		45.0	461.300	0.100	1.52	72	80	14	52	1807	4.0	101.8	
6		50.0	464.720	0.100	1.52	72	81	15	52	1886	5.7	100.7	
		55.0	467.960	0.095	1.38	72	80	15	54	1860	5.7	102.0	
7		60.0	471.170	0.090	1.33	72	79	15	54	1875	10.3	102.3	
		65.0	474.380	0.090	1.33	72	80	16	56				

A. Lanfranco and Associates Inc. - Emission Report

	70.0	477,630	0.090	1.36	71	80	16	56	1798	10.3	101.9
8	75.0	480,890	0.090	1.36	71	79	16	50	1803	12.0	102.5
	80.0	484,130	0.090	1.36	71	79	16	50	1795	12.0	101.6
9	85.0	487,390	0.090	1.36	71	79	16	48	1800	13.2	102.4
	90.0	490,540	0.085	1.29	71	78	17	48	1808	13.2	102.1
10	95.0	493,780	0.090	1.36	71	78	18	48	1793	14.1	101.7
	100.0	497,110	0.095	1.44	71	78	18	48	1800	14.1	101.9
11	105.0	500,530	0.100	1.52	71	79	18	50	1816	14.9	102.3
	110.0	503,740	0.090	1.33	71	78	18	50	1850	14.9	102.0
12	115.0	506,980	0.090	1.36	71	77	18	44	1810	15.7	102.2
	120.0	510,220	0.090	1.36	71	75	18	44	1798	15.7	102.1
		Average:	0.095	1.437	69.6	80.8	12.5	49.8	1815.2		101.8

Client: De Beers, Snap Lake
Jobsite: Snap Lake Mine
Source: Incinerator Stack #2

Date: July, 13/14
Run: 1 PCDD/PCDF
Run Time: 09:33-13:43

Concentration:
 0.00 mg/dscm
 0.00 mg/Acm
 0.0000 gr/dscf
 0.0000 gr/Acf

Emission Rate:
 0.00 mg/dscm (@ 11% O2)
 0.00 Kg/hr
 0.0000 gr/dscf (@ 11% O2)
 0.000 lb/hr

Sample Gas Volume: 4.4821 dscm
Total Sample Time: 240.0 minutes
 158.287 dscf

Average Isokineticity: 102.0 %

Flue Gas Characteristics

Moisture: 12.31 %
Temperature: 1000.9 oC
Flow: 17.9 dscm/min
 0.30 dscm/sec
 91.2 Acf/min
 633 dscf/min
 10.6 dscf/sec
 3220 Acf/min
Velocity: 11.715 m/sec
 38.43 f/sec
Gas Analysis: 6.06 % O2
 10.59 % CO2

29.937 Mol. Wt (g/gmole) Dry
 28.467 Mol. Wt (g/gmole) Wet

*** Standard Conditions:**
Metric: 25 deg C, 101.325 kPa
Imperial: 77 deg F, 29.92 in.Hg

Client: De Beers, Snap Lake
Jobsite: Snap Lake Mine
Source: Incinerator Stack #2

Date: July 13/14
Run: 1 PCDD/PCDF
Run Time: 09:33-13:43

Control Unit (Y) 1.0101
Nozzle Diameter (in.) 0.5113
Pitot Factor 0.8463
Baro. Press. (in. Hg) 28.66
Static Press. (in. Hg) 0.08
Stack Height (ft) 25
Stack Diameter (in.) 16.0
Stack Area (sq.ft.) 1.396
Minutes Per Reading 5.0
Minutes Per Point 10.0

Collection:

Filter (grams) 0.0000
Washings (grams) 0.0000
Impinger (grams) 0.0000
Total (grams) 0.0000

Gas Analysis (Vol. %):

	CO2	O2
Trav 1	12.89	3.68
Trav 2	8.29	8.44

Condensate Collection:

Impinger 1 (grams) 420.0
 Impinger 2 (grams) 30.0
 Impinger 3 (grams) 0.0
 Impinger 4 (grams) 13.0

Average = 10.59 6.06

Total Gain (grams) 463.0

Traverse	Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	XAD Exit (oF)	Stack (oF)	Wall Dist. (in.)	Isokin. (%)
1	1	0.0	186.413	0.110	1.78	63	63	7	46	1660	0.3	103.4
		5.0	190.060	0.105	1.70	64	64	8	46	1670	0.3	103.4
	2	15.0	197.100	0.100	1.62	64	64	8	46	1689	1.1	104.0
		20.0	200.540	0.100	1.56	67	67	8	46	1750	1.1	103.6
	3	25.0	204.150	0.110	1.73	68	68	8	52	1756	1.9	103.7
		30.0	207.760	0.110	1.73	70	70	8	52	1766	2.8	102.5
	4	35.0	211.410	0.115	1.77	70	70	8	54	1772	2.8	103.3
		40.0	215.150	0.120	1.85	71	71	8	54	1798	4.0	103.7
	5	45.0	218.870	0.120	1.81	72	72	10	58	1850	4.0	103.9
		50.0	222.590	0.120	1.81	73	73	10	58	1868	5.7	102.9
	6	55.0	226.270	0.120	1.77	75	75	11	58	1895	5.7	102.9
		60.0	229.780	0.110	1.63	75	75	12	58	1910	5.7	102.9
2	7	65.0	233.120	0.100	1.48	76	76	12	48	1927	10.3	102.8
		70.0	236.300	0.090	1.33	77	77	12	48	1950	10.3	103.4
	8	75.0	239.470	0.090	1.33	78	78	11	52	1950	12.0	102.9
		80.0	242.810	0.100	1.48	79	79	10	52	1959	12.0	102.9
	9	85.0	246.180	0.100	1.51	80	80	10	56	1850	13.2	101.3
		90.0	249.590	0.100	1.54	80	80	12	56	1800	13.2	101.4
	10	95.0	253.130	0.110	1.66	80	80	12	58	1878	14.1	102.1
		100.0	256.470	0.100	1.48	81	81	13	58	1950	14.1	102.3
	11	105.0	259.830	0.100	1.48	81	81	14	58	1941	14.9	102.7
		110.0	263.170	0.100	1.48	81	81	14	58	1900	14.9	101.3
	12	115.0	266.580	0.100	1.54	81	81	14	50	1811	15.7	101.4
		120.0	269.920	0.100	1.48	81	81	14	50	1930	15.7	101.9
2	1	0.0	269.920	0.100	1.51	81	81	14	54	1850	0.3	101.1
		5.0	273.290	0.100	1.51	82	82	14	54	1844	0.3	100.8
	2	15.0	276.660	0.100	1.54	82	82	14	56	1800	1.1	101.6
		20.0	280.090	0.100	1.54	83	83	14	56	1793	1.1	100.7
	3	25.0	283.500	0.090	1.39	83	83	14	58	1808	1.9	100.8
		30.0	286.730	0.090	1.39	83	83	14	58	1815	1.9	101.9
	4	35.0	289.990	0.100	1.48	83	83	12	48	1878	2.8	101.8
5	5	40.0	293.370	0.100	1.48	82	82	12	48	1885	2.8	100.6
		45.0	296.710	0.095	1.47	83	83	12	50	1808	4.0	101.2
	6	50.0	300.040	0.095	1.36	82	82	12	49	1863	4.0	102.2
		55.0	303.270	0.095	1.47	81	81	12	49	1813	5.7	101.3
	7	60.0	306.590	0.095	1.47	82	82	12	49	1805	5.7	101.6
	65.0	309.930	0.100	1.54	81	81	13	52	1808	10.3	101.7	

A. Lanfranco and Associates Inc. - Emission Report

	70.0	316.770	0.100	1.54	80	80	14	52	1783	10.3	101.3
8	75.0	320.190	0.100	1.54	81	81	14	56	1793	12.0	101.3
	80.0	323.600	0.100	1.54	82	82	14	56	1800	12.0	101.0
9	85.0	326.970	0.100	1.51	83	83	14	56	1850	13.2	100.7
	90.0	330.390	0.100	1.54	84	84	14	56	1817	13.2	101.3
10	95.0	333.620	0.090	1.39	83	83	14	54	1814	14.1	100.9
	100.0	336.760	0.085	1.31	82	82	14	54	1822	14.1	101.3
11	105.0	340.090	0.095	1.47	83	83	13	52	1825	14.9	101.5
	110.0	343.330	0.090	1.39	84	84	13	52	1811	14.9	101.0
12	115.0	346.500	0.090	1.33	85	85	13	48	1880	15.7	100.1
	120.0	349.820	0.095	1.47	86	86	14	48	1821	15.7	100.6
		Average:	0.101	1.536	78.5	78.5	12.0	52.9	1833.7		102.0

Client: De Beers, Snap Lake Mine
Jobsite: Snap Lake
Source: Incinerator Stack #2

Date: July, 14/14
Run: 2 PCDD/PCDF
Run Time: 13:30-18:25

Concentration:
 0.00 mg/dscm
 0.00 mg/Acm
 0.0000 gr/dscf
 0.0000 gr/Acf

Emission Rate:
 0.00 mg/dscm (@ 11% O2)
 0.00 Kg/hr
 0.0000 gr/dscf (@ 11% O2)
 0.000 lb/hr

Sample Gas Volume: 153.017 dscf
Total Sample Time: 4.3329 dscm
 240.0 minutes

Average Isokineticity: 99.8 %

Flue Gas Characteristics

Moisture: 12.25 %
Temperature: 1862.4 oF
 1016.9 oC
Flow: 609 dscf/min
 10.1 dscf/sec
 88.9 Acm/min
 3139 Acf/min
Velocity: 37.47 f/sec
Gas Analysis: 10.16 % CO2

29.912 Mol. Wt (g/gmole) Dry
 28.453 Mol. Wt (g/gmole) Wet

*** Standard Conditions:**
Metric: 25 deg C, 101.325 kPa
Imperial: 77 deg F, 29.92 in.Hg

Client: De Beers, Snap Lake Mine
Jobsite: Snap Lake
Source: Incinerator Stack #2

Date: July, 14/14
Run: 2 PCDD/PCDF
Run Time: 13:30-18:25

Control Unit (Y) 1.0101
Nozzle Diameter (in.) 0.5183
Pitot Factor 0.8463
Baro. Press. (in. Hg) 28.60
Static Press. (in. Hg) 0.08
Stack Height (ft) 25
Stack Diameter (in.) 16.0
Stack Area (sq.ft.) 1.396
Minutes Per Reading 5.0
Minutes Per Point 10.0

Collection:

Filter (grams) 0.0000
Washings (grams) 0.0000
Impinger (grams) 0.0000
Total (grams) 0.0000

Gas Analysis (Vol. %):

Trav 1	CO2	O2
Trav 2	10.94	6.38
	9.38	7.93

Condensate Collection:

Impinger 1 (grams) 425.0
Impinger 2 (grams) 20.0
Impinger 3 (grams) 0.0
Impinger 4 (grams) 0.0

Average = 10.16 **7.16**

Total Gain (grams) **445.0**

Traverse	Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	XAD Exit (oF)	Stack (oF)	Wall Dist. (in.)	Isokin. (%)
1	1	0.0	511.462	0.080	1.48	81	81	5	52	1600	0.8	103.9
		5.0	514.840	0.080	1.48	82	82	5	52	1550	0.8	102.5
	2	15.0	521.390	0.080	1.31	82	82	8	52	1680	0.8	99.1
		20.0	524.560	0.080	1.31	82	82	12	52	1764	0.8	101.1
	3	25.0	527.820	0.090	1.38	82	82	15	56	1900	2.6	101.0
		30.0	531.150	0.090	1.44	82	82	15	56	1804	2.6	101.0
	4	35.0	534.440	0.090	1.41	83	83	16	58	1826	2.6	100.1
		40.0	537.770	0.090	1.44	84	84	18	58	1809	2.6	100.8
	5	45.0	541.100	0.090	1.44	85	85	18	54	1801	5.3	100.4
		50.0	544.330	0.085	1.36	85	85	18	54	1795	5.3	100.1
	6	55.0	547.620	0.090	1.41	85	85	18	50	1866	5.3	100.6
		60.0	550.910	0.090	1.41	84	84	5	50	1852	5.3	100.5
	7	65.0	554.200	0.090	1.41	85	85	5	52	1870	12.7	100.7
		70.0	557.580	0.095	1.49	85	85	6	52	1863	12.7	100.6
	8	75.0	560.930	0.095	1.46	86	86	6	54	1900	12.7	100.3
		80.0	564.190	0.090	1.38	87	87	6	54	1894	12.7	99.9
	9	85.0	567.470	0.090	1.38	88	88	7	58	1925	15.4	101.0
		90.0	570.730	0.090	1.38	88	88	7	58	1870	15.4	99.2
	10	95.0	573.990	0.090	1.38	89	89	7	60	1904	15.4	99.8
		100.0	577.340	0.095	1.46	90	90	8	60	1921	15.4	100.0
	11	105.0	580.690	0.095	1.46	91	91	8	52	1898	17.2	99.3
		110.0	584.050	0.095	1.46	91	91	8	52	1890	17.2	99.4
	12	115.0	587.310	0.090	1.38	92	92	8	52	1884	17.2	98.8
		120.0	590.590	0.090	1.38	92	92	8	52	1885	17.2	99.4
2	1	0.0	590.590	0.095	1.46	91	91	8	54	1880	0.8	98.9
		5.0	593.940	0.100	1.57	92	92	8	54	1868	0.8	99.5
	2	15.0	600.850	0.100	1.53	92	92	8	56	1881	0.8	98.9
		20.0	604.290	0.100	1.53	92	92	8	56	1920	0.8	99.7
	3	25.0	607.770	0.100	1.57	92	92	8	52	1856	2.6	99.5
		30.0	611.210	0.100	1.53	92	92	8	52	1868	2.6	98.6
	4	35.0	614.690	0.100	1.57	91	91	9	49	1870	2.6	100.0
		40.0	618.210	0.105	1.61	91	91	9	49	1910	2.6	99.6
	5	45.0	621.680	0.100	1.57	92	92	10	48	1871	5.3	99.5
		50.0	625.170	0.100	1.57	92	92	10	48	1876	5.3	100.2
	6	55.0	628.620	0.100	1.53	93	93	10	50	1880	5.3	99.0
		60.0	631.970	0.095	1.46	93	93	10	50	1915	5.3	99.3
	7	65.0	635.320	0.095	1.46	92	92	11	52	1881	12.7	98.8

A. Lanfranco and Associates Inc. - Emission Report

	70.0	638,760	0.100	1.53	93	93	12	52	1880	12.7	98.7
8	75.0	642,200	0.100	1.53	93	93	12	58	1919	12.7	99.5
	80.0	645,730	0.105	1.61	94	94	12	58	1925	12.7	99.6
9	85.0	649,170	0.100	1.53	93	93	12	52	1914	15.4	99.4
	90.0	652,620	0.100	1.53	92	92	12	52	1890	15.4	99.4
10	95.0	655,970	0.095	1.46	92	92	13	48	1898	15.4	99.1
	100.0	659,230	0.090	1.38	93	93	14	48	1910	15.4	99.2
11	105.0	662,020	0.095	1.46	92	92	14	50	1922	17.2	83.0
	110.0	666,020	0.100	1.53	93	93	15	50	1920	17.2	115.7
12	115.0	669,460	0.100	1.53	93	93	15	52	1910	17.2	99.3
	120.0	672,900	0.100	1.53	92	92	15	52	1880	17.2	98.9
		Average:	0.094	1.468	89.1	89.1	10.4	53.0	1862.4		99.8

Client: De Beers, Snap Lake
Jobsite: Snap Lake Mine
Source: Incinerator Stack #2

Date: July, 15/14
Run: 3 PCDD/PCDF
Run Time: 09:35-13:45

Concentration:
 0.00 mg/dscm
 0.00 mg/Acm
 0.0000 gr/dscf
 0.0000 gr/Acf

Emission Rate:
 0.00 mg/dscm (@ 11% O2)
 0.00 Kg/hr
 0.0000 gr/dscf (@ 11% O2)
 0.000 lb/hr

Sample Gas Volume: 156.194 dscf
Total Sample Time: 240.0 minutes

Average Isokineticity: 102.7 %

Flue Gas Characteristics

Moisture: 12.39 %
Temperature: 1855.0 oF
Flow: 604 dscf/min
 10.1 dscf/sec
 3143 Acf/min
Velocity: 37.52 f/sec
Gas Analysis: 10.00 % CO2

29.903 Mol. Wt (g/gmole) Dry
 28.429 Mol. Wt (g/gmole) Wet

*** Standard Conditions:** Metric: 25 deg C, 101.325 kPa
 Imperial: 77 deg F, 29.92 in.Hg

Client: De Beers, Snap Lake
Jobsite: Snap Lake Mine
Source: Incinerator Stack #2

Date: July, 15/14
Run: 3 PCDD/PCDF
Run Time: 09:35-13:45

Control Unit (Y) 1.0101
Nozzle Diameter (in.) 0.5183
Pilot Factor 0.8463
Baro. Press. (in. Hg) 28.30
Static Press. (in. Hg) 0.08
Stack Height (ft) 25
Stack Diameter (in.) 16.0
Stack Area (sq.ft.) 1,396
Minutes Per Reading 5.0
Minutes Per Point 10.0

Collection:

Filter (grams) 0.0000
Washings (grams) 0.0000
Impinger (grams) 0.0000
Total (grams) 0.0000

Gas Analysis (Vol. %):

Trav 1	CO2	O2
Trav 2	11.00	6.74
	9.00	8.41

Condensate Collection:

Impinger 1 (grams) 423.0
 Impinger 2 (grams) 22.0
 Impinger 3 (grams) 0.0
 Impinger 4 (grams) 15.0

Average = 10.00 7.58

Total Gain (grams) 460.0

Traverse	Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	XAD Exit (oF)	Stack (oF)	Wall Dist. (in.)	Isokin. (%)
1	1	0.0	673.290	0.090	1.44	60	71	5	42	1793	0.8	123.1
		5.0	677.250	0.090	1.47	59	72	5	42	1775	0.8	104.7
	2	15.0	684.120	0.100	1.57	59	73	6	42	1853	0.8	104.2
		20.0	687.650	0.100	1.60	63	74	8	42	1800	0.8	103.7
	3	25.0	690.990	0.090	1.44	66	73	8	43	1810	2.6	103.4
		30.0	694.310	0.090	1.41	65	74	8	43	1859	2.6	103.9
	4	35.0	697.840	0.100	1.60	66	74	10	44	1817	2.6	103.8
		40.0	701.370	0.100	1.60	67	74	10	44	1809	2.6	103.5
	5	45.0	704.900	0.100	1.60	67	75	10	48	1811	5.3	103.5
		50.0	708.370	0.100	1.57	67	76	10	48	1853	5.3	102.6
	6	55.0	711.870	0.100	1.57	69	77	10	48	1828	5.3	102.6
		60.0	715.380	0.100	1.57	69	78	10	48	1867	5.3	103.7
	7	65.0	718.880	0.100	1.57	71	78	10	52	1841	12.7	102.6
		70.0	722.370	0.100	1.57	71	79	10	52	1870	12.7	102.9
	8	75.0	725.780	0.095	1.49	71	80	10	56	1837	12.7	102.3
		80.0	729.100	0.090	1.41	71	80	10	56	1837	12.7	102.3
	9	85.0	732.510	0.095	1.49	72	82	10	60	1840	15.4	102.0
		90.0	735.880	0.095	1.46	72	84	10	60	1900	15.4	101.9
	10	95.0	739.200	0.090	1.41	72	84	10	50	1858	15.4	102.3
		100.0	742.520	0.090	1.41	72	85	10	50	1845	15.4	101.9
	11	105.0	745.870	0.095	1.46	72	85	10	50	1894	17.2	101.1
		110.0	749.190	0.090	1.38	73	86	10	50	1852	17.2	101.8
	12	115.0	752.600	0.095	1.48	73	88	10	45	1866	17.2	101.9
		120.0	756.010	0.095	1.48	73	89	10	45	1852	17.2	101.5
2	1	0.0	756.010	0.100	1.53	67	88	10	45	1905	0.8	101.7
		5.0	759.450	0.105	1.61	71	86	10	45	1883	0.8	101.2
	2	15.0	762.980	0.105	1.61	70	87	11	46	1916	0.8	101.9
		20.0	770.100	0.105	1.64	70	88	12	46	1859	0.8	102.3
	3	25.0	773.710	0.110	1.69	70	88	12	44	1890	2.6	101.1
		30.0	777.390	0.110	1.72	70	88	12	44	1860	2.6	102.5
	4	35.0	780.740	0.095	1.46	71	87	12	43	1885	2.6	100.8
		40.0	784.230	0.100	1.57	73	88	12	43	1875	2.6	101.9
	5	45.0	787.550	0.090	1.41	72	88	12	43	1859	5.3	101.9
		50.0	790.870	0.090	1.41	72	89	12	43	1858	5.3	101.8
	6	55.0	794.090	0.085	1.33	72	87	12	46	1857	5.3	101.7
		60.0	797.410	0.090	1.41	72	88	12	46	1868	5.3	102.1
	7	65.0	800.580	0.085	1.30	72	87	12	48	1900	12.7	101.1

A. Lanfranco and Associates Inc. - Emission Report

	70.0	803.900	0.090	1.41	71	88	12	48	1875	12.7	102.3
8	75.0	807.220	0.090	1.41	71	87	12	50	1851	12.7	101.9
	80.0	810.540	0.090	1.41	71	88	12	50	1870	12.7	102.2
9	85.0	813.670	0.080	1.25	71	88	12	51	1851	15.4	101.8
	90.0	816.890	0.085	1.33	71	87	12	51	1854	15.4	101.8
10	95.0	820.020	0.080	1.25	71	87	12	53	1847	15.4	101.8
	100.0	823.150	0.080	1.25	71	88	12	53	1848	15.4	101.7
11	105.0	826.390	0.085	1.33	71	87	12	56	1833	17.2	101.9
	110.0	829.520	0.080	1.25	71	86	12	56	1854	17.2	102.0
12	115.0	832.790	0.090	1.44	71	87	12	58	1880	17.2	101.0
	120.0	835.970	0.085	1.30	71	88	12	58	1894	17.2	101.2
		Average:	0.094	1.466	69.6	83.1	10.5	48.5	1855.0		102.7

Client: De Beers, Snap Lake
Jobsite: Snap Lake
Source: Incinerator Stack #1

Date: July. 11/14
Run: 1 Partic/ Metals
Run Time: 13:50-16:00

Particulate Concentration: **68.2 mg/dscm** 0.0298 gr/dscf
 13.3 mg/Acm 0.0058 gr/Acf
 41.9 mg/dscm (@ 11% O2) 0.0183 gr/dscf (@ 11% O2)

Emission Rate: 0.08 Kg/hr 0.171 lb/hr

Sample Gas Volume: 2.8453 dscm 100.480 dscf
Total Sample Time: 120.0 minutes

Average Isokineticity: 101.2 %

Flue Gas Characteristics

Moisture:	11.87 %	
Temperature	995.8 oC	1824.5 oF
Flow	19.0 dscm/min 0.32 dscm/sec 97.0 Acm/min	670 dscf/min 11.2 dscf/sec 3425 Acf/min
Velocity	12.460 m/sec	40.88 f/sec
Gas Analysis	4.80 % O2	11.04 % CO2
	29.958 Mol. Wt (g/gmole) Dry	28.539 Mol. Wt (g/gmole) Wet

*** Standard Conditions:** Metric: 25 deg C, 101.325 kPa
 Imperial: 77 deg F, 29.92 in.Hg

Client: De Beers, Snap Lake
Jobsite: Snap Lake
Source: Incinerator Stack #1

Date: July. 11/14
Run: 1 Partic/ Metals
Run Time: 13:50-16:00

Control Unit (Y) 0.9950
Nozzle Diameter (in.) 0.5623
Pitot Factor 0.8457
Baro. Press. (in. Hg) 28.25
Static Press. (in. H2O) 0.06
Stack Height (ft) 25
Stack Diameter (in.) 16.0
Stack Area (sq.ft.) 1.396
Minutes Per Reading 5.0
Minutes Per Point 5.0

Gas Analysis (Vol. %):

	CO2	O2
Trav. 1	11.08	4.90
Trav. 2	11.00	4.70
Average =	<u>11.04</u>	<u>4.80</u>

Condensate Collection:

Impinger 1 (grams)	153.0
Impinger 2 (grams)	55.0
Impinger 3 (grams)	46.0
Impinger 4 (grams)	18.0
Impinger 5 (grams)	0.0
Impinger 6 (grams)	10.0
Total Gain (grams)	<u>282.0</u>

Collection:

Filter (grams)	0.0949
Washings (grams)	0.0992
Impinger (grams)	0.0000
Total (grams)	<u>0.1941</u>

Traverse	Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature		Stack (oF)	Wall Dist. (in.)	Isokin. (%)
						Inlet (oF)	Outlet (oF)			
1		0.0	443.035							
	1	5.0	447.240	0.110	2.31	60	60	1861	0.3	101.3
	2	10.0	451.620	0.120	2.51	60	60	1875	1.1	101.4
	3	15.0	455.970	0.120	2.48	59	59	1890	1.9	101.2
	4	20.0	460.130	0.110	2.26	60	60	1908	2.8	101.2
	5	25.0	464.460	0.120	2.48	60	60	1924	4.0	101.3
	6	30.0	468.850	0.120	2.51	61	61	1875	5.7	101.4
	7	35.0	473.210	0.115	2.48	61	61	1802	10.3	101.3
	8	40.0	477.540	0.110	2.46	62	62	1729	12.0	101.0
	9	45.0	481.760	0.105	2.35	63	63	1735	13.2	100.6
	10	50.0	486.090	0.110	2.47	62	62	1720	14.1	100.8
	11	55.0	490.370	0.110	2.36	63	63	1826	14.9	101.8
12	60.0	494.460	0.105	2.19	62	62	1890	15.7	101.1	
2		0.0	494.460							
	1	5.0	498.710	0.110	2.35	63	63	1832	0.3	101.2
	2	10.0	503.040	0.110	2.41	63	63	1780	1.1	101.9
	3	15.0	507.380	0.110	2.44	64	64	1754	1.9	101.4
	4	20.0	511.910	0.120	2.66	65	65	1762	2.8	101.4
	5	25.0	516.250	0.110	2.44	66	66	1764	4.0	101.2
	6	30.0	520.610	0.110	2.46	66	66	1745	5.7	101.3
	7	35.0	525.000	0.120	2.51	64	64	1886	10.3	101.1
	8	40.0	529.460	0.120	2.61	66	66	1808	12.0	100.6
	9	45.0	533.780	0.110	2.42	65	65	1780	13.2	101.3
	10	50.0	538.150	0.120	2.50	65	65	1907	14.1	100.9
	11	55.0	542.410	0.110	2.35	65	65	1845	14.9	101.3
12	60.0	546.530	0.105	2.20	65	65	1889	15.7	101.2	
			Average:	0.113	2.425	62.9	62.9	1824.5		101.2

Client: De Beers, Snap Lake
Jobsite: Snap Lake
Source: Incinerator Stack #1

Date: July. 12/14
Run: 2 Partic/ Metals
Run Time: 10:26-14:05

Particulate Concentration: **78.9 mg/dscm** 0.0345 gr/dscf
 15.6 mg/Acm 0.0068 gr/Acf
 57.7 mg/dscm (@ 11% O2) 0.0252 gr/dscf (@ 11% O2)

Emission Rate: 0.09 Kg/hr 0.187 lb/hr

Sample Gas Volume: 2.6568 dscm 93.825 dscf
Total Sample Time: 120.0 minutes

Average Isokineticity: 99.9 %

Flue Gas Characteristics

Moisture: 11.18 %

Temperature 1002.8 oC 1837.0 oF

Flow 18.0 dscm/min 634 dscf/min
 0.30 dscm/sec 10.6 dscf/sec
 90.8 Acm/min 3206 Acf/min

Velocity 11.665 m/sec 38.27 f/sec

Gas Analysis 7.35 % O2 9.79 % CO2

29.860 Mol. Wt (g/gmole) Dry 28.535 Mol. Wt (g/gmole) Wet

*** Standard Conditions:** Metric: 25 deg C, 101.325 kPa
 Imperial: 77 deg F, 29.92 in.Hg

Client: De Beers, Snap Lake
Jobsite: Snap Lake
Source: Incinerator Stack #1

Date: July. 12/14
Run: 2 Partic/ Metals
Run Time: 10:26-14:05

Control Unit (Y) 0.9950
Nozzle Diameter (in.) 0.5623
Pitot Factor 0.8457
Baro. Press. (in. Hg) 28.50
Static Press. (in. H2O) 0.06
Stack Height (ft) 25
Stack Diameter (in.) 16.0
Stack Area (sq.ft.) 1.396
Minutes Per Reading 5.0
Minutes Per Point 5.0

Gas Analysis (Vol. %):

	CO2	O2
Trav. 1	11.08	5.07
Trav. 2	8.50	9.63
Average =	<u>9.79</u>	<u>7.35</u>

Condensate Collection:

Impinger 1 (grams)	150.0
Impinger 2 (grams)	79.0
Impinger 3 (grams)	5.0
Impinger 4 (grams)	0.0
Impinger 5 (grams)	0.0
Impinger 6 (grams)	12.0
Total Gain (grams)	<u>246.0</u>

Collection:

Filter (grams)	0.0972
Washings (grams)	0.1125
Impinger (grams)	0.0000
Total (grams)	<u>0.2097</u>

Traverse	Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature		Stack (oF)	Wall Dist. (in.)	Isokin. (%)
						Inlet (oF)	Outlet (oF)			
1		0.0	562.667							
	1	5.0	566.820	0.110	2.23	66	66	1927	0.3	100.0
	2	10.0	571.100	0.120	2.41	65	65	1944	1.1	99.2
	3	15.0	575.310	0.115	2.30	66	66	1960	1.9	99.8
	4	20.0	579.460	0.110	2.19	67	67	1976	2.8	100.7
	5	25.0	584.110	0.120	2.78	69	69	1637	4.0	100.0
	6	30.0	588.620	0.120	2.65	71	71	1756	5.7	99.3
	7	35.0	593.080	0.115	2.55	71	71	1746	10.3	100.1
	8	40.0	597.330	0.105	2.31	71	71	1750	12.0	99.8
	9	45.0	601.650	0.110	2.38	73	73	1805	13.2	100.0
	10	50.0	605.722	0.100	2.10	78	78	1901	14.1	99.9
	11	55.0	609.670	0.090	1.97	79	79	1806	14.9	99.8
12	60.0	613.950	0.110	2.33	75	75	1862	15.7	99.9	
2		0.0	613.950							
	1	5.0	618.090	0.100	2.18	76	76	1803	0.3	99.8
	2	10.0	622.030	0.090	1.93	75	75	1837	1.1	101.0
	3	15.0	625.690	0.080	1.68	76	76	1883	1.9	100.3
	4	20.0	629.790	0.100	2.11	77	77	1884	2.8	100.4
	5	25.0	634.100	0.110	2.37	77	77	1835	4.0	99.7
	6	30.0	638.200	0.100	2.15	78	78	1847	5.7	99.5
	7	35.0	642.120	0.090	1.97	79	79	1809	10.3	99.2
	8	40.0	645.810	0.080	1.75	79	79	1808	12.0	98.9
	9	45.0	649.650	0.085	1.86	79	79	1803	13.2	99.8
	10	50.0	653.320	0.080	1.69	80	80	1889	14.1	99.9
	11	55.0	657.040	0.080	1.75	80	80	1815	14.9	99.7
12	60.0	660.660	0.075	1.65	81	81	1805	15.7	99.8	

A. Lanfranco and Associates Inc. - Emission Report

		Average:	0.100	2.137	74.5	74.5	1837.0	99.9
--	--	-----------------	-------	-------	------	------	--------	------

Client: De Beers, Snap Lake
Jobsite: Snap Lake
Source: Incinerator Stack #1

Date: July. 13/14
Run: 3 Partic/ Metals
Run Time: 14:50-17:13

Particulate Concentration: **111.1 mg/dscm** 0.0485 gr/dscf
 22.3 mg/Acm 0.0098 gr/Acf
 79.8 mg/dscm (@ 11% O2) 0.0349 gr/dscf (@ 11% O2)

Emission Rate: 0.12 Kg/hr 0.270 lb/hr

Sample Gas Volume: 2.7220 dscm 96.126 dscf
Total Sample Time: 120.0 minutes

Average Isokineticity: 99.6 %

Flue Gas Characteristics

Moisture:	11.73 %	
Temperature	980.3 oC	1796.6 oF
Flow	18.4 dscm/min 0.31 dscm/sec 91.4 Acm/min	650 dscf/min 10.8 dscf/sec 3229 Acf/min
Velocity	11.749 m/sec	38.55 f/sec
Gas Analysis	7.13 % O2	10.25 % CO2
	29.925 Mol. Wt (g/gmole) Dry	28.527 Mol. Wt (g/gmole) Wet

*** Standard Conditions:** Metric: 25 deg C, 101.325 kPa
 Imperial: 77 deg F, 29.92 in.Hg

Client: De Beers, Snap Lake
Jobsite: Snap Lake
Source: Incinerator Stack #1

Date: July. 13/14
Run: 3 Partic/ Metals
Run Time: 14:50-17:13

Control Unit (Y) 0.9950
Nozzle Diameter (in.) 0.5623
Pitot Factor 0.8457
Baro. Press. (in. Hg) 28.66
Static Press. (in. H2O) 0.06
Stack Height (ft) 25
Stack Diameter (in.) 16.0
Stack Area (sq.ft.) 1.396
Minutes Per Reading 5.0
Minutes Per Point 5.0

Gas Analysis (Vol. %):

	CO2	O2
Trav. 1	10.50	6.15
Trav. 2	10.00	8.10
Average =	<u>10.25</u>	<u>7.13</u>

Condensate Collection:

Impinger 1 (grams)	176.0
Impinger 2 (grams)	54.0
Impinger 3 (grams)	10.0
Impinger 4 (grams)	14.0
Impinger 5 (grams)	0.0
Impinger 6 (grams)	12.0
Total Gain (grams)	<u>266.0</u>

Collection:

Filter (grams)	0.1476
Washings (grams)	0.1548
Impinger (grams)	0.0000
Total (grams)	<u>0.3024</u>

Traverse	Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature		Stack (oF)	Wall Dist. (in.)	Isokin. (%)
						Inlet (oF)	Outlet (oF)			
1		0.0	761.747							
	1	5.0	766.070	0.110	2.36	81	81	1819	0.3	99.8
	2	10.0	770.160	0.100	2.13	81	81	1834	1.1	99.2
	3	15.0	774.200	0.100	2.10	82	82	1876	1.9	98.7
	4	20.0	778.410	0.110	2.28	83	83	1908	2.8	98.6
	5	25.0	782.390	0.100	2.04	83	83	1946	4.0	98.5
	6	30.0	786.550	0.110	2.23	84	84	1966	5.7	98.5
	7	35.0	791.330	0.120	2.93	85	85	1560	10.3	98.8
	8	40.0	796.030	0.110	2.80	84	84	1472	12.0	99.4
	9	45.0	800.270	0.100	2.25	84	84	1720	13.2	99.8
	10	50.0	804.370	0.100	2.13	84	84	1850	14.1	99.3
	11	55.0	808.190	0.090	1.85	84	84	1926	14.9	99.0
12	60.0	812.070	0.090	1.90	85	85	1868	15.7	99.2	
		0.0	812.070							
2	1	5.0	817.050	0.110	2.40	84	84	1796	0.3	113.7
	2	10.0	821.870	0.110	2.43	83	83	1763	1.1	109.5
	3	15.0	825.940	0.100	2.10	84	84	1880	1.9	99.2
	4	20.0	830.200	0.105	2.31	82	82	1763	2.8	99.2
	5	25.0	834.590	0.110	2.45	81	81	1734	4.0	99.4
	6	30.0	839.150	0.120	2.68	81	81	1728	5.7	98.8
	7	35.0	843.420	0.110	2.32	83	83	1871	10.3	99.3
	8	40.0	847.280	0.100	2.21	82	82	1760	12.0	92.0
	9	45.0	851.390	0.100	2.14	83	83	1830	13.2	99.3
	10	50.0	855.470	0.095	2.10	82	82	1760	14.1	99.7
	11	55.0	859.440	0.090	2.00	83	83	1743	14.9	99.1
	12	60.0	863.130	0.090	1.86	82	82	1745	15.7	92.3

		Average:	0.103	2.250	82.9	82.9	1796.6	99.6
--	--	-----------------	-------	-------	------	------	--------	------

Client: De Beers, Snap Lake
Jobsite: Snap Lake
Source: Incinerator Stack #2

Date: July. 13/14
Run: 1 Partic/ Metals
Run Time: 09:33-11:45

Particulate Concentration: **140.8 mg/dscm** 0.0615 gr/dscf
 27.0 mg/Acm 0.0118 gr/Acf
 80.3 mg/dscm (@ 11% O2) 0.0351 gr/dscf (@ 11% O2)

Emission Rate: 0.15 Kg/hr 0.328 lb/hr

Sample Gas Volume: 2.7401 dscm 96.766 dscf
Total Sample Time: 120.0 minutes

Average Isokineticity: 104.9 %

Flue Gas Characteristics

Moisture: 14.68 %

Temperature 997.4 oC 1827.3 oF

Flow 17.6 dscm/min 622 dscf/min
 0.29 dscm/sec 10.4 dscf/sec
 91.8 Acm/min 3243 Acf/min

Velocity 11.798 m/sec 38.71 f/sec

Gas Analysis 3.54 % O2 12.88 % CO2

30.202 Mol. Wt (g/gmole) Dry 28.410 Mol. Wt (g/gmole) Wet

*** Standard Conditions:** Metric: 25 deg C, 101.325 kPa
 Imperial: 77 deg F, 29.92 in.Hg

Client: De Beers, Snap Lake
Jobsite: Snap Lake
Source: Incinerator Stack #2

Date: July. 13/14
Run: 1 Partic/ Metals
Run Time: 09:33-11:45

Control Unit (Y) 0.9950
Nozzle Diameter (in.) 0.5623
Pitot Factor 0.8457
Baro. Press. (in. Hg) 28.66
Static Press. (in. H2O) 0.08
Stack Height (ft) 25
Stack Diameter (in.) 16.0
Stack Area (sq.ft.) 1.396
Minutes Per Reading 5.0
Minutes Per Point 5.0

Gas Analysis (Vol. %):

	CO2	O2
Trav. 1	14.50	1.83
Trav. 2	11.25	5.25
Average =	<u>12.88</u>	<u>3.54</u>

Condensate Collection:

Impinger 1 (grams)	211.0
Impinger 2 (grams)	84.0
Impinger 3 (grams)	12.0
Impinger 4 (grams)	23.0
Impinger 5 (grams)	5.0
Impinger 6 (grams)	12.0
Total Gain (grams)	<u>347.0</u>

Collection:

Filter (grams)	0.2074
Washings (grams)	0.1784
Impinger (grams)	0.0000
Total (grams)	<u>0.3858</u>

Traverse	Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature		Stack (oF)	Wall Dist. (in.)	Isokin. (%)
						Inlet (oF)	Outlet (oF)			
		0.0	661.255							
1	1	5.0	665.470	0.100	2.31	63	63	1657	0.3	105.0
	2	10.0	669.850	0.110	2.52	63	63	1675	1.1	104.5
	3	15.0	674.300	0.115	2.60	63	63	1702	1.9	104.5
	4	20.0	678.640	0.110	2.47	64	64	1724	2.8	104.5
	5	25.0	682.760	0.100	2.21	65	65	1755	4.0	104.6
	6	30.0	686.900	0.100	2.22	66	66	1756	5.7	104.9
	7	35.0	691.000	0.100	2.17	67	67	1804	10.3	104.8
	8	40.0	695.160	0.105	2.27	67	67	1816	12.0	104.1
	9	45.0	699.210	0.100	2.15	67	67	1833	13.2	104.2
	10	50.0	703.250	0.100	2.13	68	68	1858	14.1	104.3
	11	55.0	707.100	0.090	1.90	69	69	1878	14.9	104.9
	12	60.0	710.910	0.090	1.88	69	69	1903	15.7	104.4
		0.0	710.900							
2	1	5.0	715.030	0.105	2.18	69	69	1916	0.3	105.1
	2	10.0	719.020	0.100	2.07	70	70	1927	1.1	104.1
	3	15.0	723.000	0.100	2.06	70	70	1941	1.9	104.1
	4	20.0	727.380	0.110	2.44	70	70	1775	2.8	105.5
	5	25.0	731.750	0.110	2.45	71	71	1776	4.0	105.1
	6	30.0	735.920	0.100	2.26	71	71	1735	5.7	104.2
	7	35.0	740.350	0.110	2.53	72	72	1898	10.3	109.2
	8	40.0	744.770	0.120	2.49	73	73	1938	12.0	105.0
	9	45.0	748.800	0.100	2.06	74	74	1957	13.2	105.0
	10	50.0	752.890	0.100	2.12	75	75	1896	14.1	105.0
	11	55.0	756.850	0.090	1.99	75	75	1797	14.9	104.9
	12	60.0	760.700	0.090	1.88	76	76	1938	15.7	104.9

A. Lanfranco and Associates Inc. - Emission Report

		Average:	0.102	2.223	69.0	69.0	1827.3	104.9
--	--	-----------------	-------	-------	------	------	--------	-------

Client: De Beers, Snap Lake
Jobsite: Snap Lake
Source: Incinerator Stack #2

Date: July. 14/14
Run: 2 Partic/ Metals
Run Time: 13:50-14:07

Particulate Concentration: 147.9 mg/dscm 0.0646 gr/dscf
 28.9 mg/Acm 0.0126 gr/Acf
 99.3 mg/dscm (@ 11% O2) 0.0434 gr/dscf (@ 11% O2)

Emission Rate: 0.15 Kg/hr 0.329 lb/hr

Sample Gas Volume: 2.5510 dscm 90.087 dscf
Total Sample Time: 120.0 minutes

Average Isokineticity: 102.4 %

Flue Gas Characteristics

Moisture:	13.22 %	
Temperature	994.1 oC	1821.4 oF
Flow	16.8 dscm/min 0.28 dscm/sec 86.0 Acm/min	593 dscf/min 9.9 dscf/sec 3039 Acf/min
Velocity	11.056 m/sec	36.27 f/sec
Gas Analysis	6.15 % O2	10.84 % CO2
	29.980 Mol. Wt (g/gmole) Dry	28.395 Mol. Wt (g/gmole) Wet

*** Standard Conditions:** Metric: 25 deg C, 101.325 kPa
 Imperial: 77 deg F, 29.92 in.Hg

Client: De Beers, Snap Lake
Jobsite: Snap Lake
Source: Incinerator Stack #2

Date: July. 14/14
Run: 2 Partic/ Metals
Run Time: 13:50-14:07

Control Unit (Y) 0.9950
Nozzle Diameter (in.) 0.5623
Pitot Factor 0.8457
Baro. Press. (in. Hg) 28.60
Static Press. (in. H2O) 0.08
Stack Height (ft) 25
Stack Diameter (in.) 16.0
Stack Area (sq.ft.) 1.396
Minutes Per Reading 5.0
Minutes Per Point 5.0

Gas Analysis (Vol. %):

	CO2	O2
Trav. 1	11.67	5.00
Trav. 2	10.00	7.30
Average =	<u>10.84</u>	<u>6.15</u>

Condensate Collection:

Impinger 1 (grams)	182.0
Impinger 2 (grams)	74.0
Impinger 3 (grams)	10.0
Impinger 4 (grams)	6.0
Impinger 5 (grams)	4.0
Impinger 6 (grams)	10.0
Total Gain (grams)	<u>286.0</u>

Collection:

Filter (grams)	0.2087
Washings (grams)	0.1686
Impinger (grams)	0.0000
Total (grams)	<u>0.3773</u>

Traverse	Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature		Stack (oF)	Wall Dist. (in.)	Isokin. (%)
						Inlet (oF)	Outlet (oF)			
		0.0	864.309							
1	1	5.0	868.160	0.085	1.88	79	79	1778	0.3	101.8
	2	10.0	872.170	0.085	2.02	80	80	1628	1.1	102.2
	3	15.0	876.160	0.090	2.00	80	80	1773	1.9	102.2
	4	20.0	880.370	0.100	2.22	81	81	1779	2.8	102.3
	5	25.0	884.600	0.100	2.24	82	82	1767	4.0	102.4
	6	30.0	888.720	0.095	2.13	82	82	1759	5.7	102.1
	7	35.0	892.980	0.100	2.25	83	83	1761	10.3	102.8
	8	40.0	897.120	0.095	2.12	84	84	1781	12.0	102.7
	9	45.0	901.280	0.100	2.14	85	85	1878	13.2	102.6
	10	50.0	905.350	0.095	2.06	84	84	1851	14.1	102.5
	11	55.0	909.300	0.090	1.93	85	85	1880	14.9	102.6
	12	60.0	913.230	0.090	1.91	85	85	1900	15.7	102.6
		0.0	913.230							
2	1	5.0	916.960	0.080	1.71	85	85	1881	0.3	102.8
	2	10.0	920.710	0.080	1.72	86	86	1879	1.1	103.1
	3	15.0	924.560	0.085	1.85	85	85	1847	1.9	102.2
	4	20.0	928.540	0.090	1.98	86	86	1816	2.8	101.8
	5	25.0	932.550	0.090	1.98	86	86	1816	4.0	102.6
	6	30.0	936.630	0.095	2.08	86	86	1832	5.7	102.0
	7	35.0	940.600	0.090	1.94	87	87	1867	10.3	102.5
	8	40.0	944.480	0.085	1.86	86	86	1836	12.0	102.6
	9	45.0	948.470	0.090	1.96	87	87	1848	13.2	102.6
	10	50.0	952.310	0.085	1.85	88	88	1858	14.1	101.6
	11	55.0	956.090	0.080	1.74	87	87	1846	14.9	103.0
	12	60.0	959.860	0.080	1.74	88	88	1852	15.7	102.7
			Average:	0.090	1.971	84.5	84.5	1821.4		102.4

Client: De Beers, Snap Lake
Jobsite: Snap Lake
Source: Incinerator Stack #2

Date: July. 15/14
Run: 3 Partic/ Metals
Run Time: 10:15-12:33

Particulate Concentration: **84.9 mg/dscm** 0.0371 gr/dscf
 16.3 mg/Acm 0.0071 gr/Acf
 58.2 mg/dscm (@ 11% O2) 0.0254 gr/dscf (@ 11% O2)

Emission Rate: 0.09 Kg/hr 0.194 lb/hr

Sample Gas Volume: 2.5775 dscm 91.026 dscf
Total Sample Time: 120.0 minutes

Average Isokineticity: 100.6 %

Flue Gas Characteristics

Moisture: 12.99 %

Temperature 1004.9 oC 1840.8 oF

Flow 17.3 dscm/min 610 dscf/min
 0.29 dscm/sec 10.2 dscf/sec
 90.0 Acm/min 3178 Acf/min

Velocity 11.564 m/sec 37.94 f/sec

Gas Analysis 6.46 % O2 10.75 % CO2

29.977 Mol. Wt (g/gmole) Dry 28.422 Mol. Wt (g/gmole) Wet

*** Standard Conditions:** Metric: 25 deg C, 101.325 kPa
 Imperial: 77 deg F, 29.92 in.Hg

Client: De Beers, Snap Lake
Jobsite: Snap Lake
Source: Incinerator Stack #2

Date: July. 15/14
Run: 3 Partic/ Metals
Run Time: 10:15-12:33

Control Unit (Y) 0.9950
Nozzle Diameter (in.) 0.5623
Pitot Factor 0.8457
Baro. Press. (in. Hg) 28.30
Static Press. (in. H2O) 0.08
Stack Height (ft) 25
Stack Diameter (in.) 16.0
Stack Area (sq.ft.) 1.396
Minutes Per Reading 5.0
Minutes Per Point 5.0

Gas Analysis (Vol. %):

	CO2	O2
Trav. 1	11.41	6.08
Trav. 2	10.08	6.83
Average =	<u>10.75</u>	<u>6.46</u>

Condensate Collection:

Impinger 1 (grams)	182.0
Impinger 2 (grams)	71.0
Impinger 3 (grams)	10.0
Impinger 4 (grams)	8.0
Impinger 5 (grams)	2.0
Impinger 6 (grams)	10.0
Total Gain (grams)	<u>283.0</u>

Collection:

Filter (grams)	0.1072
Washings (grams)	0.1116
Impinger (grams)	0.0000
Total (grams)	<u>0.2188</u>

Traverse	Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature		Stack (oF)	Wall Dist. (in.)	Isokin. (%)
						Inlet (oF)	Outlet (oF)			
1		0.0	960.470							
	1	5.0	964.410	0.095	2.00	70	70	1815	0.3	100.3
	2	10.0	968.290	0.090	1.90	71	71	1805	1.1	101.0
	3	15.0	972.330	0.100	2.10	70	70	1823	1.9	100.5
	4	20.0	976.470	0.105	2.20	71	71	1826	2.8	100.4
	5	25.0	980.630	0.105	2.21	72	72	1819	4.0	100.5
	6	30.0	984.850	0.110	2.28	76	76	1860	5.7	99.8
	7	35.0	989.100	0.110	2.32	73	73	1822	10.3	100.2
	8	40.0	993.220	0.105	2.18	74	74	1865	12.0	100.2
	9	45.0	997.330	0.100	2.11	76	76	1838	13.2	101.4
	10	50.0	1001.420	0.100	2.08	77	77	1874	14.1	101.5
	11	55.0	1005.290	0.090	1.91	77	77	1822	14.9	100.0
12	60.0	1009.150	0.090	1.87	78	78	1880	15.7	100.8	
		0.0	1009.150							
2	1	5.0	1013.030	0.090	1.91	79	79	1837	0.3	100.2
	2	10.0	1017.000	0.095	1.99	79	79	1863	1.1	100.4
	3	15.0	1021.090	0.100	2.11	80	80	1845	1.9	100.3
	4	20.0	1025.000	0.090	1.92	79	79	1825	2.8	100.8
	5	25.0	1029.090	0.100	2.12	79	79	1840	4.0	100.4
	6	30.0	1033.220	0.100	2.13	80	80	1831	5.7	101.0
	7	35.0	1037.330	0.100	2.13	81	81	1836	10.3	100.4
	8	40.0	1041.340	0.095	1.98	80	80	1875	12.0	101.5
	9	45.0	1045.260	0.090	1.91	80	80	1838	13.2	101.1
	10	50.0	1049.170	0.090	1.91	80	80	1839	14.1	100.9
	11	55.0	1052.960	0.085	1.79	81	81	1862	14.9	100.9
	12	60.0	1056.660	0.080	1.70	82	82	1839	15.7	100.8
		Average:		0.096	2.032	76.9	76.9	1840.8		100.6

APPENDIX 2
ANALYTICAL DATA

METHOD 23/1-RM-3 DATA REPORT

Client: A. Lanfranco & Associates
 Client ID: Snap Lake - Run 1
 Incinerator #1
 PRL ID: PR141628

Sample Date: 11-Jul-14
 Date Extracted: 29-Jul-14
 Date Analysed: 16-Aug-14
 Filter Wt.: 0.44 g

DIOXINS			
Congeners	pg	DL pg	# of peaks
2,3,7,8-TCDD	ND	2	
Total TCDD	240	2	0
1,2,3,7,8-PeCDD	210	4	
Total PeCDD	1400	4	0
1,2,3,4,7,8-HxCDD	220	4	
1,2,3,6,7,8-HxCDD	250	4	
1,2,3,7,8,9-HxCDD	250	4	
Total HxCDD	3900	4	0
1,2,3,4,6,7,8-HpCDD	2000	4	
Total HpCDD	4300	4	0
OCDD	3500	15	0
Total Dioxin TEQ			

I-TEQs		
(ND=0) pg	(ND=½DL) pg	(ND=DL) pg
ND	1	2
105	105	105
22	22	22
25	25	25
25	25	25
20	20	20
3.5	3.5	3.5
200	200	200

FURANS			
Congeners	pg	DL pg	# of peaks
2,3,7,8-TCDF	120	2	
Total TCDF	1900	2	0
1,2,3,7,8-PeCDF	160	4	
2,3,4,7,8-PeCDF	370	4	
Total PeCDF	4200	4	0
1,2,3,4,7,8-HxCDF	360	4	
1,2,3,6,7,8-HxCDF	450	4	
1,2,3,7,8,9-HxCDF	170	4	
2,3,4,6,7,8-HxCDF	850	4	
Total HxCDF	4300	4	0
1,2,3,4,6,7,8-HpCDF	2300	4	
1,2,3,4,7,8,9-HpCDF	350	4	
Total HpCDF	4200	4	0
OCDF	1200	15	0
Total Furan TEQ			

I-TEQs		
(ND=0) pg	(ND=½DL) pg	(ND=DL) pg
12	12	12
8	8	8
185	185	185
36	36	36
45	45	45
17	17	17
85	85	85
23	23	23
3.5	3.5	3.5
1.2	1.2	1.2
420	420	420

Total PCDD/PCDF Toxic Equivalent (pg)

620 620 620


Surrogate Recoveries (%)

³⁷ Cl ₄ -2,3,7,8-TCDD	93
¹³ C ₁₂ -2,3,4,7,8-PeCDF	88
¹³ C ₁₂ -1,2,3,4,7,8-HxCDD	88
¹³ C ₁₂ -1,2,3,4,7,8-HxCDF	89
¹³ C ₁₂ -1,2,3,4,7,8,9-HpCDF	71

ND - none detected

Internal Standards (%)

¹³ C ₁₂ -2,3,7,8-TCDD	90
¹³ C ₁₂ -1,2,3,7,8-PeCDD	101
¹³ C ₁₂ -1,2,3,6,7,8-HxCDD	95
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDD	88
¹³ C ₁₂ -OCDD	103
¹³ C ₁₂ -2,3,7,8-TCDF	62
¹³ C ₁₂ -1,2,3,7,8-PeCDF	93
¹³ C ₁₂ -1,2,3,6,7,8-HxCDF	99
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDF	84



Patrick Pond
 Patrick Pond CTO 12/05/14

METHOD 23/1-RM-3 DATA REPORT

Client: A. Lanfranco & Associates
 Client ID: Snap Lake - Run 2
 Incinerator #1
 PR141629

Sample Date: 12-Jul-14
 Date Extracted: 29-Jul-14
 Date Analysed: 16-Aug-14
 Filter Wt.: 0.47 g

DIOXINS			
Congeners	pg	DL pg	# of peaks
2,3,7,8-TCDD	54	2	
Total TCDD	1500	2	5
1,2,3,7,8-PeCDD	1000	4	
Total PeCDD	4800	4	7
1,2,3,4,7,8-HxCDD	1600	4	
1,2,3,6,7,8-HxCDD	1100	4	
1,2,3,7,8,9-HxCDD	940	4	
Total HxCDD	16000	4	5
1,2,3,4,6,7,8-HpCDD	19000	4	
Total HpCDD	36000	4	2
OCDD	53000	15	1
			Total Dioxin TEQ

I-TEQs		
(ND=0) pg	(ND=1/2DL) pg	(ND=DL) pg
54	54	54
500	500	500
160	160	160
110	110	110
94	94	94
190	190	190
53	53	53
1200	1200	1200

FURANS			
Congeners	pg	DL pg	# of peaks
2,3,7,8-TCDF	200	2	
Total TCDF	5000	2	9
1,2,3,7,8-PeCDF	590	4	
2,3,4,7,8-PeCDF	1300	4	
Total PeCDF	21000	4	3
1,2,3,4,7,8-HxCDF	1700	4	
1,2,3,6,7,8-HxCDF	3100	4	
1,2,3,7,8,9-HxCDF	1200	4	
2,3,4,6,7,8-HxCDF	7600	4	
Total HxCDF	28000	4	8
1,2,3,4,6,7,8-HpCDF	22000	4	
1,2,3,4,7,8,9-HpCDF	3200	4	
Total HpCDF	39000	4	3
OCDF	21000	15	1
			Total Furan TEQ

I-TEQs		
(ND=0) pg	(ND=1/2DL) pg	(ND=DL) pg
20	20	20
29.5	29.5	29.5
650	650	650
170	170	170
310	310	310
120	120	120
760	760	760
220	220	220
32	32	32
21	21	21
2300	2300	2300

Total PCDD/PCDF Toxic Equivalent (pg)

3500 3500 3500

Surrogate Recoveries (%)


³⁷ Cl ₄ -2,3,7,8-TCDD	93
¹³ C ₁₂ -2,3,4,7,8-PeCDF	90
¹³ C ₁₂ -1,2,3,4,7,8-HxCDD	89
¹³ C ₁₂ -1,2,3,4,7,8-HxCDF	83
¹³ C ₁₂ -1,2,3,4,7,8,9-HpCDF	71

Internal Standards (%)

¹³ C ₁₂ -2,3,7,8-TCDD	78
¹³ C ₁₂ -1,2,3,7,8-PeCDD	103
¹³ C ₁₂ -1,2,3,6,7,8-HxCDD	94
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDD	93
¹³ C ₁₂ -OCDD	126
¹³ C ₁₂ -2,3,7,8-TCDF	59
¹³ C ₁₂ -1,2,3,7,8-PeCDF	88
¹³ C ₁₂ -1,2,3,6,7,8-HxCDF	93
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDF	85

ND - none detected

Patrick Pond
 Patrick Pond CTO




METHOD 23/1-RM-3 DATA REPORT

Client: A. Lanfranco & Associates
 Client ID: Snap Lake - Run 3
 Incinerator #1
 PRL ID: PR141630

Sample Date: 13-Jul-14
 Date Extracted: 29-Jul-14
 Date Analysed: 17-Aug-14
 Filter Wt.: 0.96 g

DIOXINS			
Congeners	pg	DL pg	# of peaks
2,3,7,8-TCDD	130	2	
Total TCDD	1200	2	8
1,2,3,7,8-PeCDD	750	4	
Total PeCDD	3800	4	7
1,2,3,4,7,8-HxCDD	840	4	
1,2,3,6,7,8-HxCDD	1400	4	
1,2,3,7,8,9-HxCDD	1100	4	
Total HxCDD	16000	4	7
1,2,3,4,6,7,8-HpCDD	22000	4	
Total HpCDD	43000	4	2
OCDD	53000	15	1
			Total Dioxin TEQ

I-TEQs		
(ND=0) pg	(ND=½DL) pg	(ND=DL) pg
130	130	130
375	375	375
84	84	84
140	140	140
110	110	110
220	220	220
53	53	53
1100	1100	1100

FURANS			
Congeners	pg	DL pg	# of peaks
2,3,7,8-TCDF	520	2	
Total TCDF	11000	2	8
1,2,3,7,8-PeCDF	1300	4	
2,3,4,7,8-PeCDF	2500	4	
Total PeCDF	36000	4	3
1,2,3,4,7,8-HxCDF	3500	4	
1,2,3,6,7,8-HxCDF	4900	4	
1,2,3,7,8,9-HxCDF	2800	4	
2,3,4,6,7,8-HxCDF	12000	4	
Total HxCDF	46000	4	7
1,2,3,4,6,7,8-HpCDF	23000	4	
1,2,3,4,7,8,9-HpCDF	11000	4	
Total HpCDF	73000	4	4
OCDF	45000	15	1
			Total Furan TEQ

I-TEQs		
(ND=0) pg	(ND=½DL) pg	(ND=DL) pg
52	52	52
65	65	65
1250	1250	1250
350	350	350
490	490	490
280	280	280
1200	1200	1200
230	230	230
110	110	110
45	45	45
4100	4100	4100

Total PCDD/PCDF Toxic Equivalent (pg)

5200 5200 5200

Surrogate Recoveries (%)


³⁷ Cl ₄ -2,3,7,8-TCDD	94
¹³ C ₁₂ -2,3,4,7,8-PeCDF	89
¹³ C ₁₂ -1,2,3,4,7,8-HxCDD	83
¹³ C ₁₂ -1,2,3,4,7,8-HxCDF	81
¹³ C ₁₂ -1,2,3,4,7,8,9-HpCDF	76

ND - none detected

Internal Standards (%)

¹³ C ₁₂ -2,3,7,8-TCDD	81
¹³ C ₁₂ -1,2,3,7,8-PeCDD	101
¹³ C ₁₂ -1,2,3,6,7,8-HxCDD	96
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDD	96
¹³ C ₁₂ -OCDD	130
¹³ C ₁₂ -2,3,7,8-TCDF	54
¹³ C ₁₂ -1,2,3,7,8-PeCDF	87
¹³ C ₁₂ -1,2,3,6,7,8-HxCDF	98
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDF	87

Patrick Pond
 Patrick Pond CTO



METHOD 23/1-RM-3 DATA REPORT

Client: A. Lanfranco & Associates
 Client ID: Snap Lake - Run 1
 Incinerator #2
 PRL ID: PR141631

Sample Date: 13-Jul-14
 Date Extracted: 29-Jul-14
 Date Analysed: 16-Aug-14
 Filter Wt.: 0.99 g

DIOXINS			
Congeners	pg	DL pg	# of peaks
2,3,7,8-TCDD	340	2	
Total TCDD	2900	2	8
1,2,3,7,8-PeCDD	1800	4	
Total PeCDD	12000	4	7
1,2,3,4,7,8-HxCDD	3900	4	
1,2,3,6,7,8-HxCDD	4600	4	
1,2,3,7,8,9-HxCDD	3400	4	
Total HxCDD	42000	4	3
1,2,3,4,6,7,8-HpCDD	64000	4	
Total HpCDD	112000	4	2
OCDD	127000	15	1
			Total Dioxin TEQ

I-TEQs		
(ND=0)	(ND=1/2DL)	(ND=DL)
pg	pg	pg
340	340	340
900	900	900
390	390	390
460	460	460
340	340	340
640	640	640
127	127	127
3200	3200	3200

FURANS			
Congeners	pg	DL pg	# of peaks
2,3,7,8-TCDF	2300	2	
Total TCDF	37000	2	12
1,2,3,7,8-PeCDF	4200	4	
2,3,4,7,8-PeCDF	4900	4	
Total PeCDF	91000	4	7
1,2,3,4,7,8-HxCDF	6500	4	
1,2,3,6,7,8-HxCDF	8500	4	
1,2,3,7,8,9-HxCDF	3200	4	
2,3,4,6,7,8-HxCDF	15000	4	
Total HxCDF	71000	4	7
1,2,3,4,6,7,8-HpCDF	36000	4	
1,2,3,4,7,8,9-HpCDF	12000	4	
Total HpCDF	104000	4	4
OCDF	70000	15	1
			Total Furan TEQ

I-TEQs		
(ND=0)	(ND=1/2DL)	(ND=DL)
pg	pg	pg
230	230	230
210	210	210
2450	2450	2450
650	650	650
850	850	850
320	320	320
1500	1500	1500
360	360	360
120	120	120
70	70	70
6800	6800	6800

Total PCDD/PCDF Toxic Equivalent (pg)

10000 10000 10000

Surrogate Recoveries (%)


³⁷ Cl ₄ -2,3,7,8-TCDD	93
¹³ C ₁₂ -2,3,4,7,8-PeCDF	84
¹³ C ₁₂ -1,2,3,4,7,8-HxCDD	92
¹³ C ₁₂ -1,2,3,4,7,8-HxCDF	78
¹³ C ₁₂ -1,2,3,4,7,8,9-HpCDF	65

ND - none detected

Internal Standards (%)

¹³ C ₁₂ -2,3,7,8-TCDD	84
¹³ C ₁₂ -1,2,3,7,8-PeCDD	93
¹³ C ₁₂ -1,2,3,6,7,8-HxCDD	91
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDD	93
¹³ C ₁₂ -OCDD	116
¹³ C ₁₂ -2,3,7,8-TCDF	58
¹³ C ₁₂ -1,2,3,7,8-PeCDF	87
¹³ C ₁₂ -1,2,3,6,7,8-HxCDF	101
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDF	87

(Signature)
 Patrick Pond CTO



METHOD 23/1-RM-3 DATA REPORT

Client: A. Lanfranco & Associates
 Client ID: Snap Lake - Run 2
 Incinerator #2: PR141632

Sample Date: 14-Jul-14
 Date Extracted: 29-Jul-14
 Date Analysed: 16-Aug-14
 Filter Wt.: 1.04 g

DIOXINS			
Congeners	pg	DL pg	# of peaks
2,3,7,8-TCDD	9200	2	
Total TCDD	38000	2	6
1,2,3,7,8-PeCDD	20000	4	
Total PeCDD	80000	4	7
1,2,3,4,7,8-HxCDD	6800	4	
1,2,3,6,7,8-HxCDD	11000	4	
1,2,3,7,8,9-HxCDD	7800	4	
Total HxCDD	103000	4	7
1,2,3,4,6,7,8-HpCDD	45000	4	
Total HpCDD	80000	4	2
OCDD	47000	15	1
Total Dioxin TEQ			

I-TEQs		
(ND=0) pg	(ND=½DL) pg	(ND=DL) pg
9200	9200	9200
10000	10000	10000
680	680	680
1100	1100	1100
780	780	780
450	450	450
47	47	47
22000	22000	22000

FURANS			
Congeners	pg	DL pg	# of peaks
2,3,7,8-TCDF	34000	2	
Total TCDF	436000	2	13
1,2,3,7,8-PeCDF	38000	4	
2,3,4,7,8-PeCDF	25000	4	
Total PeCDF	509000	4	8
1,2,3,4,7,8-HxCDF	22000	4	
1,2,3,6,7,8-HxCDF	23000	4	
1,2,3,7,8,9-HxCDF	5200	4	
2,3,4,6,7,8-HxCDF	21000	4	
Total HxCDF	171000	4	9
1,2,3,4,6,7,8-HpCDF	33000	4	
1,2,3,4,7,8,9-HpCDF	10000	4	
Total HpCDF	93000	4	4
OCDF	41000	15	1
Total Furan TEQ			

I-TEQs		
(ND=0) pg	(ND=½DL) pg	(ND=DL) pg
3400	3400	3400
1900	1900	1900
12500	12500	12500
2200	2200	2200
2300	2300	2300
520	520	520
2100	2100	2100
330	330	330
100	100	100
41	41	41
25000	25000	25000

Total PCDD/PCDF Toxic Equivalent (pg)

47000 47000 47000


Surrogate Recoveries (%)

³⁷ Cl ₄ -2,3,7,8-TCDD	101
¹³ C ₁₂ -2,3,4,7,8-PeCDF	90
¹³ C ₁₂ -1,2,3,4,7,8-HxCDD	86
¹³ C ₁₂ -1,2,3,4,7,8-HxCDF	95
¹³ C ₁₂ -1,2,3,4,7,8,9-HpCDF	75

ND - none detected

Internal Standards (%)

¹³ C ₁₂ -2,3,7,8-TCDD	77
¹³ C ₁₂ -1,2,3,7,8-PeCDD	92
¹³ C ₁₂ -1,2,3,6,7,8-HxCDD	88
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDD	85
¹³ C ₁₂ -OCDD	87
¹³ C ₁₂ -2,3,7,8-TCDF	44
¹³ C ₁₂ -1,2,3,7,8-PeCDF	88
¹³ C ₁₂ -1,2,3,6,7,8-HxCDF	97
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDF	85



Patrick Pond
 Patrick Pond
 CTO



METHOD 23/1-RM-3 DATA REPORT

Client: A. Lanfranco & Associates
 Client ID: Snap Lake - Run 3
 Incinerator #2
 PRL ID: PR141633

Sample Date: 15-Jul-14
 Date Extracted: 29-Jul-14
 Date Analysed: 16-Aug-14
 Filter Wt.: 0.58 g

DIOXINS			
Congeners	pg	DL pg	# of peaks
2,3,7,8-TCDD	2200	2	
Total TCDD	13000	2	7
1,2,3,7,8-PeCDD	14000	4	
Total PeCDD	71000	4	7
1,2,3,4,7,8-HxCDD	16000	4	
1,2,3,6,7,8-HxCDD	24000	4	
1,2,3,7,8,9-HxCDD	16000	4	
Total HxCDD	200000	4	7
1,2,3,4,6,7,8-HpCDD	69000	4	
Total HpCDD	127000	4	2
OCDD	117000	15	1
Total Dioxin TEQ			

I-TEQs		
(ND=0)	(ND=½DL)	(ND=DL)
pg	pg	pg
2200	2200	2200
7000	7000	7000
1600	1600	1600
2400	2400	2400
1600	1600	1600
690	690	690
117	117	117
16000	16000	16000

FURANS			
Congeners	pg	DL pg	# of peaks
2,3,7,8-TCDF	7400	2	
Total TCDF	127000	2	10
1,2,3,7,8-PeCDF	17000	4	
2,3,4,7,8-PeCDF	20000	4	
Total PeCDF	339000	4	7
1,2,3,4,7,8-HxCDF	23000	4	
1,2,3,6,7,8-HxCDF	25000	4	
1,2,3,7,8,9-HxCDF	11000	4	
2,3,4,6,7,8-HxCDF	34000	4	
Total HxCDF	242000	4	13
1,2,3,4,6,7,8-HpCDF	40000	4	
1,2,3,4,7,8,9-HpCDF	29000	4	
Total HpCDF	139000	4	4
OCDF	69000	15	1
Total Furan TEQ			

I-TEQs		
(ND=0)	(ND=½DL)	(ND=DL)
pg	pg	pg
740	740	740
850	850	850
10000	10000	10000
2300	2300	2300
2500	2500	2500
1100	1100	1100
3400	3400	3400
400	400	400
290	290	290
69	69	69
22000	22000	22000

Total PCDD/PCDF Toxic Equivalent (pg)

38000 38000 38000


Surrogate Recoveries (%)

³⁷ Cl ₄ -2,3,7,8-TCDD	95
¹³ C ₁₂ -2,3,4,7,8-PeCDF	88
¹³ C ₁₂ -1,2,3,4,7,8-HxCDD	85
¹³ C ₁₂ -1,2,3,4,7,8-HxCDF	86
¹³ C ₁₂ -1,2,3,4,7,8,9-HpCDF	76

ND - none detected

Internal Standards (%)

¹³ C ₁₂ -2,3,7,8-TCDD	74
¹³ C ₁₂ -1,2,3,7,8-PeCDD	100
¹³ C ₁₂ -1,2,3,6,7,8-HxCDD	95
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDD	100
¹³ C ₁₂ -OCDD	129
¹³ C ₁₂ -2,3,7,8-TCDF	45
¹³ C ₁₂ -1,2,3,7,8-PeCDF	89
¹³ C ₁₂ -1,2,3,6,7,8-HxCDF	97
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDF	91



Patrick Pond
 Patrick Pond CTO

Report Transmission Cover Page

Bill To: A. Lanfranco & Associates
Report To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Al LanFranco
Sampled By:
Company:

Project:
ID:
Name: Debeers
Location: Snaplake, YT
LSD:
P.O.:
Acct code:

Lot ID: **1017066**
Control Number: B202062
Date Received: Jul 28, 2014
Date Reported: Aug 18, 2014
Report Number: 1936220

Contact & Affiliation	Address	Delivery Commitments
Mark Lanfranco A. Lanfranco & Associates Inc.	#101, 9488 - 189 Street Surrey, British Columbia V4N 4W7 Phone: (604) 881-2582 Fax: (604) 881-2581 Email: mark.lanfranco@alanfranco.com	On [Lot Verification] send (COA) by Email - Multiple Reports By Agreement On [Report Approval] send (COC, Test Report) by Email - Merge Reports On [Lot Creation] send (COR) by Email - Single Report

Notes To Clients:

Analytical Report

Bill To: A. Lanfranco & Associates
 Report To: A. Lanfranco & Associates
 #101, 9488 - 189 Street
 Surrey, BC, Canada
 V4N 4W7
 Attn: Al LanFranco
 Sampled By:
 Company:

Project:
 ID:
 Name: Debeers
 Location: Snaplake, YT
 LSD:
 P.O.:
 Acct code:

Lot ID: **1017066**
 Control Number: B202062
 Date Received: Jul 28, 2014
 Date Reported: Aug 18, 2014
 Report Number: 1936220

Analyte	Matrix	Units	Reference Number	1017066-1	1017066-2	1017066-3	Nominal Detection Limit
			Sample Date	Sample Time	Sample Location	Sample Description	
				Stack Samples	Stack Samples	Stack Samples	
Mercury by CVAA							
Mercury	As Tested	ug/L		<0.050	<0.050	<0.050	0.05
Dilution Factor	As Tested			1.00	1.00	1.00	
Volume	Sample	mL		250	250	250	
Volume	aliquot volume	mL		25.0	25.0	25.0	
Volume	Final	mL		40.0	40.0	40.0	
Mercury	Fraction 1B	ug/sample		<0.020	<0.020	<0.020	
Mercury	As Tested	ug/L		<0.050	<0.050	<0.050	0.05
Dilution Factor	As Tested			1.00	1.00	1.00	
Volume	Sample	mL		700	1040	1060	
Volume	aliquot volume	mL		5.00	5.00	5.00	
Volume	Final	mL		40.0	40.0	40.0	
Mercury	Fraction 2B	ug/sample		<0.280	<0.416	<0.424	
Mercury	As Tested	ug/L		<0.050	<0.050	<0.050	0.05
Dilution Factor	As Tested			1.00	1.00	1.00	
Volume	Sample	mL		118	151	94.0	
Volume	aliquot volume	mL		25.0	25.0	25.0	
Volume	Final	mL		40.0	40.0	40.0	
Mercury	Fraction 3A	ug/sample		<0.009	<0.012	<0.008	
Mercury	As Tested	ug/L		<0.050	<0.050	<0.050	0.05
Dilution Factor	As Tested			1.00	1.00	1.00	
Volume	Sample	mL		1000	1000	1000	
Volume	aliquot volume	mL		25.0	25.0	25.0	
Volume	Final	mL		40.0	40.0	40.0	
Mercury	Fraction 3B	ug/sample		<0.080	<0.080	<0.080	
Mercury	As Tested	ug/L		<0.05	0.25	0.33	0.05
Dilution Factor	As Tested			1.00	1.00	1.00	
Volume	Sample	mL		200	200	200	
Volume	aliquot volume	mL		25.0	25.0	25.0	
Volume	Final	mL		40	40	40	
Mercury	Fraction 3C	ug/sample		<0.02	0.080	0.11	



Analytical Report

Bill To: A. Lanfranco & Associates
 Report To: A. Lanfranco & Associates
 #101, 9488 - 189 Street
 Surrey, BC, Canada
 V4N 4W7
 Attn: Al LanFranco
 Sampled By:
 Company:

Project:
 ID:
 Name: Debeers
 Location: Snaplake, YT
 LSD:
 P.O.:
 Acct code:

Lot ID: **1017066**
 Control Number: B202062
 Date Received: Jul 28, 2014
 Date Reported: Aug 18, 2014
 Report Number: 1936220

Analyte	Matrix	Units	Reference Number	Reference Number	Reference Number	Nominal Detection Limit
			1017066-4	1017066-5	1017066-6	
			Sample Date	Sample Date	Sample Date	
			Sample Time	Sample Time	Sample Time	
			Sample Location	Sample Location	Sample Location	
			Sample Description	Sample Description	Sample Description	
			Unit #1 Run#3 - Blank Beaker (Met 3) + 3 bottles Stack Samples	Unit #2 Run#1 - Blank Beaker (Mex1) + 3 bottles Stack Samples	Unit #2 Run#2 - Blank Beaker (MB2) + 3 bottles Stack Samples	
			Results	Results	Results	
Mercury by CVAA						
Mercury	As Tested	ug/L	<0.050	<0.050	0.140	0.05
Dilution Factor	As Tested		1.00	1.00	1.00	
Volume	Sample	mL	250	250	250	
Volume	aliquot volume	mL	25.0	25.0	25.0	
Volume	Final	mL	40.0	40.0	40.0	
Mercury	Fraction 1B	ug/sample	<0.020	<0.020	0.056	
Mercury	As Tested	ug/L	<0.050	<0.050	<0.050	0.05
Dilution Factor	As Tested		1.00	1.00	1.00	
Volume	Sample	mL	1000	930	980	
Volume	aliquot volume	mL	5.00	5.00	5.00	
Volume	Final	mL	40.0	40.0	40.0	
Mercury	Fraction 2B	ug/sample	<0.400	<0.372	<0.392	
Mercury	As Tested	ug/L	<0.050	<0.050	<0.050	0.05
Dilution Factor	As Tested		1.00	1.00	1.00	
Volume	Sample	mL	110	98.0	109	
Volume	aliquot volume	mL	25.0	25.0	25.0	
Volume	Final	mL	40.0	40.0	40.0	
Mercury	Fraction 3A	ug/sample	<0.009	<0.008	<0.009	
Mercury	As Tested	ug/L	<0.050	<0.050	<0.050	0.05
Dilution Factor	As Tested		1.00	1.00	1.00	
Volume	Sample	mL	1000	1000	1000	
Volume	aliquot volume	mL	25.0	25.0	25.0	
Volume	Final	mL	40.0	40.0	40.0	
Mercury	Fraction 3B	ug/sample	<0.080	<0.080	<0.080	
Mercury	As Tested	ug/L	0.89	0.64	0.33	0.05
Dilution Factor	As Tested		1.00	1.00	1.00	
Volume	Sample	mL	200	200	200	
Volume	aliquot volume	mL	25.0	25.0	25.0	
Volume	Final	mL	40	40	40	
Mercury	Fraction 3C	ug/sample	0.28	0.20	0.11	



Analytical Report

Bill To: A. Lanfranco & Associates
 Report To: A. Lanfranco & Associates
 #101, 9488 - 189 Street
 Surrey, BC, Canada
 V4N 4W7
 Attn: Al LanFranco
 Sampled By:
 Company:

Project:
 ID:
 Name: Debeers
 Location: Snaplake, YT
 LSD:
 P.O.:
 Acct code:

Lot ID: **1017066**
 Control Number: B202062
 Date Received: Jul 28, 2014
 Date Reported: Aug 18, 2014
 Report Number: 1936220

Reference Number 1017066-7
 Sample Date
 Sample Time
 Sample Location
 Sample Description Unit #2 Run#3 -
 Blank Beaker
 (MNew7) + 3 bottles
 Matrix Stack Samples

Analyte		Units	Results	Results	Results	Nominal Detection Limit
Mercury by CVAA						
Mercury	As Tested	ug/L	<0.050			0.05
Dilution Factor	As Tested		1.00			
Volume	Sample	mL	250			
Volume	aliquot volume	mL	25.0			
Volume	Final	mL	40.0			
Mercury	Fraction 1B	ug/sample	<0.020			
Mercury	As Tested	ug/L	<0.050			0.05
Dilution Factor	As Tested		1.00			
Volume	Sample	mL	970			
Volume	aliquot volume	mL	5.00			
Volume	Final	mL	40.0			
Mercury	Fraction 2B	ug/sample	<0.388			
Mercury	As Tested	ug/L	<0.050			0.05
Dilution Factor	As Tested		1.00			
Volume	Sample	mL	113			
Volume	aliquot volume	mL	25.0			
Volume	Final	mL	40.0			
Mercury	Fraction 3A	ug/sample	<0.009			
Mercury	As Tested	ug/L	<0.050			0.05
Dilution Factor	As Tested		1.00			
Volume	Sample	mL	1000			
Volume	aliquot volume	mL	25.0			
Volume	Final	mL	40.0			
Mercury	Fraction 3B	ug/sample	<0.080			
Mercury	As Tested	ug/L	0.46			0.05
Dilution Factor	As Tested		1.00			
Volume	Sample	mL	200			
Volume	aliquot volume	mL	25.0			
Volume	Final	mL	40			
Mercury	Fraction 3C	ug/sample	0.15			

Analytical Report

Bill To: A. Lanfranco & Associates
Report To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Al LanFranco
Sampled By:
Company:

Project:
ID:
Name: Debeers
Location: Snaplake, YT
LSD:
P.O.:
Acct code:

Lot ID: **1017066**
Control Number: B202062
Date Received: Jul 28, 2014
Date Reported: Aug 18, 2014
Report Number: 1936220

Approved by:



Carol Nam, Dipl. T.
Quality Officer

Data have been validated by Analytical Quality Control and Exova's Integrated Data Validation System (IDVS).
Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

Methodology and Notes

Bill To: A. Lanfranco & Associates	Project:	Lot ID: 1017066
Report To: A. Lanfranco & Associates	ID:	Control Number: B202062
#101, 9488 - 189 Street	Name: Debeers	Date Received: Jul 28, 2014
Surrey, BC, Canada	Location: Snaplake, YT	Date Reported: Aug 18, 2014
V4N 4W7	LSD:	Report Number: 1936220
Attn: Al LanFranco	P.O.:	
Sampled By:	Acct code:	
Company:		

Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Mercury in Air (Surrey) - 1B	EMC	* Metals Emissions from Stationary Sources, 29	30-Jul-14	Exova Surrey
Mercury in Air (Surrey) - 2B	EMC	* Metals Emissions from Stationary Sources, 29	13-Aug-14	Exova Surrey
Mercury in Air (Surrey) - 3A	EMC	* Metals Emissions from Stationary Sources, 29	11-Aug-14	Exova Surrey
Mercury in Air (Surrey) - 3B	EMC	* Metals Emissions from Stationary Sources, 29	13-Aug-14	Exova Surrey
Mercury in Air (Surrey) - 3C	EMC	* Metals Emissions from Stationary Sources, 29	11-Aug-14	Exova Surrey

** Reference Method Modified*

Comments:

Please direct any inquiries regarding this report to our Client Services group.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.

Project Information

Project ID: _____
 Project Name: DE BEERS
 Project Location: SAMP LAKE, Y.T.
 Legal Location: _____
 PO/A/E#: _____
 Proj. Acct. Code: _____

Billing Information

Company: A. LAMFARCO + ASSOC
 Address: _____
 Attention: _____
 Phone: _____
 Cell: _____
 Fax: _____
 E-mail: mart.lamfarco@lamfarco.com
 Agreement ID: _____

Copy of Report To:

Company: _____
 Address: _____
 Attention: _____
 Phone: _____
 Cell: _____
 Fax: _____

Environmental Sample Information Sheet

LOT: 1017066

Note: Proper completion of this form is required in order to proceed with analysis
 Please indicate any potentially hazardous samples

Page _____ of _____ Control # B20262

Report Results

Report Results	Online	E-mail	PDF	Excel	QA/QC Report

Special Instructions/Comments (please include contact information including ph. # if different from above):
Use full Method 29 By C.U.A.A.

Sample Identification	Location	Depth IN CM M	Date/Time sampled	Matrix	Sampling Method	Enter tests above (√ relevant samples below)	Number of Containers	
							↑	↓
1								
2	<u>SAMP LAKE - BLANK</u>					<u>4</u> ✓		
3	<u>Unit #1, Run #1</u>					<u>4</u> ✓		
4	<u>Unit #1, Run #2</u>					<u>4</u> ✓		
5	<u>Unit #1, Run #3</u>					<u>4</u> ✓		
6	<u>Unit #2, Run #1</u>					<u>4</u> ✓		
7	<u>Unit #2, Run #2</u>					<u>4</u> ✓		
8	<u>Unit #2, Run #3</u>					<u>4</u> ✓		
9								
10								
11								
12								
13								
14								
15								

Signature

Sample Custody (please print)

Sampled by: _____

Company: _____

I authorize Exova to proceed with the work indicated on this form: _____ Initial: _____

Date: _____

This section for Lab use only

Date/Time stamp: _____

Indicate below any deficiencies in the condition of samples:

Were Exova supplies used? _____

Was there any damage to the shipping container? _____

Were the containers packaged well? _____

Were any extra samples received (document below)? _____

Are samples within recommended holding times/temp? _____

and size of coolers received: _____

Shipping: COD Y/N _____

Cooler temp: 25.0

Delivery Method: _____

Waybill: _____

Received by: LC

Titration Calculation Table

Client: De Beers, Snap Lake
Location: Snap Lake
Source: Incinerator #1
Date: July 11-13/14
Parameter: SO_x

Normality = 0.009328
mg Factor = 32.02

Dilution Factor: 0

	Vol.	Aliquot	Titration	mg as SO₂
Blank		10.00	0.05	
Samples				
Run 1	262.0	10.00	2.35	18.0
Run 2	385.0	10.00	3.90	44.3
Run 3	450.0	10.00	3.00	39.7

Titration Calculation Table

Client: De Beers, Snap Lake
Location: Snap Lake
Source: Incinerator #2
Date: July. 13-15/14
Parameter: SOx

Normality = 0.009328
mg Factor = 32.02

Dilution Factor: 0

	Vol.	Aliquot	Titration	mg as SO2
Blank		10.00	0.05	
Samples				
Run 1	400.0	10.00	4.70	55.6
Run 2	485.0	10.00	4.10	58.7
Run 3	385.0	10.00	2.20	24.7

APPENDIX 3
QA/QC RESULTS

SAMPLE RECEIPT FORM / CHEMICAL ANALYSIS FORM

FILE #: PR141627

CLIENT: A. Lanfranco & Associates Inc.
 #101 – 9488 189th Street
 Surrey, BC
 V4N 4W7

Phone: (604) 881-2582

Fax: (604) 881-2581

RECEIVED BY: P.A. Pond
 CONDITION: good, 10°C

DATE/TIME: July 17, 2014 (4:40 p.m.)

<u># of Containers</u>	<u>Sample Type</u>	<u>Sample (Client Codes)</u>	<u>Lab Codes</u>	<u>Test Requested</u>
Project: Snap Lake				
5	XAD, filter, rinses	BLANK July 11/14	PR141627	PCDD/F
5	XAD, filter, rinses	Run #1 – Incinerator #1 July 11/14	PR141628	PCDD/F
5	XAD, filter, rinses	Run #2 – Incinerator #1 July 12/14	PR141629	PCDD/F
5	XAD, filter, rinses	Run #3 – Incinerator #1 July 13/14	PR141630	PCDD/F
5	XAD, filter, rinses	Run #1 – Incinerator #2 July 13/14	PR141631	PCDD/F
5	XAD, filter, rinses	Run #2 – Incinerator #2 July 14/14	PR141632	PCDD/F
5	XAD, filter, rinses	Run #3 – Incinerator #2 July 15/14	PR141633	PCDD/F

STORAGE: XAD, filter stored at 4°C, rinses stored at ambient temperature.

ANALYTES: HRGC/HRMS analysis for polychlorinated dibenzo(p)dioxins and dibenzofurans (PCDD/F).

SPECIAL INSTRUCTIONS: none

METHODOLOGY


Reference Method: PCDD/F: SOP LAB01; EPA Method 23, Environment Canada 1-RM-3

Data summarized in Data Report Attached

Report sent to: Mark Lanfranco Date: August 18, 2014

Comments: Results relate only to items tested.

David Hope PChem, CEO



METHOD 23/1-RM-3 DATA REPORT

Client: A. Lanfranco & Associates
 Client ID: Snap Lake - Blank
 PRL ID: PR141627

Sample Date: 11-Jul-14
 Date Extracted: 29-Jul-14
 Date Analysed: 16-Aug-14
 Filter Wt.: 0.24 g

DIOXINS			
Congeners	pg	DL pg	# of peaks
2,3,7,8-TCDD	ND	2	
Total TCDD	ND	2	0
1,2,3,7,8-PeCDD	ND	4	
Total PeCDD	ND	4	0
1,2,3,4,7,8-HxCDD	ND	4	
1,2,3,6,7,8-HxCDD	ND	4	
1,2,3,7,8,9-HxCDD	ND	4	
Total HxCDD	ND	4	0
1,2,3,4,6,7,8-HpCDD	57	4	
Total HpCDD	64	4	2
OCDD	440	15	1
Total Dioxin TEQ			

I-TEQs		
(ND=0) pg	(ND=½DL) pg	(ND=DL) pg
ND	1	2
ND	1	2
ND	0.2	0.4
ND	0.2	0.4
ND	0.2	0.4
0.57	0.57	0.57
0.44	0.44	0.44
1.0	3.6	6.2

FURANS			
Congeners	pg	DL pg	# of peaks
2,3,7,8-TCDF	ND	2	
Total TCDF	ND	2	0
1,2,3,7,8-PeCDF	ND	4	
2,3,4,7,8-PeCDF	ND	4	
Total PeCDF	4.2	4	1
1,2,3,4,7,8-HxCDF	ND	4	
1,2,3,6,7,8-HxCDF	ND	4	
1,2,3,7,8,9-HxCDF	ND	4	
2,3,4,6,7,8-HxCDF	ND	4	
Total HxCDF	ND	4	0
1,2,3,4,6,7,8-HpCDF	24	4	
1,2,3,4,7,8,9-HpCDF	ND	4	
Total HpCDF	78	4	2
OCDF	68	15	1
Total Furan TEQ			

I-TEQs		
(ND=0) pg	(ND=½DL) pg	(ND=DL) pg
ND	0.1	0.2
ND	0.1	0.2
ND	1	2
ND	0.2	0.4
ND	0.2	0.4
ND	0.2	0.4
ND	0.2	0.4
0.24	0.24	0.24
ND	0.02	0.04
0.068	0.068	0.068
0.31	2.3	4.3

Total PCDD/PCDF Toxic Equivalent (pg)

1.3 5.9 11

Surrogate Recoveries (%)


³⁷ Cl ₄ -2,3,7,8-TCDD	102
¹³ C ₁₂ -2,3,4,7,8-PeCDF	90
¹³ C ₁₂ -1,2,3,4,7,8-HxCDD	88
¹³ C ₁₂ -1,2,3,4,7,8-HxCDF	84
¹³ C ₁₂ -1,2,3,4,7,8,9-HpCDF	73

ND - none detected

Internal Standards (%)

¹³ C ₁₂ -2,3,7,8-TCDD	70
¹³ C ₁₂ -1,2,3,7,8-PeCDD	82
¹³ C ₁₂ -1,2,3,6,7,8-HxCDD	42
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDD	49
¹³ C ₁₂ -OCDD	52
¹³ C ₁₂ -2,3,7,8-TCDF	50
¹³ C ₁₂ -1,2,3,7,8-PeCDF	76
¹³ C ₁₂ -1,2,3,6,7,8-HxCDF	41
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDF	43

Patrick Pond
 Patrick Pond CTO 19/08/14



QC REPORT - BLANK

Client: A. Lanfranco & Associates
 Client ID: BLANK
 PRL ID: DF140408B

Contact: Mark Lanfranco
 Date Extracted: 29-Jul-14
 Date Analysed: 16-Aug-14

DIOXINS			
Congeners	pg	DL pg	# of peaks
2,3,7,8-TCDD	ND	2	
Total TCDD	ND	2	0
1,2,3,7,8-PeCDD	ND	4	
Total PeCDD	ND	4	0
1,2,3,4,7,8-HxCDD	ND	4	
1,2,3,6,7,8-HxCDD	ND	4	
1,2,3,7,8,9-HxCDD	ND	4	
Total HxCDD	ND	4	0
1,2,3,4,6,7,8-HpCDD	36	4	
Total HpCDD	63	4	2
OCDD	310	15	1
Total Dioxin TEQ			

I-TEQs		
(ND=0) pg	(ND=½DL) pg	(ND=DL) pg
ND	1	2
ND	1	2
ND	0.2	0.4
ND	0.2	0.4
ND	0.2	0.4
0.36	0.36	0.36
0.31	0.31	0.31
0.67	3.3	5.9

FURANS			
Congeners	pg	DL pg	# of peaks
2,3,7,8-TCDF	ND	2	
Total TCDF	ND	2	0
1,2,3,7,8-PeCDF	ND	4	
2,3,4,7,8-PeCDF	ND	4	
Total PeCDF	ND	4	0
1,2,3,4,7,8-HxCDF	ND	4	
1,2,3,6,7,8-HxCDF	ND	4	
1,2,3,7,8,9-HxCDF	ND	4	
2,3,4,6,7,8-HxCDF	ND	4	
Total HxCDF	ND	4	0
1,2,3,4,6,7,8-HpCDF	8.3	4	
1,2,3,4,7,8,9-HpCDF	ND	4	
Total HpCDF	11	4	2
OCDF	22	15	1
Total Furan TEQ			

I-TEQs		
(ND=0) pg	(ND=½DL) pg	(ND=DL) pg
ND	0.1	0.2
ND	0.1	0.2
ND	1	2
ND	0.2	0.4
ND	0.2	0.4
ND	0.2	0.4
ND	0.2	0.4
0.083	0.083	0.083
ND	0.02	0.04
0.022	0.022	0.022
0.11	2.1	4.1


Total PCDD/PCDF Toxic Equivalent (pg)

0.78 5.4 10

- Internal Standards (%)**
- ¹³C₁₂-2,3,7,8-TCDD 68
 - ¹³C₁₂-1,2,3,7,8-PeCDD 87
 - ¹³C₁₂-1,2,3,6,7,8-HxCDD 82
 - ¹³C₁₂-1,2,3,4,6,7,8-HpCDD 81
 - ¹³C₁₂-OCDD 89
 - ¹³C₁₂-2,3,7,8-TCDF 54
 - ¹³C₁₂-1,2,3,7,8-PeCDF 75
 - ¹³C₁₂-1,2,3,6,7,8-HxCDF 83
 - ¹³C₁₂-1,2,3,4,6,7,8-HpCDF 78

ND - none detected

Patrick Pond
 Patrick Pond CTO



QC REPORT - SPIKE

Client: A. Lanfranco & Associates
 Client ID: MATRIX SPIKE
 PRL ID: DF140409S

Contact: Mark Lanfranco
 Date Extracted: 29-Jul-14
 Date Analysed: 16-Aug-14


DIOXINS Congeners	LOF pg	Recovery %	Acceptable Recovery		Pass/Fail
			Min %	Max %	
2,3,7,8-TCDD	200	111	80	120	Pass
1,2,3,7,8-PeCDD	1000	108	80	120	Pass
1,2,3,4,7,8-HxCDD	1000	104	80	120	Pass
1,2,3,6,7,8-HxCDD	1000	111	80	120	Pass
1,2,3,7,8,9-HxCDD	1000	100	80	120	Pass
1,2,3,4,6,7,8-HpCDD	1000	115	80	120	Pass
OCDD	2000	119	80	120	Pass


Int. Std Recoveries %
67
96
-
93
-
92
97

FURANS Congeners	LOF pg	Recovery %	Acceptable Recovery		Pass/Fail
			Min %	Max %	
2,3,7,8-TCDF	200	114	80	120	Pass
1,2,3,7,8-PeCDF	1000	112	80	120	Pass
2,3,4,7,8-PeCDF	1000	100	80	120	Pass
1,2,3,4,7,8-HxCDF	1000	101	80	120	Pass
1,2,3,6,7,8-HxCDF	1000	112	80	120	Pass
1,2,3,7,8,9-HxCDF	1000	82	80	120	Pass
2,3,4,6,7,8-HxCDF	1000	102	80	120	Pass
1,2,3,4,6,7,8-HpCDF	1000	115	80	120	Pass
1,2,3,4,7,8,9-HpCDF	1000	81	80	120	Pass
OCDF	2000	82	80	120	Pass

Int. Std Recoveries %
52
81
-
-
91
-
-
82
-
-

LOF - Level of Fortification


 Patrick Pond CTO



Acronyms used in reporting dioxins and furans:

TCDD = Tetrachlorodibenzo-*p*-dioxin
 PeCDD = Pentachlorodibenzo-*p*-dioxin
 HxCDD = Hexachlorodibenzo-*p*-dioxin
 HpCDD = Heptachlorodibenzo-*p*-dioxin
 OCDD = Octachlorodibenzo-*p*-dioxin

TCDF = Tetrachlorodibenzofuran
 PeCDF = Pentachlorodibenzofuran
 HxCDF = Hexachlorodibenzofuran
 HpCDF = Heptachlorodibenzofuran
 OCDF = Octachlorodibenzofuran

	EPA Method 23	
	Min (%)	Max (%)
³⁷ Cl ₄ -2,3,7,8-TCDD	70	130
¹³ C ₁₂ -2,3,4,7,8-PeCDF	70	130
¹³ C ₁₂ -1,2,3,4,7,8-HxCDD	70	130
¹³ C ₁₂ -1,2,3,4,7,8-HxCDF	70	130
¹³ C ₁₂ -1,2,3,4,7,8,9-HpCDF	70	130

Acceptable recoveries for Internal Standards

	EPA Method 23		Env. Can. 1-RM-3	
	Min (%)	Max (%)	Min (%)	Max (%)
¹³ C ₁₂ -2,3,7,8-TCDD	40	130	40	130
¹³ C ₁₂ -1,2,3,7,8-PeCDD	40	130	40	130
¹³ C ₁₂ -1,2,3,6,7,8-HxCDD	40	130	40	130
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDD	25	130	40	130
¹³ C ₁₂ -OCDD	25	130	40	130
¹³ C ₁₂ -2,3,7,8-TCDF	40	130	40	130
¹³ C ₁₂ -1,2,3,7,8-PeCDF	40	130		
¹³ C ₁₂ -1,2,3,6,7,8-HxCDF	40	130		
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDF	25	130		



Quality Control

Bill To: A. Lanfranco & Associates
 Report To: A. Lanfranco & Associates
 #101, 9488 - 189 Street
 Surrey, BC, Canada
 V4N 4W7
 Attn: Al LanFranco
 Sampled By:
 Company:

Project:
 ID:
 Name: Debeers
 Location: Snaplake, YT
 LSD:
 P.O.:
 Acct code:

Lot ID: **1017066**
 Control Number: B202062
 Date Received: Jul 28, 2014
 Date Reported: Aug 18, 2014
 Report Number: 1936220

Mercury by CVAA

Blanks	Units	Measured	Lower Limit	Upper Limit	Passed QC	
Mercury	ug/L	0	-0.051	0.051	yes	
Date Acquired: August 05, 2014						
Certified Reference Material	Units	Measured	Target	Lower Limit	Upper Limit	Passed QC
Mercury	ug/L	6.88	6.881	4.361	9.401	yes
Date Acquired: August 05, 2014						
Mercury	ug/L	2.32	2.428	1.831	3.025	yes
Date Acquired: August 13, 2014						
Client Sample Replicates	Units	Replicate 1	Replicate 2	% RSD Criteria	Absolute Criteria	Passed QC
Mercury	ug/L	<0.050	<0.050	30	0.050	yes
Date Acquired: August 05, 2014						
Matrix Spike	Units	% Recovery	Lower Limit	Upper Limit	Passed QC	
Mercury	ug/L	103	85	115	yes	
Date Acquired: August 05, 2014						

APPENDIX 4
FIELD DATA SHEETS
and PROCESS DATA

cut

XAD 4-072
Bx XAD LF 067

10.74
- 10.91
* 10.48

1750

15.48ΔH
- 15.62
* 14.48

1800

10.80
15.28ΔH

PLANT	De Beers - Snap Lake	
RUN No	1 Dixon	
LOCATION	Incinerator #1	
DATE	July 11/14	
OPERATOR	C.L	
CONTROL UNIT/Y	STAGE 2 1.0101	
BAROMETRIC PRESSURE, IN. Hg	28.25	
ASSUMED MOISTURE, Bw	10%	
PROBE TIP DIAMETER, IN.	4Q-D 5.113	
PROBE LENGTH, FT/Cp	HT 4B 18463	
FILTER NUMBER		
STATIC PRESSURE, IN. H ₂ O	0.06	
STACK DIAMETER	16.0"	
STACK HEIGHT	25'	
INITIAL LEAK TEST	0.001015"	
FINAL LEAK TEST	0.001015"	

Point	Clock Time	Dry Gas Meter Ft ³	Pitot IN. H ₂ O ΔP	Orifice ΔH IN. H ₂ O	Dry Gas Temp.		Pump Vac. IN. Hg Gauge	Temperature of		Impinger Exit	Fyrites NOVA	
					Inlet of	Outlet of		Box	Stack		CO ₂ Vol. %	O ₂ Vol. %
1	1310	851.412	XAD	XAD	1.83	66	4	250	1750	50	12.0	3.5
1		855.14	45	45	1.83	67	4	250	1779	50	12.0	3.5
2		858.70	48	48	1.86	68	4	250	1780	50	12.0	3.5
2		862.42	48	48	1.86	68	4	250	1794	50	12.0	3.5
3		866.14	50	50	1.70	66	4	250	1797	50	12.0	3.5
3		869.71	50	50	1.85	66	4	250	1798	50	12.0	3.5
4		873.43	54	54	1.87	67	4	250	1830	54	12.0	3.0
4		877.21	54	54	1.87	68	4	250	1888	54	12.0	3.0
5		880.99	48	48	1.87	68	4	250	1900	54	12.0	3.0
5		884.78	48	48	1.87	68	4	250	1905	54	12.0	3.0
5		888.56	50	50	1.87	68	4	250	1910	54	12.0	3.0
6		892.35	50	50	1.87	68	4	250	1915	54	12.0	3.0
6		896.14	54	54	1.87	69	4	250	1920	54	12.0	3.0
7		899.76	54	54	1.87	68	4	250	1760	54	9.0	8.0
7		903.54	56	56	1.87	68	4	250	1735	54	9.0	8.0
8		907.16	56	56	1.87	69	5	250	1720	54	9.0	8.0
8		910.79	60	60	1.87	70	5	250	1717	54	9.0	8.0
9		914.42	58	58	1.87	70	6	250	1800	54	9.0	8.0
9		918.05	58	58	1.87	70	6	250	1770	55	9.0	8.0
10		921.67	54	54	1.87	71	6	250	1770	56	9.0	8.0
10		925.45	54	54	1.87	71	6	250	1766	56	9.0	8.0
11		929.23	48	48	1.87	71	6	250	1760	56	9.0	8.0
11		933.04	48	48	1.87	71	6	250	1750	56	9.0	8.0
12		936.79	52	52	1.87	71	6	250	1788	55	9.0	8.0
12		940.57	54	54	1.87	71	6	250	1788	55	9.0	8.0
1		944.31	54	54	1.83	71	7	250	1788	55	9.0	8.0
1		948.07	54	54	1.83	72	7	247	1740	54	9.0	8.0
2		951.83	54	54	1.83	72	7	256	1757	54	9.0	8.0
2		955.57	54	54	1.83	73	7	256	1788	54	9.0	8.0
3		959.15	54	54	1.83	73	7	256	1885	54	9.0	8.0
3		962.73	54	54	1.83	73	7	256	1885	54	9.0	8.0

* 50 min after primary ignition

C.L.
 e 1750 - 10.91 e 1800 - 10.80
 14.64 ΔH 15.62 ΔH

Point	Clock Time	Dry Gas Meter Ft ³	XAD	Pitot IN. H ₂ O ΔP	Orifice ΔH IN. H ₂ O	Dry Gas Temp.		Pump Vac. IN. Hg Gauge	Temperature of		Temperature of		Fyrites %		TOTAL GAIN (mL)
						Inlet of	Outlet of		Box	Probe	Impinger Exit	Stack	CO ₂ Vol. %	O ₂ Vol. %	
4	Continued	962.73	48	.12	1.87	73	73	8	252	270	52	1775			
4	16	976.29	48	.12	1.87	73	73	8	254	272	54	1876			
5		973.91	50	.11	1.72	73	73	10	257	270	56	1830			
5		977.19	50	.11	1.68	72	72	10	257	270	56	1775			
6		980.91	50	.10	1.55	71	71	10	252	270	58	1832			
6		981.33	52	.10	1.53	70	70	10	252	275	58	1821			88.0
7		987.57	52	.09	1.38	70	70	10	250	270	58	1800			
7		990.90	54	.095	1.46	70	70	10	250	270	58	1783			
8		994.14	54	.09	1.38	70	70	10	250	270	58	1780			
8	205	997.38	57	.09	1.38	70	70	10	250	275	58	1915			
9		1000.56	57	.09	1.32	70	70	10	260	270	60	1819			
9		1003.80	56	.10	1.38	70	70	10	260	270	60	1840			
10		1007.22	56	.11	1.53	70	70	10	262	272	57	1800			
10		1010.81	50	.11	1.60	70	70	10	262	272	57	1800			
11		1014.56	50	.12	1.83	70	70	12	262	272	57	1793			
11		1018.14	48	.11	1.68	70	70	12	262	275	58	1806			
12		1021.59	48	.10	1.53	70	70	12	262	275	58	1900			
12	17:20	1024.94	48	.10	1.46	70	70	12	262	275	58	1900			

Upstream Diameters
 Downstream Diameters
 Max. C.e

PLANT De Beers - Soap Lake
 RUN No 1
 LOCATION Oxo - Continued
 DATE July 11/14
 OPERATOR C.L.
 CONTROL UNIT / Y 110101

PROBE TIP DIAMETER, IN. 40-D 513
 PROBE LENGTH, FT / Cp HT 4B 8463
 FILTER NUMBER
 STATIC PRESSURE, IN. H₂O
 STACK DIAMETER 16"
 STACK HEIGHT 25'

INITIAL LEAK TEST 0 exp e 15"
 FINAL LEAK TEST 0.001 e 15"

BAROMETRIC PRESSURE, IN. Hg 28.25
 ASSUMED MOISTURE, Bw 10%

C.L.

XAD-LF 07A
 come
 1750 - 10.85
 1850 - 10.57
 1900 - 10.46
 15.63
 14.96 ΔH
 14.64
 11.56 17.5 ΔH
 1550

PLANT	SNAP LAKE - De Beers	
PROBE TIP DIAMETER, IN.	4.0 D 5.113	
PROBE LENGTH, FT / Cp	HT 4B : 8463	
FILTER NUMBER		
RUN No	2 Dixon	
LOCATION	INCINERATOR #1	
DATE	July 12/14	
OPERATOR	C.L	
CONTROL UNIT / Y	STICAF 2-1.0101	
IMPINGER VOLUMES	INITIAL (mL)	FINAL (mL)
Imp. # 1	0	372
Imp. # 2	100	136
Imp. # 3	0	2
Imp. # 4		
STATIC PRESSURE, IN. H ₂ O	0.06	
STACK DIAMETER	16.0"	
STACK HEIGHT	25'	

BAROMETRIC PRESSURE, IN. Hg	28.50
ASSUMED MOISTURE, Bw	10%
INITIAL LEAK TEST	0.001 e 15"
FINAL LEAK TEST	0.001 e 15"

Point	Clock Time	Dry Gas Meter Ft ³	Pitot IN. H ₂ O ΔP	Orifice ΔH IN. H ₂ O	Dry Gas Temp.		Pump Vac. IN. Hg Gauge	Temperature of		Impinger Exit	Temperature of Stack	Fyrites Nova		Dry CO
					Inlet of	Outlet of		Box	Probe			CO ₂ Vol. %	O ₂ Vol. %	
1	10:06	25.845	XAD	1.17	78	79	3	250	250	59	176	14.0	2.2	297-0
2		28.82	41	1.20	81	81	4	250	250	60	181	13.0	2.4	307-0
3		31.81	41	1.27	81	81	4	252	254	57	186	13.5	2.5	307-0
4		34.89	42	1.32	81	81	4	250	250	57	190	12.0	5.4	260-0
5		38.03	42	1.30	83	83	5	251	258	56	193	12.5	3.5	300-0
6		40.09	42	1.32	84	84	5	250	250	57	194	12.5	3.5	300-0
7		44.14	42	1.33	86	86	5	250	250	57	195	12.5	3.5	300-0
8		47.28	42	1.33	87	87	6	250	250	58	196	12.5	3.5	300-0
9		50.47	43	1.41	88	88	6	250	250	58	197	12.5	3.5	300-0
10		53.73	43	1.41	90	91	6	250	250	60	198	12.0	5.4	260-0
11		56.80	48	1.25	91	92	6	251	257	60	199	12.0	5.4	260-0
12		60.06	48	1.41	92	92	6	253	252	64	200	12.0	5.4	260-0
13		63.40	53	1.48	93	94	6	252	251	60	201	12.0	5.4	260-0
14		66.71	53	1.46	94	95	6	250	260	58	202	12.5	3.5	300-0
15		70.18	56	1.61	95	96	6	252	266	58	203	12.5	3.5	300-0
16		73.52	56	1.50	96	97	6	250	260	58	204	12.5	3.5	300-0
17		76.86	60	1.35	97	98	6	252	266	58	205	12.5	3.5	300-0
18		80.03	48	1.46	98	99	6	250	260	58	206	12.5	3.5	300-0
19		83.34	48	1.50	99	100	6	252	266	58	207	12.5	3.5	300-0
20		86.65	48	1.46	100	101	6	250	260	58	208	12.5	3.5	300-0
21		89.99	48	1.50	101	102	6	252	266	58	209	12.5	3.5	300-0
22		93.37	48	1.50	102	103	6	250	260	58	210	12.5	3.5	300-0
23		96.99	40	1.76	103	104	6	252	266	58	211	12.5	3.5	300-0
24		100.77	40	1.90	104	105	6	250	260	58	212	12.5	3.5	300-0
25		104.43	40	1.80	105	106	6	252	266	58	213	12.5	3.5	300-0
26		108.09	42	1.76	106	107	6	250	260	58	214	12.5	3.5	300-0
27		111.75	42	1.76	107	108	6	252	266	58	215	12.5	3.5	300-0
28		115.56	44	1.94	108	109	6	250	260	58	216	12.5	3.5	300-0
29		119.04	44	1.62	109	110	6	252	266	58	217	12.5	3.5	300-0
30		122.58	44	1.65	110	111	6	250	260	58	218	12.5	3.5	300-0
31		126.01	44	1.57	111	112	6	252	266	58	219	12.5	3.5	300-0

With Pyrite

* More "Dry" cardboard waste today * 903lb - waste
 * 40 min. after primary ignition

15.63
14.96
14.64
AH

17.90
18.50
19.00
19.50
20.00
20.50
21.00
21.50

10.85
10.57
10.46
10.56

PLANT	SNAP LAKE - DE BEERS	PROBE TIP DIAMETER, IN.	5.113	INITIAL	FINAL	TOTAL GAIN
RUN No	2	PROBE LENGTH, FT / Cp	8.463	(mL)	(mL)	(mL)
LOCATION	2 DRAIN CONTINUED	FILTER NUMBER				
DATE	JULY 12/14	STATIC PRESSURE, IN. H ₂ O				
OPERATOR	C-L	STACK DIAMETER	16.0"			
CONTROL UNIT / Y	1.0101	STACK HEIGHT	25'			

BAROMETRIC PRESSURE, IN. Hg	28.50
ASSUMED MOISTURE, BW	10%
INITIAL LEAK TEST	0.00 @ 15"
FINAL LEAK TEST	0.00 @ 18"

Point	Clock Time	Dry Gas Meter Ft ³	XAD	Pitot IN. H ₂ O ΔP	Orifice ΔH IN. H ₂ O	Dry Gas Temp.		Pump Vac. IN. Hg Gauge	Temperature of		Impinger Exit	Stack	Fyrites NOVA	
						Inlet of	Outlet of		Box	Probe			CO ₂ Vol. %	O ₂ Vol. %
4		126.01	46	.085	1.37	98	98	15	287	260	57	1805	8.0	9.4
4	16	129.09	46	.09	1.35	98	98	15	256	253	58	1835	8.0	9.4
5		132.26	48	.09	1.35	97	96	15	256	253	58	1860	8.0	9.5
5		135.43	46	.09	1.42	96	97	15	253	250	58	1850	8.0	9.5
6		138.60	46	.095	1.50	98	98	15	252	250	60	1823	8.0	9.6
6		141.86	46	.10	1.50	98	98	15	252	250	60	1809	8.0	9.6
7		145.50	46	.10	1.50	98	98	15	252	250	60	1850	9.5	9.9
7		148.87	48	.10	1.50	98	98	15	253	250	62	1880	7.0	9.8
8		152.21	50	.105	1.57	99	99	15	251	250	60	1836	8.5	6.3
8		155.55	44	.105	1.57	99	99	15	251	250	58	1820	8.5	6.3
9		158.89	42	.095	1.42	100	100	15	251	250	59	1808	8.5	6.3
9		162.32	42	.095	1.50	100	100	15	252	250	59	1900	8.5	6.3
9		165.75	42	.10	1.50	100	100	15	252	250	59	1827	8.5	6.3
10		169.01	42	.10	1.50	100	100	15	251	250	59	1807	8.5	6.3
10		172.37	42	.10	1.50	100	100	15	251	250	59	1807	8.5	6.3
11		175.71	42	.09	1.35	100	100	16	252	250	59	1807	8.5	6.3
11		178.88	42	.095	1.39	100	100	17	252	250	59	1807	8.5	6.3
12		182.10	42	.10	1.50	100	100	18	252	250	59	1807	8.5	6.3
12	14:20	185.44	42	.10	1.50	100	100	18	252	250	59	1807	8.5	6.3

MAX CO
100-0
99-0
97-0
100-0
104-0
155-0

XAD # LF 065

ek

PLANT		Snap Lake - De Beers		PROBE TIP DIAMETER, IN.		4.0-0.5113		IMPINGER		INITIAL		FINAL		TOTAL GAIN									
RUN No		3 Dioxin-		PROBE LENGTH, FT / Cp		14T 4B, 846B		VOLUMES		(mL)		(mL)		(mL)									
LOCATION		#1 Incinerator		FILTER NUMBER				Imp. # 1		0		388		388									
DATE		July 13/14		STATIC PRESSURE, IN. H ₂ O		0.06		Imp. # 2		100		136		36									
OPERATOR		C.L.		STACK DIAMETER		16.0"		Imp. # 3		0													
CONTROL UNIT / CASE		L10101		STACK HEIGHT		25'		Imp. # 4															
BAROMETRIC PRESSURE, IN. Hg		28.66		INITIAL LEAK TEST		0.010 @ 15"		Leak check #1		Leak check #2													
ASSUMED MOISTURE, Bw		12%		FINAL LEAK TEST		0.008 @ 15"		0.008 @ 15"		0.004 @ 15"													
Clock Time		Dry Gas Meter Ft ³		Orifice ΔH IN. H ₂ O		Dry Gas Temp. Inlet of		Pump Vac. IN. Hg Gauge		Temperature of Box		Temperature of Probe		Temperature of Impinger Exit		Stack		CO ₂ Vol. %		Fyrites Vol. %		O ₂ Vol. %	
Point				Pitot IN. H ₂ O ΔP	XAD																		
1	14:50	350.789	XAD	.11	42	1.66	80	5	241	251	60	1837	14.0	1.6	395-0								
1		354.87		.115		1.74	81	5				1850											
2		357.89		.115	44	1.70	82	6	245	255	58	1852											
2		361.49		.11		1.63	83	6				1902											
3		364.98		.10	46	1.45	84	10	245	275	60	1960	14.0	1.4	351-0								
3		368.31		.095		1.38	85	12				1974											
3		371.57		.09	48	1.31	86	14	250	263	60	1900											
4		374.74		.09		1.27	87	16				1988	7.0	10.8	307-0								
4		378.20		.10	50	1.48	88	15	243	265	62	1845											
5		381.57		.10		1.48	89	15				1860											
5		384.95		.10	52	1.52	90	15	253	267	62	1800											
6		388.39		.11		1.67	91	15				1789	8.0	8.9	77-0								
6		391.97		.105	52	1.62	92	16	255	270	60	1754											
7		395.51		.10		1.55	93	16				1750											
7		398.96		.11	49	1.67	94	17	262	275	60	1820	8.0	9.3	85-0								
8		402.54		.11		1.67	95	18				1781											
8		406.13		.10	49	1.52	96	18	248	270	60	1791											
9		409.55		.095		1.44	97	10				1793											
9		412.89		.09	50	1.36	98	10	243	273	58	1780	12.0	6.5	129-0								
10		416.13		.09		1.33	99	12				1870											
10		419.37		.09	52	1.39	100	12	246	270	60	1775	9.0	7.7	96-0								
11		422.61		.085		1.31	101	12				1750											
11		425.77		.085	50	1.29	102	12	248	275	60	1795											
12		428.92		.085		1.36	103	12				1800											
12		432.16		.09		1.36	104	13															
1		435.40		.09	54	1.36	105	13	250	275	62	1794	8.0	9.3	96-0								
1		438.63		.09		1.36	106	13				1780											
2		441.88		.09	54	1.36	107	13	250	275	60	1800											
2		445.14		.09		1.36	108	13				1800											
3		448.29		.09	51	1.29	109	14	247	268	58	1793	8.0	9.5	100-0								
3		451.36		.085		1.23	110	14				1890											

* 20 min after primary ignition

100 LB of waste

EA

PLANT	Snap Lake - De Beers	PROBE TIP DIAMETER, IN.	5.13	IMPINGER	INITIAL	FINAL	TOTAL GAIN
		PROBE LENGTH, FT / Cp	8.463	VOLUMES	(mL)	(mL)	(mL)
RUN No	3 Oxin - Continued	FILTER NUMBER		Imp. # 1	0		
LOCATION	Incrementator #1			Imp. # 2	100		
DATE	July 13/14	STATIC PRESSURE, IN. H ₂ O		Imp. # 3	0		
OPERATOR	C.L	STACK DIAMETER	16.0'	Imp. # 4			
CONTROL UNIT / Y	1.0101	STACK HEIGHT	25'				
BAROMETRIC PRESSURE, IN. Hg		28.66		Upstream Diameters			
ASSUMED MOISTURE, Bw		12.2		Downstream Diameters			

Point	Clock Time	Dry Gas Meter Ft ³	Pilot IN. H ₂ O ΔP	Orifice ΔH IN. H ₂ O	Dry Gas Temp.		Pump Vac. IN. Hg Gauge	Temperature of		Impinger Exit	Stack	CO ₂ Vol. %	Fyrites %	O ₂ Vol. %	NOx-C
					Inlet of	Outlet of		Box	Probe						
4	Continued	451.36	X40	1.36	79	80	14	255	270	58	789	8.0	9.8	86.0	
4	↓	457.88	51	1.36	80	80	14	250	271	58	870				
5		461.30	52	1.52	80	81	15	254	274	60	890				
5		464.72	54	1.52	80	80	15	246	275	62	886	8.5	8.1	106.0	
6		467.96	54	1.36	79	80	16	253	270	62	860	8.0	8.5	166.0	
6		471.17	56	1.36	80	80	16	248	270	60	875	7.0	10.0	95.0	
7		474.38	50	1.36	79	80	16	244	272	58	803	8.0	10.1	99.0	
7		477.63	48	1.36	79	78	17	252	268	56	808	8.0	9.4	90.2	
8		480.89	48	1.36	78	78	18	251	272	58	793				
8		484.13	50	1.44	78	78	18				800				
9		487.39	44	1.52	79	78	18				816				
9		490.54	44	1.36	78	77	18				850				
10		493.78	44	1.36	77	75	18				810				
10		497.11	44	1.36	75		18				798				
11		500.53													
11		503.74													
12		506.98													
12	19:55	510.22													

2

PLANT	DeBeers - Snap Lake	PROBE TIP DIAMETER, IN.	0.5623	IMPINGER	INITIAL	FINAL	TOTAL GAIN
RUN No	Metals/Partic Run 1	PROBE LENGTH, FT/Cp	HT 4a/0.8457	VOLUMES	(mL)	(mL)	(mL)
LOCATION	Incinerator 1	FILTER NUMBER		Imp. # 1	100	253	153
DATE	July 11, 2014	STATIC PRESSURE, IN. H ₂ O	+0.06	Imp. # 2	100	155	55
OPERATOR	ZA	STACK DIAMETER	16"	Imp. # 3	-	46	46
CONTROL UNIT	Y APEX 522/0.9950	STACK HEIGHT	25'	Imp. # 4	100	118	18
					0e1	100	0
BAROMETRIC PRESSURE, IN. Hg	28.25	INITIAL LEAK TEST	0.00 @ 15"	Upstream Diameters			
ASSUMED MOISTURE, Bw	10%	FINAL LEAK TEST	0.00 @ 15"	Downstream Diameters			

Point	Clock Time	Dry Gas Meter, Ft ³	NOx (ppm)	Pitot IN. H ₂ O ΔP	Orifice ΔH IN. H ₂ O	Dry Gas Temp.		Pump Vac. IN. Hg Gauge	Temperature of		Impinger Exit	Stack	Fyrites	
						Inlet of	Outlet of		Box	Probe			CO ₂ Vol. %	O ₂ Vol. %
1	13:50	443.035	177	0.11	2.39	60	248	4	256	1861	50	1875	12.5	3.2
2		447.24		0.12	2.51	60	245	4	250	1875	52	1890	12.5	3.0
3		451.62	176	0.12	2.48	60	248	4	257	1905	53	1924	9.0	7.6
4		455.97	68	0.12	2.26	61	247	4	255	1905	53	1924	9.5	6.2
5		460.13	68	0.12	2.48	61	247	4	256	1729	54	1729	10.5	6.6
6		464.46	68	0.12	2.51	62	247	4	257	1826	52	1890	12.5	3.0
7		468.85	68	0.11	2.48	62	246	4	257	1890	52	1890	12.5	3.0
8		473.21	68	0.11	2.46	63	248	5	250	1729	52	1729	12.5	3.0
9		477.54	68	0.105	2.35	63	249	5	253	1826	52	1826	12.5	3.0
10		481.76	93	0.11	2.47	63	247	5	254	1890	52	1890	12.5	3.0
11		486.09	93	0.11	2.47	62	248	5	256	1890	52	1890	12.5	3.0
12		490.37	291	0.105	2.36	62	247	5	254	1890	52	1890	12.5	3.0
1		494.46	291	0.105	2.19	62	248	5	254	1890	52	1890	12.5	3.0
1		498.71	98	0.11	2.35	63	249	5	256	1890	52	1890	12.5	3.0
2		503.04	72	0.11	2.41	63	248	5	256	1780	51	1780	9.0	7.2
3		507.38	278	0.12	2.44	64	247	6	257	1754	51	1754	12.5	3.0
4		511.91	173	0.11	2.66	65	247	6	257	1762	51	1762	12.5	3.0
5		516.25	253	0.11	2.44	66	246	6	258	1745	50	1745	12.5	3.0
6		520.61	276	0.12	2.51	64	245	6	257	1888	50	1888	12.5	3.0
7		525.00	173	0.12	2.61	65	247	6	254	1890	50	1890	12.5	3.0
8		529.46	253	0.12	2.42	65	248	6	255	1907	50	1907	12.5	3.0
9		533.78	253	0.12	2.50	65	250	6	256	1845	52	1845	12.5	3.0
10		538.13	276	0.11	2.35	65	251	6	257	1889	52	1889	12.5	3.0
11		542.41	276	0.11	2.35	65	249	6	256	1889	52	1889	12.5	3.0
12	16:00	546.53	276	0.105	2.20	65	249	6	256	1889	52	1889	12.5	3.0

Primary Ignition @ 12:10 P/M Metals @ 13:50 → Primary T=662°C Secondary T=1109°C

2

PLANT	DeBeers Snap Lake	
RUN No	2 - Partic/Metals	
LOCATION	Incinerator 1	
DATE	July 12, 2014	
OPERATOR	KA	
CONTROL UNIT / Y	Apex 522 / 09950	
BAROMETRIC PRESSURE, IN. Hg	28.50	
ASSUMED MOISTURE, Bw	12%	
PROBE TIP DIAMETER, IN.	0.5623	
PROBE LENGTH, FT / Cp	HT 4a / 0.8457	
FILTER NUMBER		
STATIC PRESSURE, IN. H ₂ O	16"	
STACK DIAMETER	25"	
STACK HEIGHT	15'	
INITIAL LEAK TEST	0.001 @ 15"	
FINAL LEAK TEST	0.001 @ 15"	

Point	Clock Time	Dry Gas Meter Ft ³	N(x) (ppm)	Pitot IN. H ₂ O ΔP	Orifice ΔH IN. H ₂ O	Dry Gas Temp.		Pump Vac. IN. Hg Gauge	Temperature of		Impinger Exit	Stack Temperature of	Fyrites	
						Inlet of	Outlet of		Box	Probe			CO ₂ Vol. %	O ₂ Vol. %
1	10:26	562.667	307	0.11	2.23	66	247	2	253	54	1927	13.0	2.4	
2		566.82	307	0.12	2.41	65	246	3	254	54	1944	13.5	2.5	
3		571.10	304	0.115	2.30	66	245	4	250	54	1960	9.0	8.0	
4		575.31	77	0.12	2.19	67	246	5	250	55	1976	10.0	8.6	
5		579.46	96	0.12	2.78	69	247	6	257	55	1756	13.0	2.5	
6		584.11	301	0.12	2.65	71	248	7	258	55	1750	8.0	9.4	
7		588.62	301	0.115	2.55	71	246	8	257	55	1805	13.0	2.5	
8		593.08	100	0.105	2.31	73	247	2	256	53	1906	8.0	9.4	
9	Filter Change	601.65	100	0.11	2.28	73	248	2	257	53	1806	8.0	9.4	
10		605.72	100	0.10	2.10	78	246	2	256	53	1806	8.0	9.4	
11		609.67	100	0.09	1.97	79	246	2	256	53	1806	8.0	9.4	
12	12:45	612.95	100	0.11	2.33	75	246	3	257	54	1803	8.0	9.5	
1	13:05	618.09	99	0.10	2.18	76	248	3	256	54	1837	8.0	9.5	
2		620.03	97	0.09	1.93	75	249	3	258	53	1803	8.0	9.6	
3		625.69	100	0.08	1.60	76	250	3.5	257	55	1835	9.5	9.9	
4		629.79	106	0.10	2.11	77	247	3.5	256	54	1847	9.5	9.9	
5		634.10	106	0.11	2.37	78	247	3.0	257	54	1809	9.5	9.9	
6		638.20	104	0.10	2.15	79	246	3.0	256	54	1806	9.5	9.9	
7		642.12	104	0.09	1.97	79	247	3.0	257	54	1803	9.5	9.9	
8		645.81	106	0.08	1.75	79	246	3.0	256	54	1806	9.5	9.9	
9		649.65	106	0.085	1.86	79	247	3.0	257	54	1803	9.5	9.9	
10		653.32	106	0.080	1.69	80	246	3.0	258	55	1806	9.5	9.9	
11		657.04	106	0.080	1.75	80	247	3.0	259	55	1815	9.5	9.9	
12	14:05	660.66	106	0.075	1.65	81	246	3.0	259	55	1805	9.5	9.9	

CO ppm 0 0 0 0 0 0 0 0 0 0 0 0

Primary Ignition @ 0926 ppm Metals @ 1026

Load: 903 lbs

Primary: 610°C Secondary: 115°C

ed

PLANT DeBeers Snap Lake

RUN No 3 - P/Y Metals

LOCATION Incinerator 1

DATE July 13 2014

OPERATOR LR

CONTROL UNIT/Y Apex 522 / 0.9980

PROBE TIP DIAMETER, IN. 0.5623

PROBE LENGTH, FT / Op 41 4a / 0.2457

FILTER NUMBER

STATIC PRESSURE, IN. H₂O

STACK DIAMETER 16"

STACK HEIGHT 25'

BAROMETRIC PRESSURE, IN. Hg 28.66

ASSUMED MOISTURE, Bw 13%

INITIAL LEAK TEST 0.001@17"

FINAL LEAK TEST 0.001@18"

Point	Clock Time	Dry Gas Meter Ft ³	Pilot IN. H ₂ O ΔP	Orifice ΔH IN. H ₂ O	Dry Gas Temp.		Pump Vac. IN. Hg Gauge	Temperature of		Impinger Exit	Stack Temperature of	Fyrites	
					Inlet of	Outlet of		Box	Probe			CO ₂ Vol. %	O ₂ Vol. %
1	14:50	761.747	0.11	2.36	81	81	3	247	258	55	1819	14	1.6
2		766.07	0.10	2.13	81	82	4	246	257	55	1834	14	1.6
3		770.16	0.11	2.10	82	83	5	246	257	54	1876	14	1.4
4		774.20	0.10	2.28	83	83	8	245	257	54	1909	7.0	10.8
5		778.41	0.11	2.04	83	84	9	244	257	54	1946	6.0	11.2
6		782.39	0.12	2.23	84	85	10	246	258	54	1966	14	1.7
7		786.55	0.11	2.93	84	85	11	246	258	54	1980	8	10.2
8		791.33	0.12	2.80	85	84	12	246	257	54	1980	8	10.2
9		796.23	0.10	2.25	84	84	12	247	256	54	1980	14	1.7
10		800.27	0.10	2.15	84	84	12	246	255	54	1980	8	10.2
11		804.37	0.09	1.85	84	85	12	245	254	54	1980	8	10.2
12		808.19	0.09	1.90	85	85	12	246	255	54	1868	9	7.6
1	16:08	812.07	0.11	2.40	84	84	17	247	256	53	1796	9	7.7
2		817.05	0.11	2.43	83	83	19	248	251	54	1763	9	7.5
3		821.87	0.10	2.10	84	84	4	248	252	55	1734	8.0	9.0
4		825.94	0.105	2.31	84	84	4	246	255	55	1760	8.0	9.3
5		830.20	0.11	2.45	84	84	4	247	253	54	1745	8.0	7.5
6		834.59	0.12	2.68	84	84	4	247	254	54	1734	8.0	9.0
7		839.15	0.11	2.32	83	83	5	247	255	55	1760	8.0	9.3
8		843.42	0.10	2.21	83	83	5	248	254	55	1760	8.0	7.5
9		847.28	0.10	2.14	83	83	6	248	254	55	1760	8.0	9.0
10		851.39	0.095	2.10	83	83	6	248	254	55	1760	8.0	9.3
11		855.47	0.09	2.06	83	83	6	247	255	55	1743	8.0	7.5
12	17:13	859.44	0.09	1.86	82	82	6	246	255	55	1745	8.0	7.5

Primary Ignition @ 1430 Test Start @ 1450 Primary T = 302°C Secondary = 981°C Load: 1000 lbs

14C
0.001
14C
0.001

ATV-47-06D

primary ignition 8:13

Point	Clock Time	Dry Gas Meter Ft ³	XAD	Pitot IN. H ₂ O ΔP	Orifice ΔH IN. H ₂ O	Dry Gas Temp.		Pump Vac. IN. Hg Gauge	Temperature of		Impinger Exit	Stack Temperature of	Fyrites Analysis	
						Inlet of	Outlet of		Box	Probe			CO ₂ Vol. %	O ₂ Vol. %
PLANT Soap Lake - Dr. Beers														
PROBE TIP DIAMETER, IN. 4.0 D. 5.113														
PROBE LENGTH, FT / Cp HT 48, 8463														
FILTER NUMBER														
RUN No 1 Dixon														
LOCATION Incinerator #2														
DATE July 13/14														
OPERATOR C.L														
CONTROL UNIT / Y CAE 21001														
BAROMETRIC PRESSURE, IN. Hg 28.66														
ASSUMED MOISTURE, Bw 10%														
INITIAL LEAK TEST 0.001 @ 15"														
FINAL LEAK TEST 0.001 @ 15"														
Upstream Diameters														
Downstream Diameters														
1	09:33	186.413	46	.11	1.78	63	250	7	250	58	160	16.0	1.5	320
2		190.06	46	.105	1.70	64	250	8	250	59	167	15.0	1.5	320
3		193.62	52	.10	1.62	67	253	8	253	60	168	15.0	1.5	340
4		197.10	51	.11	1.56	70	254	8	254	60	175	14.5	1.5	340
5		200.54	58	.12	1.73	71	249	10	249	64	176	14.5	1.5	345
6		204.15	58	.12	1.73	72	242	10	242	60	177	14.5	1.5	345
7		207.76	48	.11	1.77	75	242	11	242	59	178	14.5	2.0	361
8		211.41	52	.10	1.89	77	256	10	256	58	180	14.0	2.3	345
9		215.15	56	.10	1.81	79	244	10	244	60	185	14.0	2.5	335
10		218.87	58	.10	1.85	80	250	12	250	64	188	8.5	9.3	48
11		222.59	58	.09	1.77	80	245	12	245	62	190	12.5	3.0	343
12		226.27	50	.10	1.63	81	250	14	250	60	191	8.0	9.5	71
1		229.78	54	.10	1.48	81	248	14	248	60	193	11.5	5.5	244
2		233.12	56	.10	1.48	82	248	14	248	62	195	9.0	8.5	100
3		236.30	58	.10	1.33	83	250	14	250	62	198	9.0	8.5	100
4		239.47	58	.10	1.33	83	250	14	250	62	198	9.0	8.5	100
5		242.81	52	.10	1.48	83	250	14	250	62	198	9.0	8.5	100
6		246.18	56	.10	1.51	83	250	14	250	62	198	9.0	8.5	100
7		249.59	58	.10	1.54	83	250	14	250	62	198	9.0	8.5	100
8		253.13	58	.10	1.66	83	250	14	250	62	198	9.0	8.5	100
9		256.47	58	.10	1.48	83	250	14	250	62	198	9.0	8.5	100
10		259.83	50	.10	1.48	83	250	14	250	62	198	9.0	8.5	100
11		263.17	50	.10	1.48	83	250	14	250	62	198	9.0	8.5	100
12		266.58	50	.10	1.54	83	250	14	250	62	198	9.0	8.5	100
1		269.92	54	.10	1.48	83	250	14	250	62	198	9.0	8.5	100
2		273.29	54	.110	1.51	83	250	14	250	62	198	9.0	8.5	100
3		276.66	56	.110	1.51	83	250	14	250	62	198	9.0	8.5	100
4		280.09	56	.110	1.54	83	250	14	250	62	198	9.0	8.5	100
5		283.50	58	.10	1.54	83	250	14	250	62	198	9.0	8.5	100
6		286.73	58	.09	1.39	83	250	14	250	62	198	9.0	8.5	100
7		289.99	58	.09	1.39	83	250	14	250	62	198	9.0	8.5	100

*20 min after primary ignition

2

Point	Clock Time	Dry Gas Meter Ft ³	XAD	Pitot IN. H ₂ O ΔP	Orifice ΔH IN. H ₂ O	Dry Gas Temp.		Pump Vac. IN. Hg Gauge	Temperature of		Impinger Exit	Stack Temperature of	CO ₂ Vol. %	Fyrites NOVA O ₂ Vol. %
						Inlet of	Outlet of		Box	Probe				
4	Continued	289.99	48	.10	1.48	82	82	12	253	250	60	1878	9.0	7.5
4	1 st	293.37	48	.10	1.48	83	83	12	249	247	59	1883		
5		296.71	50	.095	1.47	83	83	12	245	251	58	1808		
5		300.04	49	.09	1.36	82	82	12	250	250	60	1813		
6		303.27	52	.095	1.47	81	81	12	250	250	62	1805		
6		306.59	52	.10	1.51	80	80	13	250	250	60	1783		
7		309.93	56	.10	1.51	81	81	14	250	250	62	1800		
7		313.35	56	.10	1.51	82	82	14	250	250	64	1850		
8		316.77	54	.10	1.39	83	83	14	250	250	62	1817		
8	9 ⁰⁰	320.19	52	.09	1.31	84	84	14	250	250	60	1822		
9		323.60	52	.085	1.47	83	83	13	245	250	61	1880		
9		326.97	48	.090	1.39	84	84	13	245	250	61	1821		
9		330.39	48	.095	1.33	86	86	14						
10		333.62												
10		336.76												
10		340.09												
11		343.33												
11		346.50												
12	13:43	349.82												

188-0
188-0
108-0
93-0
178-0
135-0

PLANT Snap Lake - De Beers
 RUN No 1 Dixon - Continued
 LOCATION Incinerator #2
 DATE May 13/14
 OPERATOR Cal
 CONTROL UNIT / Y 110101
 PROBE TIP DIAMETER, IN. 4.00 5113
 PROBE LENGTH, FT / Cp HT 46 8463
 FILTER NUMBER
 STATIC PRESSURE, IN. H₂O 16.0"
 STACK DIAMETER 26"
 STACK HEIGHT
 INITIAL LEAK TEST 0.001 e 15"
 FINAL LEAK TEST 0.001 e 15"

Upstream Diameters
 Downstream Diameters

BAROMETRIC PRESSURE, IN. Hg 28.66
 ASSUMED MOISTURE, Bw 10%

XAD LF 069

16.36
11.20 e 1750
11.09 e 1800
10.48 e 1850
10.07 e 1900
11.04 e 1900
16.00
15.65 ΔH
15.32
18.45

CAE

ck

PLANT	Snap Lake - De Beers	PROBE TIP DIAMETER, IN.	4.42 C *	IMPINGER	INITIAL	FINAL	TOTAL GAIN
RUN No	2 Dixon	PROBE LENGTH, FT / Cp	HT 4B - 18463	VOLUMES	(mL)	(mL)	(mL)
LOCATION	Incinerator #2	FILTER NUMBER		Imp. # 1	0	425	425
DATE	July 14/14	STATIC PRESSURE, IN. H ₂ O	0.08	Imp. # 2	100	120	20
OPERATOR	C.L	STACK DIAMETER	16.0"	Imp. # 3	0		
CONTROL UNIT / Y / ST	CAE 2 1.0101	STACK HEIGHT	25'	Imp. # 4			

BAROMETRIC PRESSURE, IN. Hg	28.60	Leak Check #1	
ASSUMED MOISTURE, Bw	12%	Leak Check #2	
INITIAL LEAK TEST	0.005 e 15" / 0.002 e 15"	Downstream Diameters	1.75
FINAL LEAK TEST	0.005 e 18" / 0.002 e 18"	Temperature of	7.25

Point	Clock Time	Dry Gas Meter Ft ³	XAD	Pilot IN. H ₂ O ΔP	Orifice ΔH IN. H ₂ O	Dry Gas Temp. Inlet of	Dry Gas Temp. Outlet of	Pump Vac. IN. Hg Gauge	Temperature of		Impinger Exit	Stack	CO ₂ Vol. %	Fyrites Vol. %	O ₂ Vol. %
									Box	Probe					
1	13:30	511.462	XAD	0.08	1.48	250	253	5	250	253	60	1600	16.0	1.0	
2		514.84	52	0.08	1.48	246	253	5	246	253	62	1550	16.0	1.0	
3		518.22	52	0.08	1.31	253	260	5	253	260	60	1680	8.0	8.0	
4		521.89	56	0.09	1.38	249	274	5	249	274	62	1804	8.0	8.0	
5		524.56	58	0.09	1.44	250	270	5	250	270	64	1826	12.0	5.6	
6		527.82	50	0.085	1.36	250	275	5	250	275	64	1801	12.0	5.6	
7		531.15	52	0.09	1.41	252	270	5	252	270	64	1795	9.5	7.3	
8		534.44	52	0.09	1.41	248	265	5	248	265	62	1866	9.5	7.3	
9		537.77	54	0.09	1.41	252	270	5	252	270	64	1852	10.5	8.5	
10		541.10	54	0.09	1.46	251	272	7	251	272	65	1900	10.5	8.5	
11		544.33	58	0.09	1.38	252	275	7	252	275	66	1863	8.5	9.0	
12		547.62	60	0.095	1.46	251	270	7	251	270	64	1904	8.5	9.0	
13		550.91	52	0.09	1.38	252	275	7	252	275	66	1870	8.5	9.0	
14		554.20	52	0.09	1.46	251	270	7	251	270	64	1907	12.5	3.2	
15		557.58	52	0.09	1.46	250	275	7	250	275	62	1898	12.5	3.2	
16		560.93	52	0.09	1.38	252	270	7	252	270	62	1890	12.5	3.2	
17		564.19	52	0.09	1.38	255	275	7	255	275	62	1884	12.5	3.2	
18		567.47	54	0.09	1.46	255	275	7	255	275	62	1885	12.5	3.2	
19		570.73	54	0.09	1.46	255	275	7	255	275	62	1880	12.5	3.2	
20		573.99	56	0.10	1.57	252	275	7	252	275	62	1880	12.0	4.0	
21		577.24	52	0.10	1.53	252	275	7	252	275	62	1881	12.0	4.0	
22		580.69	52	0.10	1.53	252	275	7	252	275	62	1881	12.0	4.0	
23		584.05	52	0.10	1.57	252	275	7	252	275	62	1881	12.0	4.0	
24		587.31	52	0.10	1.57	252	275	7	252	275	62	1881	12.0	4.0	
25		590.59	52	0.10	1.53	252	275	7	252	275	62	1881	12.0	4.0	
26		593.94	54	0.095	1.46	255	275	7	255	275	62	1880	12.0	4.0	
27		597.41	56	0.10	1.57	252	275	7	252	275	62	1880	12.0	4.0	
28		600.86	52	0.10	1.53	252	275	7	252	275	62	1881	12.0	4.0	
29		604.29	52	0.10	1.53	252	275	7	252	275	62	1881	12.0	4.0	
30		607.77	52	0.10	1.57	252	275	7	252	275	62	1881	12.0	4.0	
31		611.21	52	0.10	1.53	252	275	7	252	275	62	1881	12.0	4.0	

Flow of waste * Primary ignition 19:50

* 46 min after primary ignition

NOX-CO
378 (200)
481 (200)
104 (144)
90 (0)
119 (0)
132 (8)
133 (8)
244 (7)
127 (0)

el

PLANT Snap Lake - De Beers

RUN NO 2 Diexin - continued

LOCATION JACINESCATA #2

DATE July H/14

OPERATOR CL

CONTROL UNIT / Y 10101

BAROMETRIC PRESSURE, IN. Hg 28.60

ASSUMED MOISTURE, Bw 2.3

PROBE TIP DIAMETER, IN. 5.183

PROBE LENGTH, FT / Cp HT 46.8463

FILTER NUMBER

STATIC PRESSURE, IN. H₂O 16.0"

STACK DIAMETER 25"

STACK HEIGHT

INITIAL LEAK TEST

FINAL LEAK TEST

Point	Clock Time	Dry Gas Meter Ft ³	XAD	Pitot IN. H ₂ O ΔP	Orifice ΔH IN. H ₂ O	Dry Gas Temp.		Pump Vac. IN. Hg Gauge	Temperature of		Impinger Exit	Temperature of Stack	Fyrites <small>Moist-A</small>	
						Inlet of	Outlet of		Box	Probe			CO ₂ Vol. %	O ₂ Vol. %
4	Continued	611.21	49	.10	1.57	91	91	9	257	275	62	1876	8.0	8.4
4		614.69		.105	1.61	91	91	9				1910		
5		618.21	48	.10	1.57	92	92	10	260	275	60	1871	9.0	8.0
5		621.68		.10	1.57	92	92	10				1876		
6		625.17	50	.10	1.53	93	93	10	256	272	58	1880	10.5	9.3
6		628.62		.095	1.46	93	93	10				1915		
7		631.97	52	.095	1.46	93	93	11	251	270	58	1881	8.0	8.0
7		635.32		.10	1.53	93	93	12				1880		
7		638.76	58	.10	1.53	93	93	12	253	275	60	1919	8.0	9.0
8		642.20		.105	1.61	94	94	12				1925		
8		645.63	52	.10	1.53	93	93	13	247	270	62	1890	8.0	8.7
8		649.17		.10	1.53	93	93	13				1898		
10		652.62	48	.10	1.46	93	93	13	251	275	62	1910	11.5	7.0
10		655.97		.095	1.38	93	93	14				1920		
11		659.23	50	.09	1.46	93	93	14	249	275	60	1920	8.0	9.0
11		662.58		.105	1.53	93	93	15				1910		
11		666.02	52	.10	1.53	93	93	15	250	272	58	1880	8.0	9.0
11		669.46		.10	1.53	93	93	15				1880		
12		672.90		.10	1.53	92	92	15						

NEX-Co 124.4 125.0 121.0 120.0 127.0 19.0 127.0

* XAD LF 066

cfm e
 175 11.27
 180 11.16
 185 10.85
 190 10.88
 195 10.94

16.36
 16.00
 15.65 ΔH
 15.32
 15.45

PLANT	Snag Lake - De Beers
RUN No	3 Diacin
LOCATION	Increrator #2
DATE	July 15/14
OPERATOR	C.L
CONTROL UNIT / ST CAFE	2 1.0101
BAROMETRIC PRESSURE, IN. Hg	28.30
ASSUMED MOISTURE, Bw	12%

PROBE TIP DIAMETER, IN.	40-C	5.83
PROBE LENGTH, FT / Cp	HT 46	8463
FILTER NUMBER		
STATIC PRESSURE, IN. H ₂ O	0.08	
STACK DIAMETER	16.0"	
STACK HEIGHT	25'	
INITIAL LEAK TEST	0.00 e 15"	
FINAL LEAK TEST	0.00 e 15"	

Point	Clock Time	Dry Gas Meter Ft ³	Pitot IN. H ₂ O ΔP	Orifice ΔH IN. H ₂ O	Dry Gas Temp.		Pump Vac. IN. Hg Gauge	Temperature of		Impinger Exit	Temperature of Stack	Fyrites MVA	
					Inlet of	Outlet of		Box	Probe			CO ₂ Vol. %	O ₂ Vol. %
1	09:35	673.210	XAD	42	0.09	1.44	71	285	254	54	1793	9.0	8.1
2		680.63		42	0.09	1.47	72		254	58	1775	15.0	3.5
3		684.12		43	0.10	1.57	73		250	58	1853		
4		687.65		44	0.09	1.44	74		251	60	1800		
5		690.99		44	0.09	1.41	74		249	56	1810		
6		694.31		48	0.10	1.60	74		251	58	1859		
7		697.84		48	0.10	1.60	74		251	58	1817		
8		701.37		48	0.10	1.60	75		251	56	1809		
9		704.90		48	0.10	1.60	76		251	58	1811		
10		708.37		48	0.10	1.57	77		251	58	1853		
11		711.87		52	0.10	1.57	77		251	60	1828		
12		715.38		52	0.10	1.57	78		251	60	1867		
13		718.88		56	0.10	1.57	78		250	62	1870		
14		722.37		56	0.095	1.49	79		252	62	1840		
15		725.78		60	0.09	1.41	80		252	64	1900		
16		729.10		60	0.095	1.49	80		252	64	1858		
17		732.51		50	0.095	1.46	80		249	60	1845		
18		735.88		45	0.09	1.38	80		252	58	1804		
19		739.20		45	0.095	1.48	80		252	58	1852		
20		742.52		45	0.095	1.48	80		252	58	1866		
21		745.87		45	0.095	1.48	80		252	58	1852		
22		749.19		45	0.10	1.53	80		252	58	1905		
23		752.60		45	0.105	1.61	80		252	58	1853		
24		756.01		44	0.105	1.64	80		252	58	1916		
25		759.45		44	0.11	1.69	80		250	60	1859		
26		762.91		44	0.11	1.72	80		250	60	1890		
27		766.51		45	0.105	1.61	80		250	60	1860		
28		770.10		45	0.105	1.64	80		250	60	1851		
29		773.71		44	0.105	1.69	80		250	60	1890		
30		777.39		44	0.11	1.72	80		250	60	1860		

* 8:35 Primary ignition * 500lb of waste * 60 min after primary ignition

2

PLANT	Snap Lake - De Beers	PROBE TIP DIAMETER, IN.	1.5183	IMPINGER	INITIAL	FINAL	TOTAL GAIN
RUN No	3 Dioxin - Continued	PROBE LENGTH, FT / Cp	8.463	VOLUMES	(mL)	(mL)	(mL)
LOCATION	Waste water #2	FILTER NUMBER		Imp. # 1			
DATE	July 15/14	STATIC PRESSURE, IN. H ₂ O	0.08	Imp. # 2			
OPERATOR	CL	STACK DIAMETER	16.0"	Imp. # 3			
CONTROL UNIT / CAE	2 1.001	STACK HEIGHT	25'	Imp. # 4			
BAROMETRIC PRESSURE, IN. Hg	28.30	INITIAL LEAK TEST					
ASSUMED MOISTURE, Bw	12%	FINAL LEAK TEST					

Point	Clock Time	Dry Gas Meter Ft ³	Pitot IN. H ₂ O ΔP	Orifice ΔH IN. H ₂ O	Dry Gas Temp.		Pump Vac. IN. Hg Gauge	Temperature of		Impinger Exit	Stack	Fyrites	
					Inlet of	Outlet of		Box	Probe			CO ₂ Vol. %	O ₂ Vol. %
4	Continued	777.39	X40	1.46	87	87	12	249	269	58	1885	9.0	9.2
4		780.94	43	1.57	88	88	12	250	270	60	1875		
4		784.23	43	1.41	88	88	12	249	270	58	1859		
5		787.55	46	1.33	87	87	12	249	272	58	1858		
6		790.87	48	1.41	88	88	12	253	275	60	1857		
6		794.09	50	1.30	88	88	12	251	270	60	1868		
6		797.41	51	1.41	88	88	12	250	272	60	1870		
6		800.58	53	1.33	88	88	12	247	270	62	1851		
6		803.90	56	1.25	87	87	12	249	275	62	1854		
6		807.22	58	1.25	87	87	12	249	275	62	1847		
6		810.54		1.33	87	87	12	249	275	62	1848		
6		813.67		1.25	87	87	12	250	275	64	1833		
6		816.89		1.33	87	87	12	250	275	64	1834		
6		820.02		1.25	87	87	12	250	275	64	1880		
6		823.15		1.33	87	87	12	250	275	64	1874		
6		826.37		1.25	87	87	12	250	275	64	1874		
6		829.59		1.33	87	87	12	250	275	64	1874		
6		832.79		1.25	87	87	12	250	275	64	1874		
6	13:45	835.97		1.30	88	88	12	250	275	64	1874		

Max. Co
124.0
123.0
122.0
118.0
119.0
106.0

CS

PLANT	Snap Lake DeBeers		PROBE TIP DIAMETER, IN.	0.3623	
RUN No	1 - PM/Metals		PROBE LENGTH, FT / Cp	HT 4x/0.8457	
LOCATION	Incinerator 2		FILTER NUMBER		
DATE	July 13, 2014		STATIC PRESSURE, IN. H ₂ O	50.08	
OPERATOR	JLA		STACK DIAMETER	16"	
CONTROL UNIT	Apex 522/0.9950		STACK HEIGHT	25'	
	ΔH @ = 1.8690		INITIAL LEAK TEST	0.001 @ 15"	
BAROMETRIC PRESSURE, IN. Hg	28.66		FINAL LEAK TEST	0.001 @ 15"	
ASSUMED MOISTURE, Bw	11%		Upstream Diameters		

Point	Clock Time	Dry Gas Meter Ft ³	NOx ppm	Pitot IN. H ₂ O ΔP	Orifice ΔH IN. H ₂ O	Dry Gas Temp.		Pump Vac. IN. Hg Gauge	Temperature of		Impinger Exit	Stack	Fyrites	
						Inlet (2-470)	Outlet of		Box	Probe			CO ₂ Vol. %	O ₂ Vol. %
1	0933	661.255		0.10	2.31	45	63	5	246	286	53	1687	15	1.5
2		665.47	322	0.11	2.52	45	63	6	245	257	53	1675	15	1.5
3		669.85		0.115	2.60	45	63	6	245	258	53	1702	15	1.5
4		674.30	341	0.11	2.47	45	64	7	246	257	53	1724	15	1.5
5		678.64		0.10	2.21	45	65	7	246	257	53	1755	15	1.5
6		682.26	345	0.10	2.22	45	66	8	247	258	53	1756	14.5	1.5
7		686.90		0.10	2.17	45	67	8	246	257	54	1804	14.0	2.3
8		691.00	343	0.105	2.27	45	67	9	245	257	54	1816	14.0	2.2
9		695.16		0.10	2.15	45	67	9	244	256	54	1823	14.5	2.0
10		699.21	347	0.10	2.13	45	68	10	245	256	54	1856	14.0	2.2
11		703.25		0.10	1.90	45	69	10.5	247	257	54	1878	14.5	2.0
12		707.10	361	0.09	1.88	45	69	11	245	258	54	1903	14.0	2.5
1		710.91		0.105	2.18	45	69	13	246	259	54	1916	8.5	9.3
2		715.03	335	0.10	2.07	49	70	13	247	257	54	1927	12.5	3.4
3		719.02		0.19	2.06	45	70	14	248	256	53	1941	12	3.0
4		723.00	67	0.11	2.44	45	70	15	246	255	53	1775	8.0	9.5
5		727.38		0.11	2.45	45	71	16	247	256	53	1776	12.5	3.4
6		731.75	271	0.10	2.26	45	71	16	248	257	53	1735	12	3.0
7		735.92		0.13	2.53	45	72	18	247	256	54	1898	8.0	9.5
8		740.35	329	0.12	2.49	40	73	19	246	255	54	1938	12.5	3.4
9		744.77		0.10	2.06	45	74	19	245	256	55	1957	8.0	9.5
10		749.80	71	0.10	2.17	45	75	20	244	257	55	1896	12.5	3.4
11		754.89		0.09	1.99	45	75	20	244	258	55	1797	12.5	3.8
12	1145	759.85	300	0.09	1.88	45	76	20	245	259	55	1738	12.5	3.8
12		764.70		0.09	1.88	45	76	20	245	259	55	1738	12.5	3.8

CO ppm 0 0 0 0 0 0 0 0 0 0 0 0

Primary Ignition @ 0913 test Start @ 0933 Primary 341°C Secondary 900°C

2.0

PLANT	DeBeers Snap Lake	PROBE TIP DIAMETER, IN.	0.5623	IMPINGER	INITIAL	FINAL	TOTAL GAIN
RUN NO	2 - P/M Metals	PROBE LENGTH, FT / Cp	HT 4a / 0.8457	VOLUMES	(mL)	(mL)	(mL)
LOCATION	Incinerator 2	FILTER NUMBER		Imp. # 1	100	192	188
DATE	July 14, 2017			Imp. # 2	100	174	74
OPERATOR	LD	STATIC PRESSURE, IN. H ₂ O		Imp. # 3	-	10	10
CONTROL UNIT	Apex 522/0.9950	STACK DIAMETER	16"	Imp. # 4	100	106	6
	4H @ 1.8690	STACK HEIGHT	25'		100	104	4
		INITIAL LEAK TEST	0.001 @ 19"		0-e-1		
		FINAL LEAK TEST	0.001 @ 19"				

Point	Clock Time	Dry Gas Meter Ft ³	MAX (ppm)	Pitot IN. H ₂ O ΔP	Orifice ΔH IN. H ₂ O	Dry Gas Temp.		Pump Vac. IN. Hg Gauge	Temperature of		Stack Temperature of	Fyrites	
						Inlet of	Outlet of		Box	Probe		CO ₂ Vol. %	O ₂ Vol. %
1	13:50	864.309	481	0.085	1.88	79	80	6	246	258	1778	8.0	9.1
2		872.17	106	0.085	2.03	80	80	7.5	247	257	1628	12	5.6
3		876.16	91	0.10	2.00	81	82	8	248	256	1773	9.5	7.3
4		880.37	366	0.10	2.22	82	83	9.5	247	255	1767	13	1
5		884.60	366	0.095	2.24	83	84	10	247	254	1759	13	3
6		888.72	366	0.10	2.25	83	84	11	247	254	1761	13	4
7	Stop to Change Filter	892.98	366	0.095	2.12	84	85	13-20	246	255	1781	13	5
8		897.12	366	0.10	2.14	84	85	4	247	256	1878	13	7
9		901.28	102	0.09	2.06	85	85	4.5	246	257	1851	13	4
10		905.35	102	0.09	1.93	84	85	5.5	246	254	1889	8.0	8.3
11		909.30	102	0.09	1.93	85	85	7	247	257	1900	9.0	7.6
12		913.23	102	0.09	1.91	85	85		248	257	1816	10.5	8.5
1		916.96	109	0.08	1.71	85	86	7	249	256	1891	9.0	8.5
2		920.71	102	0.08	1.72	86	86	7	246	257	1879	12.5	1.5
3		924.56	119	0.085	1.85	85	86	8	246	256	1847	11.0	8.4
4		928.54	128	0.09	1.93	86	86	8	247	258	1816	12.5	7
5		932.55	253	0.09	1.98	86	87	8.5	247	257	1816	11.0	8.4
6		936.63	253	0.095	2.02	86	87	9	246	256	1832	12.5	7
7		940.60	253	0.09	1.94	86	87	9	247	257	1867	12.5	7
8		944.48	253	0.085	1.86	86	87	9	248	257	1836	12.5	7
9		948.47	253	0.09	1.92	87	88	9	247	256	1848	12.5	7
10		952.31	253	0.085	1.85	87	88	9	246	258	1858	12.5	7
11		956.09	253	0.08	1.74	87	88	9.5	247	257	1845	12.5	7
12	14:07	959.86	253	0.08	1.74	88	88	9.5	246	257	1852	12.5	7

CO ppm 1800
O₂ ppm 50
O₂ ppm 0
1800
78
5

HC add @ 11
HC 0.001 @ 16
Stop @ 25
@ 14:30
Restart

Primary Jamtion @ 12:50 Load = 260 lbs Metals start @ 13:50 Primary T = 510 °C Secondary T = 1000 °C

SA

PLANT	De Beers Soap Lake	PROBE TIP DIAMETER, IN.	0.5623	IMPINGER	INITIAL	FINAL	TOTAL GAIN
RUN No	3	PROBE LENGTH, FT / Cp	HT 40 / A.8457	VOLUMES	(mL)	(mL)	(mL)
LOCATION	Partic / Metals	FILTER NUMBER		Imp. # 1	100	252	182
DATE	Engineering 2			Imp. # 2	100	171	71
OPERATOR	July 15 2014			Imp. # 3		10	10
CONTROL UNIT / Y	Apex 522 / 4.9950	STATIC PRESSURE, IN. H ₂ O	+0.08	Imp. # 4	100	108	8
		STACK DIAMETER	16"		100	102	2
		STACK HEIGHT	231		Cre-1		
BAROMETRIC PRESSURE, IN. Hg	28.3	INITIAL LEAK TEST	0.001 @ 18 V	Upstream Diameters			
ASSUMED MOISTURE, Bw	13%	FINAL LEAK TEST	0.003 @ 21 V	Downstream Diameters			

Point	Clock Time	Dry Gas Meter Ft ³	NOx ppm	Pitot IN. H ₂ O ΔP	Orifice ΔH IN. H ₂ O	Dry Gas Temp.		Pump Vac. IN. Hg Gauge	Temperature of		Impinger Exit	Stack	Fyrites	
						Inlet of	Outlet of		Box	Probe			CO ₂ Vol. %	O ₂ Vol. %
1	10:15	960.470		0.095	2.00	79		3	248	258	53	1815	13.5	8.5
2		964.41	232	0.090	1.90	71		3	247	257	53	1805	13.5	8.5
3		968.29		0.10	2.10	70		3.5	247	257	52	1823	11.5	8.0
4		972.33	120	0.105	2.20	71		4	246	259	52	1819	10	8.0
5		976.47	132	0.105	2.20	73		4.5	245	259	52	1860	8.5	7.5
6		980.63		0.11	2.32	73		5.5	246	258	52	1822	11.5	6.5
7		984.85	150	0.105	2.19	74		6	247	256	52	1839	13.5	3.0
8		989.10	130	0.10	2.17	76		7	246	257	53	1874	11.5	6.5
9		993.22	130	0.10	2.08	77		8	246	255	53	1822	13.5	3.0
10		997.33	221	0.09	1.91	77		8.5	247	258	53	1880		
11		1001.42		0.09	1.87	78			248	257				
12		1005.29		0.09										
1		1009.15		0.09										
2		1013.03	128	0.09	1.91	79		9	247	256	54	1837	9.0	8.8
3		1017.00	180	0.095	1.99	79		10	246	255	54	1863	12.0	4.5
4		1021.09	193	0.10	2.11	80		11.5	245	257	55	1845	9.5	9.0
5		1025.00	124	0.09	1.93	79		12	246	258	55	1825	11.0	4.0
6		1029.09	81	0.10	2.13	79		13	247	257	55	1840	9.5	8.0
7		1033.12	124	0.10	2.13	80		14	246	258	55	1831	11.0	4.0
8		1037.33	193	0.10	2.13	80		14	246	257	50	1836	9.0	9.2
9		1041.34	124	0.095	1.98	80		14	245	257	50	1838	10.0	6.5
10		1045.26	81	0.09	1.91	80		14	246	256	50	1839		
11		1049.17	81	0.09	1.91	80		14	245	258	50	1862		
12		1053.06	81	0.085	1.79	81		14	246	257	51	1839		
1		1056.66	81	0.08	1.70	82		14.5	247	256	51	1839		

11/12/14
11/16/14
11/16/14

Primary Ignition @ 0835 Load: 560 lbs Metals start @ 10:15 Primary T = 705°C Secondary = 1090°C

ed

Point	Clock Time	Dry Gas Meter, PPH	Pitot IN. H ₂ O ΔP	Orifice ΔH IN. H ₂ O	Dry Gas Temp.		Pump Vac. IN. Hg Gauge	Temperature of		Impinger Stack	Fyrites	
					Inlet of	Outlet of		Box	Probe		CO ₂ Vol. %	O ₂ Vol. %
PLANT <i>DeBeer's Snap take</i> PROBE TIP DIAMETER, IN. PROBE LENGTH, FT / Cp FILTER NUMBER STATIC PRESSURE, IN. H ₂ O STACK DIAMETER STACK HEIGHT INITIAL LEAK TEST FINAL LEAK TEST Upstream Diameters Downstream Diameters												
1	13:55	181.5816				60						
2						61						
3						61						
4						62						
5						63						
6	14:55	181.9265				63						
0:00	10:32	181.9397				58						
0:10						61						
0:20	10:52	182.1402				64						
0:30						62						
0:40						64						
0:50	11:32	182.5310				65						
1:00						65						
0:00	9:33	182.5555				62						
0:10						62						
0:20						62						
0:30						64						
0:40						64						
0:50	10:33											
1:00	14:50	183.1527				74						
0:10						75						
0:20						75						
0:30						76						
0:40						76						
0:50						76						
1:00	15:50	183.6754				75						

1

2

30

3

ad

PLANT		PROBE TIP DIAMETER, IN.		IMPINGER		INITIAL		FINAL		TOTAL GAIN	
DR. Boers Swamp Lake		PROBE LENGTH, FT / Cp		VOLUMES		(mL)		(mL)		(mL)	
RUN No 1-3 SO _x		FILTER NUMBER		Imp. # 1		100		100			
LOCATION Inverter #2				Imp. # 2		100					
DATE July 13, 2014				Imp. # 3		0					
OPERATOR				Imp. # 4		66L					
CONTROL UNIT / Y LM-4											
BAROMETRIC PRESSURE, IN. Hg		INITIAL LEAK TEST 0.001		Temperature of		Box		0.002		0.000	
ASSUMED MOISTURE, Bw		FINAL LEAK TEST 0.001		Temperature of		0.001		0.001		0.000	
				Upstream Diameters							
				Downstream Diameters							
Point	Clock Time	Dry Gas Meter	Pitot	Orifice ΔH	Dry Gas Temp.	Pump Vac.	Temperature of	Impinger	Stack	CO ₂	O ₂
0:00	9:33	182.5555	IN. H ₂ O ΔP	IN. H ₂ O	Inlet of	IN. Hg Gauge	Box	Exit		Vol. %	Vol. %
0:10					62						
0:20					63						
0:30					64						
0:40					65						
0:50					68						
1:00	10:33	183.1405			70						
0:00	13:54	183.6852			60						
0:10					62						
0:20					62						
0:30					63						
0:40					65						
0:50					67						
1:00	14:54	184.2412			67						
0:00	10:15	184.2480			66						
0:10					67						
0:20					67						
0:30					68						
0:40					69						
0:50					71						
1:00	11:15	184.7476			72						
					70						

1

2

3

APPENDIX 5
CALIBRATION DATA

CEM FIELD DATA SHEET

Plant : De Beers Snaplake
 Source : Incinerator 1
 Date : July 11-13, 2014

Technician : LA
 Ambient Temp °C : _____
 Bar. Pressure in Hg : _____

Cylinder Gas Pressure (psi)

1 Gas	2 Gas	3 Gas	4 Gas	5 Gas	N ₂	O ₂	H ₂	Comb Air	Low meth	Mid meth	High meth
						20.9 (Amb)					

Certified Gas Value (ppm)

CO											
SO ₂											
NO _x											

Range

--	--	--	--	--	--	--	--	--	--	--	--

CEM Readings (Nova)

Time	Source	O ₂	CO ₂	CO	THC	SO ₂	NO _x	Response Time (sec)
								NO _x up
July 11/4	1300	Amb	20.9	0			0	NO _x dn
		N ₂	0.0	0			0	O ₂ up
								O ₂ dn
	1400	Amb	20.9	0			0	CO up
	1430	Amb	20.9	0			0	CO dn
	1500	Amb	20.9	0			0	CO ₂ up
								CO ₂ dn
	1750	Amb	20.9	0			0	SO ₂ up
		N ₂	0.0	0			0	SO ₂ dn
								THC up
								THC dn
July 12/14	0830	Amb	20.9	0			0	
		N ₂	0.0	0			0	
	1435	Amb	20.8	0			2	
		N ₂	-0.2	0			0	
July 13/14	0830	Amb	20.9	0			0	
		N ₂	0.0	0			0	
	1330	Amb	20.9	0			0	
		N ₂	0.1	0			0	
	1715	Amb	20.9	0			0	
		N ₂	0.1	0			0	

A.Lanfranco & Associates inc.

EPA Method 5
Meter Box Calibration
English Meter Box Units, English K' Factor

Model #: CAE2
Serial #: 28-072911-1

Date: 30-Apr-14
Barometric Pressure: 30.30 (in. Hg)
Theoretical Critical Vacuum: 14.29 (in. Hg)

!!!!!!
IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)³/(deg R)^{0.5}((in Hg)^{0.5}(min)).
!!!!!!

----- DRY GAS METER READINGS -----										-CRITICAL ORIFICE READINGS-					
dH (in H2O)	Time (min)	Volume		Volume Total (cu ft)	Initial Temps.		Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	-- Ambient Temperature --			
		Initial (cu ft)	Final (cu ft)		Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)	
0.35	15.00	69.400	74.068	4.668	75.0	75.0	75.0	76.0	40	0.2408	24.5	76.0	79.0	77.5	
0.69	17.00	61.500	69.234	7.734	76.0	76.0	75.0	75.0	48	0.3560	23.0	76.0	75.0	76.5	
1.18	15.00	51.500	60.479	8.979	72.0	72.0	74.0	74.0	55	0.4606	21.5	76.0	72.0	74.0	
1.98	16.00	39.000	51.289	12.289	71.0	71.0	69.0	69.0	63	0.5956	19.7	74.0	73.0	73.5	
3.85	19.00	18.500	38.438	19.938	71.0	71.0	70.0	70.0	73	0.8185	16.8	72.0	73.0	72.5	

***** RESULTS *****												
-- DRY GAS METER --		----- ORIFICE -----			-- DRY GAS METER --		----- ORIFICE -----					
VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME NOMINAL	Value	Variation	Value	Value	Variation	Ko		
Vm(std) (cu ft)	Vm(std) (liters)	Vcr(std) (cu ft)	Vcr(std) (liters)	Vcr (cu ft)	(number)	(number)	(in H2O)	(mm H2O)	(in H2O)	(value)		
4.663	132.1	4.721	133.7	4.747	1.012	0.002	1.985	50.41	0.119	0.680		
7.732	219.0	7.917	224.2	7.947	1.024	0.014	1.787	45.39	-0.079	0.709		
9.030	255.7	9.059	258.6	9.051	1.003	-0.007	1.826	46.37	-0.040	0.715		
12.453	352.7	12.501	354.0	12.478	1.004	-0.006	1.841	46.75	-0.025	0.711		
20.276	574.2	20.420	578.3	20.344	1.007	-0.003	1.890	48.00	0.024	0.698		
Average Y----->					1.0101	Average dH@----->		1.866	47.4	Average Ko----->		0.703

TEMPERATURE CALIBRATION			
Calibration Standard ----->		Omega Model CL23A S/N:T-218768	
Reference Temperature Set-Point (deg F)	Temperature Device Reading (deg F)	Variation (deg F)	Percent of Absolute
32	33	1	0.20%
100	101	1	0.18%
300	301	1	0.13%
500	502	2	0.21%
1000	1001	1	0.07%

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.
For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 58 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +0.2.
For Temperature Devices, the reading must be within 1.5% of certified calibration standard (absolute temperature) to be acceptable.

SIGNED 

Date: Apr. 30/14

A. LANFRANCO AND ASSOCIATES INC.

EPA Method 5
Meter Box Calibration
English Meter Box Units, English K' Factor

Model #: Apex Inst. Model 522
Serial #:

Date: June, 10/14
Barometric Pressure: 29.95 (in. Hg)
Theoretical Critical Vacuum: 14.13 (in. Hg)

!!!!!!!
IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)³/(deg R)³/(in.Hg)²(min).
!!!!!!!


----- DRY GAS METER READINGS -----										-CRITICAL ORIFICE READINGS-					
dH (in H ₂ O)	Time (min)	Volume		Volume Total (cu ft)	Initial Temps.		Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	-- Ambient Temperature --			
		Initial (cu ft)	Final (cu ft)		Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)	
3.90	16.00	306.000	323.248	17.248	79.0	78.0	78.0	75.0	73	0.8185	18.0	72.0	72.0	72.0	
2.10	15.00	323.248	335.040	11.792	76.0	75.0	76.0	75.0	63	0.5956	21.0	73.0	72.0	72.5	
1.25	15.00	335.040	344.233	9.193	76.0	75.0	76.0	75.0	55	0.4606	23.0	73.0	72.0	72.5	
0.66	15.00	363.880	370.848	6.968	76.0	75.0	76.0	75.0	48	0.3560	23.0	73.0	72.0	72.5	
0.31	24.00	356.276	383.880	7.604	76.0	75.0	76.0	75.0	40	0.2408	25.0	73.0	73.0	73.0	

--- DRY GAS METER ---		----- ORIFICE -----			-- DRY GAS METER --		----- ORIFICE -----					
VOLUME CORRECTED Vm(std) (cu ft)	VOLUME CORRECTED Vm(std) (liters)	VOLUME CORRECTED Vcr(std) (cu ft)	VOLUME CORRECTED Vcr(std) (liters)	VOLUME NOMINAL Vcr (cu ft)	Value (number)	Variation (number)	Value (in H ₂ O)	Value (mm H ₂ O)	Variation (in H ₂ O)	Ko (value)		
17.132	485.2	17.005	481.6	17.124	0.993	-0.002	1.913	48.60	0.044	0.694		
11.694	331.2	11.595	328.4	11.667	0.992	-0.003	1.953	49.60	0.084	0.689		
9.098	257.6	8.987	253.9	9.038	0.988	-0.009	1.944	49.37	0.075	0.695		
6.886	195.0	6.931	196.3	6.986	1.006	0.012	1.770	44.96	-0.099	0.714		
7.508	212.6	7.497	212.3	7.564	0.999	0.004	1.765	44.84	-0.104	0.721		
Average Y----->					0.9950	Average dH@----->		1.8690	47.47	Average Ko----->		0.7027

TEMPERATURE CALIBRATION			
Calibration Standard ----->		Omega Model CL23A S/N T-218768	
Reference Temperature Set-Point (deg F)	Temperature Device Reading (deg F)	Variation (deg F)	Percent of Absolute
32	33	1	0.20%
100	99	-1	-0.18%
300	298	-2	-0.26%
500	498	-2	-0.21%
1000	995	-5	-0.34%

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/-0.02.
For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H₂O that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/-0.2.
For Temperature Device, the reading must be within 1.5% of certified calibration standard (absolute temperature) to be acceptable.

SIGNED _____



Date: June 10/14

June 10/14

Pitot Tube Calibration

Date: 27-Jun-14
Pbar (in.Hg): 30.25

Temp (R): 530
Dn (in.): 0.25

Pitot ID: **4A**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.620	0.860	51.8	0.8406	0.0056
0.520	0.730	47.5	0.8356	0.0006
0.370	0.520	40.0	0.8351	0.0001
0.240	0.340	32.3	0.8318	0.0032
0.120	0.170	22.8	0.8318	0.0032
Average :			0.8350	0.0025

Pitot ID: **HT-4A**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.080	0.110	18.6	0.8443	0.0014
0.250	0.350	32.9	0.8367	0.0090
0.360	0.490	39.5	0.8486	0.0029
0.520	0.700	47.5	0.8533	0.0076
Average :			0.8457	0.0052

Pitot ID: **4A-1**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.130	0.180	23.7	0.8413	0.0007
0.150	0.210	25.5	0.8367	0.0040
0.320	0.440	37.2	0.8443	0.0036
0.420	0.580	42.7	0.8425	0.0018
0.660	0.920	53.5	0.8385	0.0021
Average :			0.8407	0.0024

Pitot ID: **HT-4B**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.080	0.110	18.6	0.8443	0.0014
0.240	0.330	32.3	0.8443	0.0014
0.350	0.480	39.0	0.8454	0.0003
0.510	0.690	47.0	0.8511	0.0054
Average :			0.8463	0.0022

Pitot ID: **4A-2**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.100	0.140	20.8	0.8367	0.0000
0.300	0.420	36.1	0.8367	0.0000
0.400	0.560	41.6	0.8367	0.0000
0.620	0.870	51.8	0.8357	0.0009
0.730	1.020	56.3	0.8375	0.0008
Average :			0.8367	0.0004

Pitot ID:

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
Average :				


Pitot ID: **4B**

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
0.630	0.880	52.3	0.8377	0.0007
0.540	0.750	48.4	0.8400	0.0031
0.390	0.550	41.1	0.8337	0.0033
0.250	0.350	32.9	0.8367	0.0002
0.100	0.140	20.8	0.8367	0.0002
Average :			0.8370	0.0015

Pitot ID:

Reference Pitot (in H2O)	S-Type Pitot (in H2O)	Air Velocity (ft/s)	Pitot Coeff. Cp	Deviation (absolute)
Average :				

* Average absolute deviation must not exceed 0.01.



Calibrated by A. Lanfranco and Associates Inc.

A. LANFRANCO and ASSOCIATES INC.

ENVIRONMENTAL CONSULTANTS

UNI PROBE NOZZLE DIAMETER CALIBRATION FORM

Technician: C. Lanfranco

Date: June. 10/14

Signature: _____



Nozzle I.D.	d1 (inch)	d2 (inch)	d3 (inch)	difference (inch)	average dia. (inch)	average area (ft ²)
4Q - A	0.4680	0.4680	0.4670	0.0010	0.4677	0.0011929
4Q - B	0.4690	0.4695	0.4695	0.0005	0.4693	0.0012014
4Q - C	0.5190	0.5180	0.5180	0.0010	0.5183	0.0014654
4Q - D	0.5120	0.5100	0.5120	0.0020	0.5113	0.0014261
4Q - E	0.5065	0.5070	0.5075	0.0010	0.5070	0.0014020
4Q - F	0.6570	0.6575	0.6570	0.0005	0.6572	0.0023555
4Q - G	0.6520	0.6530	0.6520	0.0010	0.6523	0.0023210
New/Old 3A	0.5620	0.5620	0.5630	0.0010	0.5623	0.0017247
No-Name	0.5080	0.5080	0.5090	0.0010	0.5083	0.0014094

Where:

- (a) D1, D2, D3 = three different nozzle diameters; each diameter must be measured to within (0.025mm) 0.001 in.
- (b) Difference = maximum difference between any two diameters; must be less than or equal to (0.1mm) 0.004 in.
- (c) Average = average of D1, D2 and D3

BAROMETER CALIBRATION FORM

Device	Cal Date	Pbar Env Canada		Device (inches of Hg)		Difference (Env Can - Elv Corr)
		(kPa)	(inches of Hg)	Reading	Elevation Corrected	
LA	January 9, 2014	101.0	29.83	29.71	29.783	0.05
DS	January 9, 2014	101.0	29.83	29.74	29.813	0.02
CL	January 9, 2014	101.0	29.83	29.70	29.773	0.06
AL	January 9, 2014	101.0	29.83	29.71	29.783	0.05
ML	January 9, 2014	101.0	29.83	29.70	29.773	0.06
MH	January 9, 2014	101.0	29.83	29.74	29.813	0.02
SH	January 9, 2014	101.0	29.83	29.70	29.773	0.06
JZ	January 9, 2014	101.0	29.83	29.70	29.773	0.06
JB	January 9, 2014	101.0	29.83	29.73	29.803	0.03

Performance Specification is
Device Corrected for Elevation must be +/- 0.1 " Hg of ENV CANADA SEA-LEVEL Pbar
 Enter Environment Canada Pressure from their website for Vancouver (link below)
 and the reading from your barometer on the ground floor of the office.

http://www.weatheroffice.gc.ca/city/pages/bc-74_metric_e.html

EPA Method 5
Meter Box Calibration
English Meter Box Units, English K' Factor

Model #: LM 4
Serial #: n/a

Date: Jan.6/14
Barometric Pressure: 30.05 (in. Hg)
Theoretical Critical Vacuum: 14.17 (in. Hg)


!!!!!!!
IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)³/(deg R)^{0.5}/((in.Hg)*(min)).
!!!!!!!

----- DRY GAS METER READINGS -----										-CRITICAL ORIFICE READINGS-				
dH (in H2O)	Time (min)	Volume Initial (cu ft)	Volume Final (cu ft)	Volume Total (cu ft)	Initial Temps.		Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	-- Ambient Temperature --		
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)
0.00	15.00	180.462	180.714	8.899	67.0	67.0	67.0	67.0	55	0.4606	14.0	62.0	61.0	61.5
0.00	16.00	180.714	180.984	9.517	65.0	65.0	65.0	65.0	55	0.4606	14.0	61.0	61.0	61.0
0.00	15.00	180.984	181.181	6.989	65.0	65.0	66.0	66.0	48	0.3560	14.0	62.0	61.0	61.5

***** RESULTS *****												
--- DRY GAS METER ---			----- ORIFICE -----			-- DRY GAS METER --			----- ORIFICE -----			
VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME NOMINAL	CALIBRATION FACTOR		CALIBRATION FACTOR		CALIBRATION FACTOR		Ko (value)	
Vm(std) (cu ft)	Vm(std) (liters)	Vcr(std) (cu ft)	Vcr(std) (liters)	Vcr (cu ft)	Value (number)	Variation (number)	Value (in H2O)	Value (mm H2O)	Variation (in H2O)	dH@		
8.951	253.5	9.091	257.5	8.944	1.016	0.008	0.000	0.00	0.000		#DIV/0!	
9.610	272.1	9.702	274.8	9.536	1.010	0.002	0.000	0.00	0.000		#DIV/0!	
7.050	199.6	7.027	199.0	6.913	0.997	-0.011	0.000	0.00	0.000		#DIV/0!	
Average Y---->					1.0073	Average dH@-->		0.00	0.0	Average Ko-->		#DIV/0!


TEMPERATURE CALIBRATION				
Calibration Standard -----> Omega Model CL23A S/N:T-218768				
Reference Temperature Set-Point (deg F)	Temperature Device Reading (deg F)	Variation (degF)	Results	
			Percent of Absolute	
32	n/a	-32	-6.51%	
100		-100	-17.87%	
300		-300	-39.49%	
800		-800	-63.51%	
1700		-1700	-78.72%	

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/-0.02.
For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/-0.2.
For Temperature Device, the reading must be within 1.5% of certified calibration standard (absolute temperature) to be acceptable.

SIGNED: 

Date: Jan. 6/14

Calibration Certificate

Date: 10-Jul-14
Technician: M. Harrington
Signature: 
Instrument: _____
Calibrated: Nova 1 (New Nova)

O2

Gas	Instrument Reading	Certified Value	% Calibration Error
Zero	0.1	0.0	0.1
O2/CO2	10.9	10.9	0.0
Ambient	20.9	20.9	0.0

Performance Specification: +/- 1% O2 (absolute diff)

CO

Gas	Instrument Reading	Certified Value	% Calibration Error
Zero	0	0	0.0
1 Gas	466	463	0.6
2 Gas	245	240	2.1
3 Gas			
4 Gas			
5 Gas			

Performance Specification: +/- 5% of Certified Gas Value

Nox

Gas	Instrument Reading	Certified Value	% Calibration Error
Zero	0	0	0.0
1 Gas	465	464	0.2
2 Gas	240	236	1.7
3 Gas			
4 Gas			
5 Gas			

Performance Specification: +/- 5% of Certified Gas Value